

Improvement of a Surfactant Blend for Enhanced Oil Recovery in Carbonate Reservoirs by Means of an Ionic Liquid

Nestor Tafur ¹, Alberto P. Muñuzuri ² and Ana Soto ^{1,*}

¹ CRETUS, Department of Chemical Engineering, Universidade de Santiago de Compostela, 15782 Santiago de Compostela, Spain

² Group of Nonlinear Physics, Galician Center for Mathematical Research and Technology (CITMAga), 15782 Santiago de Compostela, Spain

* Correspondence: ana.soto@usc.es

AOT/[C₁₂mim]Br/LF2 blend scan




Figure S1. AOT/[C₁₂mim]Br + LF2 blend scan as a function of AOT/[C₁₂mim]Br ratio. (a) AOT/[C₁₂mim]Br [50%] + LF2 [50%]. (b) AOT/[C₁₂mim]Br [40%] + LF2 [60%]. Test temperature 25°C. N-octane as oil phase.