Article

Evaluation of Harmonic Contributions for Multi Harmonic Sources System Based on Mixed Entropy Screening and an Improved Independent Component Analysis Method

Jinshuai Zhao, Honggeng Yang, Xiaoyang Ma * and Fangwei Xu

The College of Electrical Engineering, Sichuan University, Chengdu 610065, China;
2017323030005@stu.scu.edu.cn (J.Z.); pqlab_99@126.com (H.Y.); xufangwei__scu@163.com (F.X.)

* Correspondence: mxy__scu@163.com

Received: 17 February 2020; Accepted: 10 March 2020; Published: 12 March 2020

Abstract: Evaluating the harmonic contributions of each nonlinear customer is important for harmonic mitigation in a power system with diverse and complex harmonic sources. The existing evaluation methods have two shortcomings: (1) the calculation accuracy is easily affected by background harmonics fluctuation; and (2) they rely on Global Positioning System (GPS) measurements, which is not economic when widely applied. In this paper, based on the properties of asynchronous measurements, we propose a model for evaluating harmonic contributions without GPS technology. In addition, based on the Gaussianity of the measured harmonic data, a mixed entropy screening mechanism is proposed to assess the fluctuation degree of the background harmonics for each data segment. Only the segments with relatively stable background harmonics are chosen for calculation, which reduces the impacts of the background harmonics in a certain degree. Additionally, complex independent component analysis, as a potential method to this field, is improved in this paper. During the calculation process, the sparseness of the mixed matrix in this method is used to reduce the optimization dimension and enhance the evaluation accuracy. The validity and the effectiveness of the proposed methods are verified through simulations and field case studies.

Keywords: harmonic contribution; multiple harmonic sources; asynchronous measurement; complex independent component analysis; mixed entropy screening mechanism

1. Introduction

Harmonic sources in a power system become complex and diverse as more nonlinear customers connected to the power grid [1,2]. For a bus with serious harmonic distortion, evaluating the contribution of each customer is essential to identify the dominant harmonic source and to design the effective scheme for harmonic pollution mitigation [3].

In general, the evaluation models are classified into two categories (Figure 1): single point and multipoint models. In the single point model, the power grid is divided into the utility and the customer sides at the point of common coupling (PCC), indicating that there is only one suspicious harmonic source. The typical methods to solve this model include the fluctuation method [4], a series of regression methods [5] and covariance method [6]. Yet, one common limitation of these methods is that they are only suitable when the background harmonics are stable. To reduce the impacts of the background harmonics, from 2015, independent component analysis method (ICA) [7,8] was applied to this researching field [9–12]. Compared with the classical methods, ICA has a higher calculation accuracy even when the background harmonics fluctuate. Thus, it becomes a popular technology to solve the single point model.

Figure 1. Models for evaluating harmonic contributions.

Although the single point model has been widely studied, it is suitable only when a nonlinear customer is directly connected at the concerned bus. However, in practice, harmonic distortion of a bus is usually caused by amplification of harmonics generated by a non-adjacent customer [13]; thus, the single point model is inapplicable in these cases. Furthermore, the wide use of cables in a power grid can potentially increase the risk of harmonic amplification [14,15], which further limits the application of this model. The above limitations have led to research on the multipoint model. This model contains centralized [16,17] and decentralized [18–21] categories as shown in Figure 1. Nonlinear customers in the centralized model are directly connected at the concerned bus (the PCC). Thus, for a certain customer, the other harmonic sources can be classified into the utility side. As a result, the circuit model can be equivalent to the single point model with similar limitations. In comparison, the decentralized model allows customers to not be directly connected at the concerned bus; thus, it can describe the problem of harmonic contribution more comprehensively.

Compared with the single point model, the developments of the decentralized multipoint model are relatively late. In 2009, a widely accepted index quantifying the harmonic contributions of each nonlinear customer on a concerned bus was proposed by Xu [18]. The idea of this index is that the harmonic contribution of the i -th harmonic source can be reflected by the projection of $\dot{U}_i$ on $\dot{U}_X$, where $\dot{U}_i$ denotes the harmonic voltage generated by the i -th harmonic source on the concerned bus, while $\dot{U}_X$ is the harmonic voltage measured at the concerned bus. Based on this index, several methods were proposed to solve the decentralized multipoint model.

In other studies [18,19], a least squares method was proposed based on the assumptions that the background harmonics are stable and that only one harmonic source fluctuates at a time segment. Although the least squares method is one of the classical methods for harmonic contributions evaluation, in practice, its necessary assumptions are hard to hold for two reasons: (1) a large number of complex nonlinear customers exists in the modern power system, which increases the fluctuation of background harmonics, and (2) it is hard to ensure only one harmonic source fluctuates at a time segment when multiple suspicious harmonic sources are involved. Thus, the application scope of the least squares method is limited. To make the method effective when multiple harmonic sources fluctuate simultaneously, a multiple linear regression method was proposed by Wang and colleagues [20]. This method assumes that for each harmonic source, the phases between $\dot{U}_i$ and $\dot{U}_X$ are approximately constant. However, since $\dot{U}_X$ is generally generated by several nonlinear customers in a multi harmonic

sources system, this assumption is hard to hold. Moreover, during the execution of the multiple linear regression method, the background harmonics are still required to be stable. Thus, it has the same limitations as the least squares method. To ensure evaluation accuracy even when background harmonics fluctuate, Wang and co-workers [21] expanded the application of the complex independent component analysis method (CICA) from the single point model to the decentralized multipoint model. Compared with the former two methods, CICA has a superior ability to resist the impacts from the background harmonics. Yet, the calculation results are still unsatisfactory when the background harmonics fluctuate greatly. In addition, the essence of CICA is to reconstruct the source signals based on a negative entropy maximization algorithm. When many suspicious harmonic sources are involved, the calculation burden may increase, and the evaluation accuracy is thus decreased. Furthermore, the CICA method and the evaluation referred to by Wang and co-workers [21] rely on measurements with a Global Positioning System (GPS)-synchronized function that can synchronize the measuring time [18–24]. However, in engineering practice, it is not realistic to install GPS-based measurements at all related buses because it is uneconomical [6]. Owing to the above three limitations, the existing CICA-based evaluation method still has room for improvements. An overview of the developments and the limitations of the existing methods are shown in Figure 2.

Figure 2. Developments and limitations of the existing methods.

To overcome the shortcomings of the existing CICA method and further accurately evaluate the harmonic contribution for each harmonic source, an improved CICA method is proposed in this paper. First, the properties of asynchronous measurements are explored, and a model independent of GPS is proposed for evaluating harmonic contributions. Then, according to the Gaussianity of the measured harmonic data, a mixed entropy screening mechanism is proposed to select the data segments where the background harmonics are relatively stable. Finally, based on the sparseness of the mixed matrix in the blind source separation model, the optimization dimensions for maximizing the negative entropy

in CICA are remarkably decreased. Thus, the calculation burden is significantly reduced, which enhances the evaluation accuracy of the harmonic contributions. Compared with the least squares and multiple linear regression methods, the corresponding assumptions are no longer needed in the proposed method. Meanwhile, as shown in Figure 2, the improved method has three advantages compared with the traditional CICA: (1) it does not rely on GPS-based measurements; (2) it is able to select data segments with stable background harmonics; and (3) it ensures a high calculation accuracy even when the background harmonics fluctuate and/or the number of suspicious harmonics sources is large. The performance of the proposed method is validated by simulations on the IEEE 14-bus system and field case studies with actual multi-infeed high voltage direct current (HVDC) system. For the convenience of reading and understanding, symbols involved in this paper are described in Table 1.

Table 1. Description of the symbols involved in this paper.

Symbol	Description
$\dot{U}_X$	the h -th harmonic voltages measured at the concerned bus
$\dot{U}_i$	the harmonic voltages generated by the customer i at the concerned bus
$\dot{U}_0$	the background harmonic voltages
α_i	the unknown relative phase between the synchronous and asynchronous measurements of the customer i
θ_i	the angle between $\dot{U}_i$ and $\dot{U}_X$
$\sigma_{X,i}$	the harmonic contribution of customer i
$\dot{I}_i$	the harmonic currents measured at the point of common coupling (PCC) of the customer i
$\dot{I}_{c,i}$	the harmonic currents generated from the customer i
$\dot{I}_{c,i}^{\alpha_i}$	the simplified representation of $e^{j\alpha_i}\dot{I}_{c,i}$
$Z_{c,i}$	the harmonic impedance of the customer i
$Z_{u,i}$	the harmonic impedance of the utility side of the customer i
$Z_{X,i}$	the transfer impedance between the customer i and bus X
$Z_{X,i}^{\alpha_i}$	the simplified representation of $e^{-j\alpha_i}Z_{X,i}$
superscript “fast”	the fast-varying components of a signal
superscript “^”	the calculated results
superscript “T”	the Hermitian transpose
X	the observed signals in the blind source separation model
A	the mixed matrix in the blind source separation model
S	the source signals in the blind source separation model
Y	the signals separated from the complex independent component analysis (CICA)
X_W	signal X after being whitened
Q	the whitening matrix of the observed signals
Λ	the diagonal matrix of eigenvalues of $E\{XX^T\}$
Γ	the orthogonal matrix of eigenvalues of $E\{XX^T\}$
W	the separating matrix
Θ	the inverse of Q
$H(s)$	the entropy of a signal
$H[s]$	the mixed entropy of a signal
σ_H	an index to assess the stability of the background harmonics
H_m	the average value of $H\left[\dot{U}_X^{\text{fast}}\right]$ for all the data segments
$E\{\cdot\}$	calculate the mean value of a signal
$std\{\cdot\}$	calculate the standard deviation of a signal
$J_G(\cdot)$	calculate the negative entropy of a signal

2. Decentralized Multipoint Model for Evaluating Harmonic Contributions

2.1. Model with Synchronized Phasor Measurements

The task of the multipoint model is to evaluate the contribution for each harmonic source at the concerned bus as presented in Figure 3, where $\dot{U}_X$ is the harmonic voltages measured at the concerned bus, $\dot{U}_0$ is the background harmonic voltages, $\dot{U}_i (i = 1, 2, 3)$ is the harmonic voltages generated by the customer i at the concerned bus, $\dot{I}_{c,i}$ is the harmonic currents generated from the customer i , $Z_{c,i}$ is the harmonic impedance of customer i , and $\dot{I}_i$ is the harmonic currents measured at the PCC of customer i . Among the above harmonic parameters, only $\dot{U}_X$ and $\dot{I}_i$ can be measured directly, while other parameters are unknown. Notably, the relative phases between $\dot{U}_X$ and each $\dot{I}_i$ are obtained from the GPS-based synchronized phasor measurements.

Figure 3. Harmonic model of the concerned bus.

In the decentralized multipoint model of Figure 3, the h -th harmonic voltages at the concerned bus ($\dot{U}_X$) are generated by all the harmonic sources in the power grid as shown in Figure 4 and Equation (1).

$$\begin{cases} \dot{U}_X = \dot{U}_0 + \sum_{i=1}^{N-1} \dot{U}_i \\ \dot{U}_i = \dot{I}_{c,i} Z_{X,i} \end{cases} \quad (1)$$

where $Z_{X,i}$ is the harmonic transfer impedance between customer i and bus X , and $N - 1$ is the number of suspicious harmonic sources.

Figure 4. Harmonic voltage at bus X .

By projecting $\dot{U}_i$ onto $\dot{U}_X$, we obtain the harmonic contribution for customer i as:

$$\sigma_{X,i} = \frac{|\dot{U}_i| \cdot \cos(\theta_i)}{|\dot{U}_X|} \times 100\%. \quad (2)$$

Thus, accurately calculating the transfer impedance $Z_{X,i}$ is the key to evaluating the harmonic contribution for each customer.

To calculate $Z_{X,i}$, the first step is to estimate the harmonic currents $\dot{I}_{c,i}$ generated from each suspicious harmonic source [21]. This can be done by solving the single point model for each customer. The equivalent harmonic circuit of customer i is shown in Figure 5, where the harmonic voltages $\dot{U}_i^{\text{PCC}}$ and currents $\dot{I}_i$ can be measured directly at the PCC. $\dot{I}_{u,i}$ and $Z_{u,i}$ are respectively the harmonic current and impedance of the utility side.

Figure 5. Circuit of the single point model for customer i .

According to Figure 5, we have

$$\begin{bmatrix} \dot{U}_i^{\text{PCC}} \\ \dot{I}_i \end{bmatrix} = \begin{bmatrix} \frac{Z_{u,i}Z_{c,i}}{Z_{u,i}+Z_{c,i}} & \frac{Z_{u,i}Z_{c,i}}{Z_{u,i}+Z_{c,i}} \\ -\frac{Z_{u,i}}{Z_{u,i}+Z_{c,i}} & \frac{Z_{c,i}}{Z_{u,i}+Z_{c,i}} \end{bmatrix} \begin{bmatrix} \dot{I}_{u,i} \\ \dot{I}_{c,i} \end{bmatrix}, \quad (3)$$

Generally, the fast-varying components of $\dot{I}_{c,i}$ and $\dot{I}_{u,i}$ separated from an average filter are approximately independent [9–11,21]. Thus, the CICA method can be adopted to solve Equation (3), and then $\dot{I}_{c,i}$ is obtained (the solving processes were introduced in [9,10] in detail; to avoid repetition, the specific calculation steps are omitted here). After the harmonic currents $\dot{I}_{c,i}$ are generated from each harmonic source estimated, we establish the corresponding blind source separation model as [21]:

$$\underbrace{\begin{bmatrix} \dot{U}_X \\ \dot{I}_{c,1} \\ \dot{I}_{c,2} \\ \vdots \\ \dot{I}_{N-1} \end{bmatrix}}_X = \underbrace{\begin{bmatrix} Z_{X,1} & Z_{X,2} & \cdots & Z_{X,N-1} & 1 \\ 1 & 0 & \cdots & 0 & 0 \\ 0 & 1 & 0 & \cdots & 0 \\ \vdots & \vdots & \ddots & \vdots & \vdots \\ 0 & 0 & \cdots & 1 & 0 \end{bmatrix}}_A \underbrace{\begin{bmatrix} \dot{I}_{c,1} \\ \dot{I}_{c,2} \\ \vdots \\ \dot{I}_{N-1} \\ \dot{U}_0 \end{bmatrix}}_S, \quad (4)$$

Since the fast-varying components among each $\dot{I}_{c,i}$ and $\dot{U}_0$ are approximately independent, Equation (4) can also be solved by the CICA method [21] as

$$\underbrace{\begin{bmatrix} \dot{U}_X^{\text{fast}} \\ \dot{I}_{c,1}^{\text{fast}} \\ \dot{I}_{c,2}^{\text{fast}} \\ \vdots \\ \dot{I}_{c,N-1}^{\text{fast}} \end{bmatrix}}_X = \underbrace{\begin{bmatrix} k_1 \hat{Z}_{X,1} & k_2 \hat{Z}_{X,2} & \cdots & k_{N-1} \hat{Z}_{X,N-1} & 1 \\ k_1 & 0 & \cdots & 0 & 0 \\ 0 & k_2 & 0 & \cdots & 0 \\ \vdots & \vdots & \ddots & \vdots & \vdots \\ 0 & 0 & \cdots & k_{N-1} & 0 \end{bmatrix}}_A \underbrace{\begin{bmatrix} \hat{I}_{c,1}^{\text{fast}} \\ \hat{I}_{c,2}^{\text{fast}} \\ \vdots \\ \hat{I}_{c,N-1}^{\text{fast}} \\ \hat{U}_0^{\text{fast}} \end{bmatrix}}_Y, \quad (5)$$

where the superscript “fast” represents the fast-varying components of each signal; the separated signals $Y = \begin{bmatrix} \hat{I}_{c,1}^{\text{fast}} & \hat{I}_{c,2}^{\text{fast}} & \cdots & \hat{I}_{c,N-1}^{\text{fast}} & \hat{U}_0^{\text{fast}} \end{bmatrix}^T$ correspond to the source signals $\begin{bmatrix} \dot{I}_{c,1}^{\text{fast}} & \dot{I}_{c,2}^{\text{fast}} & \cdots & \dot{I}_{c,N-1}^{\text{fast}} & \dot{U}_0^{\text{fast}} \end{bmatrix}^T$ with scaling indeterminacy [9–11,21]. This indeterminacy is indicated by the unknown complex coefficients k_i . The transfer impedances $Z_{X,i}$ can be obtained as:

$$\hat{Z}_{X,i} = \hat{A}_{1,i} / \hat{A}_{i+1,i}, \quad (6)$$

where $\hat{A}_{i+1,i}$ denotes the element that corresponds to the $(i + 1)$ -st row and i -th column of matrix $\hat{A}$.

Based on the calculated $\hat{Z}_{X,i}$ and Equation (4), we can recover the matrix $\hat{A}$ that does not contain k_i , and thus, the scaling indeterminacy of the separated signals Y is solved. Finally, on the basis of the obtained $\hat{Z}_{X,i}$ and $\hat{U}_0$, the harmonic contribution for each customer can be assessed by using Equations (1) and (2).

2.2. Model with Asynchronized Phasor Measurements

The above model is largely based on GPS-based synchronized phasor measurements, which is not practical as previously stated [6]. As a result, in many cases it is hard to obtain the relative phases between $\hat{U}_X$ and each $\hat{I}_i$ in Equation (1). To solve this problem, we propose a novel evaluation model in this section.

2.2.1. Properties of Asynchronous Measurements

Under conditions without GPS technology, a tiny and unknown time difference Δt exists between the starting times of two measurements. For instance, the voltage waves measured at bus X satisfy

$$U_X(t) = U_{X0} + \sum_{h=1}^{\infty} H_{Xh} \cos(h\omega_1 t + \phi_{Xh}), \quad (7)$$

where U_{X0} is the magnitude of the direct current (DC) component; H_{Xh} and ϕ_{Xh} are the magnitude and initial angle of the h -th harmonic, respectively; and $\omega_1 = 2\pi f_1$ where f_1 is the fundamental frequency.

Assuming the starting time of measurement at bus A is Δt behind that of measurement at bus X, we have

$$U_A(t) = U_{A0} + \sum_{h=1}^{\infty} H_{Ah} \cos[h\omega_1(t + \Delta t) + \phi_{Ah}], \quad (8)$$

Equation (8) can also be transformed into

$$\begin{cases} U_A(t) = U_{A0} + \sum_{h=1}^{\infty} H_{Ah} \cos[h\omega_1 t + (\phi_{Ah} + \alpha_A)] \\ \alpha_A = h\omega_1 \Delta t \end{cases}, \quad (9)$$

Adopting the discrete Fourier transform (DFT) for $U_A(t)$, we obtain the amplitude and initial angle for the h -th harmonic as H_{Ah} and $(\phi_{Ah} + \alpha_A)$. Additionally, if the starting time of measurement at bus A is advanced by Δt , the measurements at buses A and X will be synchronized, and thus, the corresponding DFT results become H_{Ah} and ϕ_{Ah} . Therefore, two conclusions can be drawn theoretically for the h -th harmonic obtained from the DFT:

- The amplitudes are the same for the synchronous and asynchronous measurements.
- The initial angular difference between the synchronous and asynchronous measurements is $h\omega_1 \Delta t$ (Δt is unknown).

In practice, all of the measuring data are usually divided into several segments to detect the harmonics. Since Δt is the same for each segment, the angular difference between the synchronous and asynchronous measurements is constant for each data segment.

We further verify the properties of asynchronous measurements for three practice cases: (1) a wind farm; (2) a photovoltaic station; and (3) nonlinear loads with computers and light-emitting diode (LED) lights. The harmonic voltages (5th, 7th, and 11th) obtained from the DFT transformation for each time segment (0.02 s) are defined as $\mathbf{U}_1$. After manually creating a measurement delay, we define the corresponding DFT results as $\mathbf{U}_2$. Figure 6 presents the difference between $\mathbf{U}_1$ and $\mathbf{U}_2$. For each

case, $|U_1| - |U_2| = 0$ and the differences between $\angle U_1$ and $\angle U_2$ are constant; thus, the aforementioned two properties are valid. Consequently, the amplitudes of harmonics detected from synchronous and asynchronous data are the same, while their phase differences are constant.

Figure 6. Amplitude and phase analysis of three practice cases: (a) wind farm; (b) photovoltaic station; and (c) nonlinear loads with computers and light-emitting diode (LED) lights.

2.2.2. Proposed Model for Evaluating Harmonic Contributions Without GPS Technology

On the basis of the analysis above, we can transform Equation (4) by setting the starting time of measurement at bus X as the reference:

$$\begin{bmatrix} \dot{U}_X \\ e^{j\alpha_1} \dot{I}_{c,1} \\ e^{j\alpha_2} \dot{I}_{c,2} \\ \vdots \\ e^{j\alpha_{N-1}} \dot{I}_{c,N-1} \end{bmatrix} = \begin{bmatrix} Z_{X,1} & Z_{X,2} & \cdots & Z_{X,N-1} & 1 \\ e^{j\alpha_1} & 0 & \cdots & 0 & 0 \\ 0 & e^{j\alpha_2} & 0 & \cdots & 0 \\ \vdots & \vdots & \ddots & \vdots & \vdots \\ 0 & 0 & \cdots & e^{j\alpha_{N-1}} & 0 \end{bmatrix} \begin{bmatrix} \dot{I}_{c,1} \\ \dot{I}_{c,2} \\ \vdots \\ \dot{I}_{c,N-1} \\ \dot{U}_0 \end{bmatrix}, \quad (10)$$

where $\alpha_i (i = 1, 2, \dots, N-1)$ represents the relative phase between the synchronous and asynchronous measurements for customers i . Notably, the source signal $\dot{I}_{c,i}$ is still synchronous with $\dot{U}_X$. Yet, because α_i is unknown, we only have the asynchronous signals $e^{j\alpha_i} \dot{I}_{c,i}$.

Since the fluctuations of $\dot{I}_{c,i}$ and $\dot{u}_0$ are independent from each other [9–11,21], Equation (10) can be solved via CICA as:

$$\underbrace{\begin{bmatrix} \dot{U}_X^{\text{fast}} \\ (e^{j\alpha_1} \dot{I}_{c,1})^{\text{fast}} \\ (e^{j\alpha_2} \dot{I}_{c,2})^{\text{fast}} \\ \vdots \\ (e^{j\alpha_{N-1}} \dot{I}_{c,N-1})^{\text{fast}} \end{bmatrix}}_X = \underbrace{\begin{bmatrix} k_1 \hat{Z}_{X,1} & k_2 \hat{Z}_{X,2} & \cdots & k_{N-1} \hat{Z}_{X,N-1} & 1 \\ k_1 e^{j\alpha_1} & 0 & \cdots & 0 & 0 \\ 0 & k_2 e^{j\alpha_2} & 0 & \cdots & 0 \\ \vdots & \vdots & \ddots & \vdots & \vdots \\ 0 & 0 & \cdots & k_{N-1} e^{j\alpha_{N-1}} & 0 \end{bmatrix}}_A \underbrace{\begin{bmatrix} \hat{I}_{c,1}^{\text{fast}} \\ \hat{I}_{c,2}^{\text{fast}} \\ \vdots \\ \hat{I}_{c,N-1}^{\text{fast}} \\ \hat{U}_0^{\text{fast}} \end{bmatrix}}_Y, \quad (11)$$

where the unknown complex coefficients k_i indicate the scaling indeterminacy [9–11,21].

The transfer impedances $Z_{X,i}$ combined with α_i can be obtained as:

$$e^{-j\alpha_i} \hat{Z}_{X,i} = \hat{A}_{1,i} / \hat{A}_{i+1,i}, \quad (12)$$

However, we still cannot separate the transfer impedances from α_i because these angles are unknown. Yet, according to Equations (1) and (12), we can evaluate the harmonic contributions via $e^{-j\alpha_i} \hat{Z}_{X,i}$ without separating the transfer impedances from these unknown angles. When signal $e^{j\alpha_i} \hat{I}_{c,i}$ multiplies $e^{-j\alpha_i}$, the new signal $\hat{I}_{c,i}$ is synchronized with $\dot{U}_X$. Although α_i is unknown, based on Equations (1) and (12), we have

$$(e^{j\alpha_i} \hat{I}_{c,i}) (e^{-j\alpha_i} \hat{Z}_{X,i}) = \hat{I}_{c,i} \hat{Z}_{X,i} = \hat{U}_i. \quad (13)$$

Thus, $\hat{I}_{c,i} \hat{Z}_{X,i}$ is obtained directly without calculating α_i because the angle α_i in $e^{j\alpha_i} \hat{I}_{c,i}$ and $e^{-j\alpha_i} \hat{Z}_{X,i}$ is just offset. Consequently, the harmonic contribution of each source can be evaluated without the synchronized phasor measurements.

3. A Mixed Entropy Screening Mechanism for Data Segments Selection

During the calculation process of CICA, the harmonic impedances should be constant to keep the matrix A invariant. To ensure this, first, the whole measured data are usually divided into several short segments. Then, we calculate the transfer impedances using each segment separately and average the results. It can be considered that the harmonic impedances are approximately constant during each single data segment because the corresponding time is quite short. Additionally, the calculation accuracy of CICA relies on stable background harmonics. A large fluctuation of the background harmonics may increase the calculation errors [9–11,21]. Therefore, if the fluctuation degree of the background harmonics is assessable, we can improve the calculation accuracy by choosing the data segments with relatively stable background harmonics for calculation, while eliminating the data segments with heavily fluctuating background harmonics. The problem is that the background harmonics cannot be measured directly. To overcome this difficulty, a mixed entropy screening mechanism is proposed in this section.

Based on the central limit theorem [25], the distribution of a signal x linear combined by many random signals tends to be Gaussian. In addition, if signal x is only dominated by a few of these signals, its Gaussian degree will be decreased. For instance, signal x is combined by four random real signals s_i ($i = 1, 2, 3, 4$) with unit amplitude as: $X = s_1 + s_2 + s_3 + s_4$. The sample size for each signal is 3000. Their distributions and Gaussian degrees are shown in Figure 7, where the Gaussian degree

is assessed by the entropy of a signal as Equation (14) [26]. A high entropy corresponds to a strong Gaussian degree.

$$H(s) = -\sum_{m=1}^M p(s_m) \log_2 p(s_m), \quad (14)$$

where M is the sample size of signal s , $p(s_m)$ is the probability mass function of s .

Figure 7. Distribution and entropy of each signal: (a) s_1 ; (b) s_2 ; (c) s_3 ; (d) s_4 ; (e) x .

Since the standard Gaussian signal has the largest entropy among all random signals of equal variance [27], to make the entropy of different signals comparable, transformations in Equations (15) and (16) are performed for each signal.

$$\begin{cases} s \rightarrow s - E\{s\} \\ s \rightarrow s / \text{std}\{s\} \end{cases} \quad (15)$$

where $E\{s\}$ and $\text{std}\{s\}$ are the mean value and standard deviation of signal s , respectively.

$$H(s) \rightarrow H(s) / H(s_G), \quad (16)$$

where s_G is the standard Gaussian signal with zero-mean and unit variance.

As shown in Figure 7, compared with the signals s_i ($i = 1, 2, 3, 4$), the mixed signal x is closer to Gaussian distribution. Meanwhile, the entropy of signal x is also the biggest one among these signals, revealing that entropy can correctly reflect the Gaussian degree of each signal. After the amplitude of signal s_4 increases k times, the distribution and the entropy of signal x is presented in Figure 8. With the increasing of k , signal x is gradually dominated by s_4 , which causes the decline of the Gaussian degree of x , and so, the corresponding entropy declines.

Figure 8. Distribution and entropy of the mix signal x in each case: (a) $k = 2$; (b) $k = 4$; (c) $k = 6$.

The above analyses can be applied into Equation (10) to assess the fluctuation degree of the background harmonic voltages $\dot{U}_0$. Since the Gaussian degree of each complex signal in Equation (10) can be reflected by the Gaussian degree of their real and imaginary parts [11], we use the mixed entropy defined in Equation (17) to assess the Gaussian degree of a complex signal. For a data segment, two possible situations are discussed below:

$$\mathbf{H}[s] = \frac{H(s_x) + H(s_y)}{2}, \quad (17)$$

where the subscripts “ x ” and “ y ” respectively represent the real and imaginary parts of signal s .

- Case (1): The background harmonics fluctuate greatly:

In this case, $\dot{U}_X^{\text{fast}}$ is dominated by the fast-varying components of the background harmonics $\dot{U}_0^{\text{fast}}$, and thus, the Gaussian degree of $\dot{U}_X^{\text{fast}}$ becomes relatively low. The mixed entropy of $\dot{U}_X^{\text{fast}}$ approaches $\mathbf{H}[\dot{U}_0^{\text{fast}}]$ and is small compared with the data segment where $\dot{U}_0$ is stable.

- Case (2): The background harmonics are stable:

In this case, $\dot{U}_X^{\text{fast}}$ usually has a relatively high Gaussian degree. However, if one of the harmonic sources fluctuates greatly in this data segment, $\dot{U}_X^{\text{fast}}$ will be dominated by $\dot{I}_{c,i}^{\text{fast}}$. Thus, the mixed entropy of $\dot{U}_X^{\text{fast}}$ approaches $\mathbf{H}[\dot{I}_{c,i}^{\text{fast}}]$ and is still small compared with the cases where $\dot{I}_{c,i}$ is relatively stable. Yet, this case is still quite different from case (1). Generally, the background harmonic voltages are the combination of other harmonics in the power grid. Thus, compared with the current signal $\dot{I}_{c,i}$ generated from a single nonlinear customer, the Gaussian degree of $\dot{U}_0^{\text{fast}}$ is usually stronger according to the central limit theorem [11]. Therefore, $\mathbf{H}[\dot{U}_0^{\text{fast}}]$ is usually larger than $\mathbf{H}[\dot{I}_{c,i}^{\text{fast}}]$.

Although $\dot{I}_{c,i}^{\text{fast}}$ cannot be directly obtained under the situation of asynchronous measurements, the distribution of $\dot{I}_{c,i}^{\text{fast}}$ and $(e^{j\alpha_i} \dot{I}_{c,i})^{\text{fast}}$ are approximately coincident. Thus, for a data segment where $\mathbf{H}[\dot{U}_X^{\text{fast}}]$ is relatively small, if $\mathbf{H}[\dot{U}_X^{\text{fast}}]$ is obviously larger than $\mathbf{H}[(e^{j\alpha_i} \dot{I}_{c,i})^{\text{fast}}]$ ($i = 1, 2, \dots, N-1$), the background harmonics fluctuate greatly. Otherwise, if $\mathbf{H}[\dot{U}_X^{\text{fast}}]$ is close to or even smaller than one of the $\mathbf{H}[(e^{j\alpha_i} \dot{I}_{c,i})^{\text{fast}}]$, then the background harmonics will be stable. Empirically, when Equation (18) holds, it can be considered that $\mathbf{H}[\dot{U}_X^{\text{fast}}]$ is close to or smaller than $\mathbf{H}[(e^{j\alpha_i} \dot{I}_{c,i})^{\text{fast}}]$.

$$\sigma_H = \min \left[\frac{\mathbf{H}[\dot{U}_X^{\text{fast}}] - \mathbf{H}[(e^{j\alpha_i} \dot{I}_{c,i})^{\text{fast}}]}{\mathbf{H}[(e^{j\alpha_i} \dot{I}_{c,i})^{\text{fast}}]} \times 100\% \right] < 4\% (i = 1, 2, \dots, N-1), \quad (18)$$

For all the given data segments, the mixed entropy for their corresponding signal $\dot{U}_X^{\text{fast}}$ can be obtained by using Equation (17). Furthermore, the average value of these mixed entropies can be calculated (defined as $\mathbf{H}_m$). If $\mathbf{H}[\dot{U}_X^{\text{fast}}] > \mathbf{H}_m$ holds for a data segment, the corresponding background harmonics are stable. Otherwise, Equation (18) is required to further assess the fluctuation degree of the background harmonics.

A schematic diagram of the mixed entropy screening mechanism is shown in Figure 9.

Figure 9. Schematic diagram of the mixed entropy screening mechanism.

4. Improved CICA Method

Although the mixed entropy screening mechanism can release the impacts of background harmonics, to further improve calculation accuracy, an improved CICA is proposed in this section. Before applying the CICA method, the observed signals X are preprocessed by centering and whitening to simplify the calculation [9–11]. The centering process transforms X into zero-mean signals, while the whitening process can be done as

$$X_w = QX, \quad (19)$$

$$Q = \Lambda^{-0.5} \Gamma^T, \quad (20)$$

where Q is the whitening matrix. Λ and Γ are the diagonal and orthogonal matrices of eigenvalues of $E\{XX^T\}$, respectively (the symbol $E\{\cdot\}$ denotes a mean value) [10].

The key step of CICA is to find a separating matrix W satisfying

$$Y = W^T X_w, \quad (21)$$

where the symbol T represents the Hermitian transpose.

CICA is essentially an optimization algorithm based on the central limit theorem. Its goal is to maximize the non-Gaussianities of each signal in matrix Y , while the elements in matrix W are the

variables to be optimized [7,8,28]. The non-Gaussianities of signal $\mathbf{W}^T \mathbf{X}_w$ (signal $\mathbf{Y}$) can be estimated via the negative entropy [7,11,29,30]:

$$J_G(\mathbf{W}^T \mathbf{X}_w) \approx \left[E\{G(\mathbf{W}^T \mathbf{X}_w)\} - E\{G(s_{\text{Gauss}})\} \right]^2, \quad (22)$$

where s_{Gauss} is a signal with zero mean and unit variance and obeys a Gaussian distribution, and $G\{\cdot\}$ is a nonlinear function. The non-Gaussianity of signal $\mathbf{W}^T \mathbf{X}_w$ strengthens as the negative entropy $J_G(\mathbf{W}^T \mathbf{X}_w)$ increases.

Of note, the maxima of $J_G(\mathbf{W}^T \mathbf{X}_w)$ are obtained when $E\{G(\mathbf{W}^T \mathbf{X}_w)\}$ is optimal [7]. Furthermore, in another study [8], by defining $g\{\cdot\}$ as the derivative of $G\{\cdot\}$, index σ_c is deduced to solve this optimization problem:

$$\sigma_c = E\left\{g\left(|\mathbf{W}^T \mathbf{X}_w|^2\right) + |\mathbf{W}^T \mathbf{X}_w|^2 g'\left(|\mathbf{W}^T \mathbf{X}_w|^2\right) - |\mathbf{W}^T \mathbf{X}_w|^2 g\left(|\mathbf{W}^T \mathbf{X}_w|^2\right)\right\}. \quad (23)$$

When $\sigma_c < 0$, we should calculate the matrix $\mathbf{W}$ that maximizes $E\{G(|\mathbf{W}^T \mathbf{X}_w|^2)\}$. Conversely, when $\sigma_c > 0$, the matrix $\mathbf{W}$ that minimizes $E\{G(|\mathbf{W}^T \mathbf{X}_w|^2)\}$ should be solved [8]. The problem of maximizing the negative entropy $J_G(\mathbf{W}^T \mathbf{X}_w)$ is now converted into optimizing $E\{G(|\mathbf{W}^T \mathbf{X}_w|^2)\}$.

Despite the ordering and scaling indeterminacies of CICA [9–11,21], the optimal $\mathbf{W}$ satisfies

$$\mathbf{W}^T = \mathbf{A}^{-1} \mathbf{Q}^{-1}. \quad (24)$$

Additionally, matrix $\mathbf{A}$ in Equation (10) is sparse to a certain degree. For an $N \times N$ matrix $\mathbf{A}$, there are $(N - 1) \times (N - 1)$ elements naturally equal to 0 and one element equal to 1. However, in traditional CICA, these known elements are still treated as variables to be solved, which may cause two problems: (1) wasting the chance to reduce the optimization dimensions; and (2) increasing errors when the calculation results of these elements do not equal to their theoretical values (0 or 1).

This paper uses the sparseness of matrix $\mathbf{A}$ to improve CICA and enhance the calculation accuracy. By assuming there are $N - 1$ suspicious harmonic sources in a system, we calculate the inverse of matrix $\mathbf{A}$ as

$$\mathbf{A}^{-1} = \begin{bmatrix} 0 & e^{-j\alpha_1} & 0 & \cdots & 0 \\ 0 & 0 & e^{-j\alpha_2} & \cdots & 0 \\ \vdots & \vdots & \vdots & \ddots & \vdots \\ 0 & 0 & \cdots & 0 & e^{-j\alpha_{N-1}} \\ 1 & -Z_{X,1} & -Z_{X,2} & \cdots & -Z_{X,N-1} \end{bmatrix}. \quad (25)$$

Since matrix $\mathbf{Q}$ can be obtained from $\mathbf{X}$, we can calculate its inverse $\mathbf{Q}^{-1}$ (defined as $\mathbf{\Theta}$). Thus, Equation (24) gives

$$\mathbf{W} = \begin{bmatrix} \Theta_{2,1}e^{-j\alpha_1} & \Theta_{3,1}e^{-j\alpha_2} & \cdots & \Theta_{N,1}e^{-j\alpha_{N-1}} & W_{1,N} \\ \Theta_{2,2}e^{-j\alpha_1} & \Theta_{3,2}e^{-j\alpha_2} & \cdots & \Theta_{N,2}e^{-j\alpha_{N-1}} & W_{2,N} \\ \vdots & \vdots & \cdots & \vdots & \vdots \\ \Theta_{2,N}e^{-j\alpha_1} & \Theta_{3,N}e^{-j\alpha_2} & \cdots & \Theta_{N,N}e^{-j\alpha_{N-1}} & W_{N,N} \end{bmatrix}, \quad (26)$$

where $W_{N,N}$ and $\Theta_{N,N}$ represent the element in the N^{th} row and N^{th} column of matrix $\mathbf{W}$ and $\mathbf{\Theta}$, respectively.

Equation (26) can be rewritten as

$$W = \begin{bmatrix} W_{1,1} & \cdots & W_{1,N-1} & W_{1,N} \\ W_{1,1} \frac{\Theta_{2,2}}{\Theta_{2,1}} & \cdots & W_{1,N-1} \frac{\Theta_{N,2}}{\Theta_{N,1}} & W_{2,N} \\ \vdots & \cdots & \vdots & \vdots \\ W_{1,1} \frac{\Theta_{2,N}}{\Theta_{2,1}} & \cdots & W_{1,N-1} \frac{\Theta_{N,N}}{\Theta_{N,1}} & W_{N,N} \end{bmatrix}. \quad (27)$$

Once, $W_{1,1}, W_{1,2}, \dots, W_{1,N}$ and $W_{2,N}, W_{3,N}, \dots, W_{N,N}$ are solved, the other elements in matrix W are obtained.

Furthermore, because

$$\begin{bmatrix} W_{1,N} & W_{2,N} & \cdots & W_{N,N} \end{bmatrix} = \begin{bmatrix} 1 & -Z_{X,1} & \cdots & -Z_{X,N-1} \end{bmatrix} \Theta, \quad (28)$$

we have

$$\begin{bmatrix} -Z_{X,1} \\ -Z_{X,2} \\ \vdots \\ -Z_{X,N-1} \end{bmatrix}^T = \left(\begin{bmatrix} W_{1,N} \\ W_{2,N} \\ \vdots \\ W_{N-1,N} \end{bmatrix}^T - \begin{bmatrix} \Theta_{1,1} \\ \Theta_{1,2} \\ \vdots \\ \Theta_{1,N-1} \end{bmatrix}^T \right) \begin{bmatrix} \Theta_{2,1} & \Theta_{2,2} & \cdots & \Theta_{2,N-1} \\ \Theta_{3,1} & \Theta_{3,2} & \cdots & \Theta_{3,N-1} \\ \vdots & \vdots & \cdots & \vdots \\ \Theta_{N,1} & \Theta_{N,2} & \cdots & \Theta_{N,N-1} \end{bmatrix}^{-1}. \quad (29)$$

Thus, $W_{N,N}$ can be obtained from $W_{2,N}, W_{3,N}, \dots, W_{N-1,N}$, and Θ as

$$W_{N,N} = \begin{bmatrix} 1 & -Z_{X,1} & \cdots & -Z_{X,N-1} \end{bmatrix} \begin{bmatrix} \Theta_{1,N} \\ \Theta_{2,N} \\ \vdots \\ \Theta_{N,N} \end{bmatrix}. \quad (30)$$

Consequently, the optimization dimensions are greatly reduced from $N \times N$ to $2(N-1)$, which significantly reduces the optimization burden. Moreover, the elements that are already known (0 or 1) in the solved matrix A will be exactly equal to their proper values without the risk of error. The calculation accuracy is thus further enhanced. The flow chart of the improved CICA is shown in Figure 10.

Figure 10. Flow chart of the improved CICA.

5. Simulation Cases and Analysis

The IEEE-14 bus system [31] is used to validate the proposed method. The simulations are processed by the Matlab 8.5 program under the 5th harmonic. Bus 6 is set as the concerned bus, and suspicious harmonic sources are set at buses 13 and 14 (Figure 11). The injected harmonic currents and background harmonic voltages are shown in Figure 12. Please note, all these harmonic data are per unit values, and the corresponding actual values can be converted by their base values in another study [31]. The harmonic data are averaged in 1 second, so we have 1 sample per second. The asynchronously measured harmonic currents are $\dot{I}_{c,A}^{\alpha_A} = e^{j\alpha_A} \dot{I}_{c,A}$ and $\dot{I}_{c,B}^{\alpha_B} = e^{j\alpha_B} \dot{I}_{c,B}$. Of note, $\dot{I}_{c,A}$ and $\dot{I}_{c,B}$ are synchronous with the voltages measured at bus 6, while the unknown phases α_A and α_B are used to simulate asynchronous measurement. During the calculation process, $\dot{I}_{c,A}^{\alpha_A}$ and $\dot{I}_{c,B}^{\alpha_B}$ are used to evaluate the harmonic contributions, and the evaluation results from $\dot{I}_{c,A}$ and $\dot{I}_{c,B}$ are just used as the reference to validate the calculation.

Figure 11. Structure of the IEEE-14 bus system.

Figure 12. Injected harmonic voltages and currents: (a) background harmonic voltages; (b) injected harmonic currents of each customer.

According to the structure and parameters of the IEEE-14 bus system [31], the harmonic impedances of the utility side are $Z_{u,A} = 0.1747 + 0.7313jp.u.$ and $Z_{u,B} = 0.2708 + 1.0004jp.u.$. Meanwhile, the harmonic impedances of the customer side are set as $Z_{c,A} = 0.5 + 2jp.u.$ and $Z_{c,B} = 2 + 11jp.u.$. Throughout this simulation, $Z_{u,A}$, $Z_{u,B}$, $Z_{c,A}$, and $Z_{c,B}$ are all unknowns and need to be solved. The above impedance values are just used as the references for analyzing the calculation errors.

5.1. Effect of the Mixed Entropy Screening Mechanism

First, to obtain the observation signals $\begin{bmatrix} \dot{U}_X & \dot{I}_{c,A}^{\alpha_A} & \dot{I}_{c,B}^{\alpha_B} \end{bmatrix}^T$ for Equation (10), the harmonic currents generated by customer A and B are estimated by solving the single point model in Equation (3) via the CICA method. Then, the fast-varying components $\begin{bmatrix} \dot{U}_X^{fast} & \left(\dot{I}_{c,A}^{\alpha_A}\right)^{fast} & \left(\dot{I}_{c,B}^{\alpha_B}\right)^{fast} \end{bmatrix}^T$ are separated from $\begin{bmatrix} \dot{U}_X & \dot{I}_{c,A}^{\alpha_A} & \dot{I}_{c,B}^{\alpha_B} \end{bmatrix}^T$ by an average filter. After that, the whole observation signals are divided into 10 segments, and the mixed entropy screening mechanism is adopted to choose the data segments where the background harmonics are relatively stable.

The calculated mixed entropies of signals $\dot{U}_X^{fast}$, $\left(\dot{I}_{c,A}^{\alpha_A}\right)^{fast}$, and $\left(\dot{I}_{c,B}^{\alpha_B}\right)^{fast}$ in each segment are presented in Table 2. Since $\dot{U}_X^{fast}$ is mixed by $\dot{I}_{c,A}^{fast}$, $\dot{I}_{c,B}^{fast}$, and $\dot{U}_0^{fast}$, according to the central limit theorem, the Gaussianity of $\dot{U}_X^{fast}$ is generally the largest among these signals. Table 2 indicates that the mean values of $\mathbf{H}\left[\left(\dot{I}_{c,A}^{\alpha_A}\right)^{fast}\right]$ and $\mathbf{H}\left[\left(\dot{I}_{c,B}^{\alpha_B}\right)^{fast}\right]$ are obviously smaller than the averages of $\mathbf{H}\left[\dot{U}_X^{fast}\right]$ (i.e., $\mathbf{H}_m$). Meanwhile, the mean value of σ_H is positive and far larger than 0. Thus, based on Equation (18), it can be concluded that the Gaussianity of $\dot{U}_X^{fast}$ is indeed the strongest in most cases. Theoretically, when the background harmonics fluctuate greatly, $\dot{U}_X^{fast}$ is dominated by $\dot{U}_0^{fast}$ and so $\mathbf{H}\left[\dot{U}_X^{fast}\right]$ decreases. Yet, since $\dot{U}_0^{fast}$ is also the combination of other harmonic sources, $\mathbf{H}\left[\dot{U}_X^{fast}\right]$ is still larger than $\mathbf{H}\left[\left(\dot{I}_{c,A}^{\alpha_A}\right)^{fast}\right]$ and $\mathbf{H}\left[\left(\dot{I}_{c,B}^{\alpha_B}\right)^{fast}\right]$ as analyzed in Section 3. For instance, at the 3rd and 9th segments, the mixed entropy of $\dot{U}_X^{fast}$ is relatively lower than $\mathbf{H}_m$ but larger than $\mathbf{H}\left[\left(\dot{I}_{c,A}^{\alpha_A}\right)^{fast}\right]$ and $\mathbf{H}\left[\left(\dot{I}_{c,B}^{\alpha_B}\right)^{fast}\right]$; thus, it can be considered that $\dot{U}_0$ fluctuates greatly at these two segments. In comparison, at the 5th and 7th segments, both $\mathbf{H}\left[\dot{U}_X^{fast}\right] < \mathbf{H}_m$ and $\sigma_H < 4\%$ hold, which indicates that $\mathbf{H}\left[\dot{U}_X^{fast}\right]$ is not only smaller than $\mathbf{H}_m$, but also close or even smaller than $\mathbf{H}\left[\left(\dot{I}_{c,A}^{\alpha_A}\right)^{fast}\right]$ or $\mathbf{H}\left[\left(\dot{I}_{c,B}^{\alpha_B}\right)^{fast}\right]$. Therefore, according to the evaluation process in Figure 9, the corresponding background harmonics are stable, while the harmonic currents generated by customer A or B fluctuate. The above conclusions are just consistent with the curves in Figure 12, and the effect of the mixed entropy screening mechanism is thus verified.

5.2. Multipoint Calculation

The key step of multipoint calculation is to solve the transfer impedance between each harmonic source and the concerned bus X (bus 6 in this case). As analyzed before, the calculated transfer impedances without synchronous measurements are $Z_{X,A}^{\alpha_A} = e^{-j\alpha_A} Z_{X,A}$ and $Z_{X,B}^{\alpha_B} = e^{-j\alpha_B} Z_{X,B}$. According to Equation (13), the contributions from each harmonic source can be calculated even though α_A and α_B are unknown.

Table 2. Results of the mixed entropy screening.

Data Segment	Mixed Entropy			σ_H (%)
	$H[\dot{U}_X^{fast}]$	$H[\dot{I}_{c,A}^{\alpha_A}]^{fast}$	$H[\dot{I}_{c,B}^{\alpha_B}]^{fast}$	
1	0.815	0.671	0.615	21.461
2	0.801	0.654	0.643	22.477
3	0.734	0.673	0.629	9.064
4	0.792	0.666	0.582	18.919
5	0.691	0.671	0.621	2.981
6	0.799	0.626	0.622	27.636
7	0.705	0.673	0.708	−0.424
8	0.809	0.647	0.668	21.108
9	0.738	0.629	0.636	16.038
10	0.793	0.639	0.612	24.1
mean value	0.768	0.655	0.634	16.34

Four methods are used for calculation: (1) the least squares method [18]; (2) the multiple linear regression method [20]; (3) traditional CICA; and (4) the proposed method. The calculation results are shown in Tables 3 and 4. For the least squares method, the calculation errors are huge because its necessary assumptions that the background harmonics are stable and that only one harmonic source fluctuates at a time are hard to hold for most of the segments. In addition, in engineering practice, with the increasing number of complex nonlinear customers, several suspicious harmonic sources usually exist for a concerned bus; thus, the basic assumptions of the least squares method are more difficult to satisfy. Meanwhile, the multiple linear regression method also requires that the background harmonics should not fluctuate; thus, the calculation errors are still high. Additionally, the calculation accuracy of traditional CICA is improved but still unsatisfactory because its calculation results are still impacted by the fluctuation of the background harmonics to a certain degree. In comparison, the improved CICA can accurately calculate the transfer impedances and evaluate the harmonic contribution correctly for each harmonic source.

Table 3. Calculation errors of the transfer impedances.

Method	Calculation Errors of the Transfer Impedances (%)			
	$ Z_{X,A}^{\alpha_A} $	$\angle Z_{X,A}^{\alpha_A}$	$ Z_{X,B}^{\alpha_B} $	$\angle Z_{X,B}^{\alpha_B}$
least squares method	53.68	47.16	45.17	37.36
multiple linear regression	38.91	41.57	46.72	31.41
traditional CICA	19.96	21.43	23.37	22.57
improved CICA	8.73	8.46	6.71	7.38

Table 4. Harmonic contributions for each harmonic source.

Method	Harmonic Contributions (%)		
	Harmonic Source A	Harmonic Source B	Background Harmonics
least squares method	23.35	61.79	14.86
multiple linear regression	32.78	48.64	18.58
traditional CICA	57.34	31.47	11.19
improved CICA	52.28	19.16	28.56
reference value	48.32	21.47	30.21

We further analyze the effects of the background harmonics on the calculation accuracy by setting $\dot{U}_0 = k\dot{U}_0$. As the coefficient k increases, the background harmonics become more unstable. The calculation results of these four methods are shown in Figure 13. The calculation errors of the least

squares and multiple linear regression methods become terrible with the increasing of k . Although the results of the traditional CICA are modified compared with the former two methods, the errors still increase rapidly as the background harmonics increase. By contrast, the results of the improved CICA always have high accuracy, satisfying engineering requirements. Therefore, it is further verified that the improved CICA has a stronger ability to resist impacts from the background harmonics.

Figure 13. Effects of the background harmonics: (a) errors of $|Z_{X,A}^{\alpha_A}|$; (b) errors of $\angle Z_{X,A}^{\alpha_A}$; (c) errors of $|Z_{X,B}^{\alpha_B}|$; (d) errors of $\angle Z_{X,B}^{\alpha_B}$.

To further explore the differences between the traditional and improved CICA, Figure 14 shows the amplitudes of the elements in the solved mixed matrix A . In the improved CICA, the elements $A_{2,2}$, $A_{2,3}$, $A_{3,1}$, and $A_{3,3}$ are exactly equal to 0. However, in the traditional CICA, these elements do not exactly equal their theoretical values, which decrease the calculation accuracy.

Figure 14. Elements in matrix A solved from traditional CICA.

In addition, real-time implementation is important for an algorithm. Since the traditional CICA is derived from a fast fixed-point algorithm [8], it already has a high execution speed. Further, in the improved CICA, the optimization dimension is decreased based on the sparseness of the matrix A . Thus, the execution time is further reduced. For the whole 10 minutes data, the execution time of the improved CICA is just 0.43 seconds. Thus, with such a high execution speed, the proposed method can be used to evaluate the harmonic contributions in real time.

6. Field Case Verifications

The power grid for an actual multi-infeed HVDC system shown in Figure 15 is used to further verify the validity of the proposed method under the situation of asynchronous measurements. In this power system, converter stations, as the high-power harmonic sources in a high-voltage level, inject a lot of characteristic harmonics into the power system, which worsen the harmonic distortion in some areas of the grid [32,33]. Bus B23 with high 11th harmonic voltage content exceeding the Chinese standard limits is set as the concerned bus, while the four HVDC systems are the main suspicious harmonic sources. After applying the DFT analysis for the measured data, the 11th harmonic voltages at bus B23 and the currents at each HVDC system are shown in Figure 16. The sampling frequency is 10k Hz and the data resolution is 1 sample per second. Of note, the measured harmonic currents in Figure 16b are asynchronized with the harmonic voltages in Figure 16a. Meanwhile, the corresponding synchronized currents are also measured, and so, the results calculated from the synchronous case can be used as the reference.

Figure 15. The topology of a multi-infeed HVDC system.

The harmonic contributions of the four HVDCs calculated from each method with the asynchronous data are shown in Figure 17 and Table 5. Since there are four suspicious harmonic sources, it is hard to satisfy the basic assumption of the least squares method that only one harmonic source fluctuates at a time. Thus, the calculation errors are large. The multiple linear regression method is based on the condition that the relative phase between $\hat{U}_X$ and each $\hat{U}_i$ is approximately constant. However, in engineering practice, this phase angle usually varies especially when $\hat{U}_X$ is generated by multiple harmonic sources. Therefore, the calculation errors of the multiple linear regression method are still large. In addition, for traditional CICA, the large number of suspicious harmonic sources increases the difficulty of signal separation. Thus, the calculation accuracy is low. In comparison, the optimization dimension of the improved CICA is decreased by adopting the sparseness of the matrix A . Hence, the calculation burden is greatly released, and the evaluation accuracy is satisfactory. Therefore, it can be concluded that HVDC2 is the dominant harmonic source for the concerned bus.

Figure 16. The measured 11th harmonic data: (a) 11th harmonic voltages measured at the concerned bus; (b) 11th harmonic currents measured at each HVDC.

Figure 17. Harmonic contribution of each HVDC.

Table 5. Harmonic contributions calculated by each method.

Method	Harmonic Contributions (%)				
	Background Harmonics	HVDC1	HVDC2	HDVC3	HVDC4
least squares method	36.74	11.56	32.36	13.25	6.09
multiple linear regression	11.37	22.68	18.74	33.66	13.55
traditional CICA	5.28	30.65	25.42	17.27	21.38
improved CICA	11.37	5.21	70.82	6.53	6.07
reference value	10.24	4.88	74.14	5.61	5.13

To further validate the above conclusion, the contents of the 11th harmonic voltage at the concerned bus are analyzed under different switching modes of harmonic filters at each HVDC. Although harmonic filters are expensive, they are still widely applied in the HVDC converter stations in China. Negative effects on technology and economy will occur without these filters. On the one

hand, the harmonic currents injected into the power system far exceed the Chinese standard limits, and the voltages in most buses of the power grid will be seriously distorted. On the other hand, the potential economic loss caused by the characteristic harmonics of HVDCs can be far beyond the cost of the harmonic filters. As a result, filters are necessary for HVDC systems [34]. Figure 18 presents the harmonic impedance property of the double-tuned filters installed at the converter station. The impedance amplitudes corresponding to the 11th, 13th, 23rd, and 25th harmonics are low; thus, the relative characteristic harmonics can be filtered out.

Figure 18. The harmonic impedance property of the double-tuned filter.

Figure 19 indicates that when more filters are put into HVDC2, the contents of the 11th harmonic voltage at the concerned bus decrease obviously. In contrast, the harmonic mitigation effects are weak after putting more filters into other HVDCs. Consequently, HVDC2 is surely the dominant harmonic source for the concerned bus and the evaluation results from the improved CICA are further validated.

Figure 19. The contents of the 11th harmonic voltage at the concerned bus.

7. Conclusions

To evaluate the harmonic contributions accurately and economically, a novel method is proposed in this paper. First, an evaluation model independent of expensive GPS technology is developed. Then, a mixed entropy screening mechanism is designed to select the data segments with stable background harmonics. Last, the optimization dimensions of CICA are greatly reduced by using the sparseness of the mixed matrix, and so the evaluation accuracy is enhanced. The results of simulations and field case studies are summarized as:

- (1) For the data segments with fluctuating background harmonics, both $\mathbf{H}\left[\dot{U}_X^{\text{fast}}\right] < \mathbf{H}_m$ and $\sigma_H < 4\%$ hold, while the simulation results satisfy $\mathbf{H}\left[\dot{U}_X^{\text{fast}}\right] > \mathbf{H}_m$ when background harmonics are stable. Thus, the fluctuation degree of background harmonics is successfully assessed by the proposed mixed entropy screening mechanism.

- (2) In simulations and filed cases studies, the results of the proposed asynchronous evaluation model are consistent with the harmonic contributions evaluated from the synchronous measurement data, verifying the validity of the proposed GPS-free evaluation model.
- (3) Calculation precision of the traditional methods is low especially when the background harmonics are unstable and there are many suspicious harmonic sources. In comparison, owing to the effect of optimization dimensions reduction, the improved CICA always has high evaluation accuracy in simulations and field case studies.

Consequently, compared with the existing studies, the proposed method can evaluate the harmonic contributions accurately even when the background harmonics fluctuate and the number of suspicious harmonic sources is large. Further, the relative evaluation processes no longer rely on expensive GPS. By applying the proposed method, the cost of the harmonic contribution evaluation will greatly decrease. Meanwhile, the accurate evaluation results can be the basis of designing the punishment mechanism for nonlinear customers and identifying the dominated harmonic sources via the proposed method is significant to guide harmonic mitigation.

In future works, we will further apply the evaluation results to release the harmonic pollutions in the power grid.

Author Contributions: Conceptualization, J.Z. and H.Y.; methodology, J.Z. and F.X.; software, J.Z. and X.M.; validation, J.Z. and F.X.; formal analysis, J.Z. and X.M.; investigation, J.Z. and H.Y.; resources, J.Z.; data curation, J.Z. and F.X.; writing—original draft preparation, J.Z.; writing—review and editing, J.Z. and F.X.; visualization, J.Z. and X.M.; supervision, H.Y. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Conflicts of Interest: The authors declare no conflicts of interest.

References

1. Ebrahimzadeh, E.; Blaabjerg, F.; Wang, X.F.; Bak, C.L. Bus participation factor analysis for harmonic instability in power electronics based power systems. *IEEE Trans. Power Electron.* **2018**, *33*, 10341–10351. [\[CrossRef\]](#)
2. Jedrzejczak, J.; Anders, G.J.; Firuzabad, M.F.; Farzin, H.; Aminifar, F. Reliability assessment of protective relays in harmonic polluted power systems. *IEEE Trans. Power Deliv.* **2017**, *32*, 556–564. [\[CrossRef\]](#)
3. Xu, F.W.; Yang, H.G.; Zhao, J.S.; Wang, Z.Q.; Liu, Y.M. Study on constraints for harmonic source determination using active power direction. *IEEE Trans. Power Deliv.* **2018**, *33*, 2683–2692. [\[CrossRef\]](#)
4. Hui, J.; Freitas, W.; Vieira, J.C.M.; Yang, H.G.; Liu, Y.M. Utility harmonic impedance measurement based on data selection. *IEEE Trans. Power Deliv.* **2012**, *27*, 2193–2203. [\[CrossRef\]](#)
5. Xu, Y.H.; Huang, S.; Liu, Y.Y. Partial least-squares regression based harmonic emission level assessing at the point of common coupling. In Proceedings of the 2006 International Conference on Power System Technology, Chongqing, China, 22–26 October 2006.
6. Hui, J.; Yang, H.G.; Lin, S.F.; Ye, M.Q. Assessing utility harmonic impedance based on the covariance characteristic of ran-dom vectors. *IEEE Trans. Power Deliv.* **2010**, *25*, 1778–1786. [\[CrossRef\]](#)
7. Hyvarinen, A. Fast and robust fixed-point algorithms for independent component analysis. *IEEE Trans. Neural Netw.* **1999**, *10*, 626–634. [\[CrossRef\]](#)
8. Bingham, E.; Hyvarinen, A. A fast fixed-point algorithm for independent component analysis of complex valued signals. *Int. J. Neural Syst.* **2000**, *10*, 1–8. [\[CrossRef\]](#)
9. Karimzadeh, F.; Esmaeili, S.; Hosseini, S.H. A novel method for noninvasive estimation of utility harmonic impedance based on complex independent component analysis. *IEEE Trans. Power Deliv.* **2015**, *30*, 1843–1852. [\[CrossRef\]](#)
10. Karimzadeh, F.; Esmaeili, S.; Hosseini, S.H. Method for determining utility and consumer harmonic contributions based on complex independent component analysis. *Gener. Transm. Distrib. IET* **2016**, *10*, 526–534. [\[CrossRef\]](#)

11. Zhao, X.I.; Yang, H.G. A new method to calculate the utility harmonic impedance based on FastICA. *IEEE Trans. Power Deliv.* **2016**, *31*, 381–388. [\[CrossRef\]](#)
12. Chen, F.Y.; Mao, N.P.; Wang, Y.; Wang, Y.; Xiao, X.Y. Improved utility harmonic impedance measurement based on robust independent component analysis and bootstrap check. *Gener. Transm. Distrib. IET* **2019**, *14*, 910–919. [\[CrossRef\]](#)
13. Lee, T.L.; Hu, S.H. An active filter with resonant current control to suppress harmonic resonance in a distribution power system. *IEEE J. Emerg. Sel. Top. Power Electron.* **2017**, *4*, 198–209. [\[CrossRef\]](#)
14. Song, Y.P.; Ebrahimzadeh, E.; Blaabjerg, F. Analysis of high frequency resonance in DFIG-based offshore wind farm via long transmission cable. *IEEE Trans. Energy Convers.* **2018**, *33*, 1036–1046. [\[CrossRef\]](#)
15. Hu, H.T.; Shao, Y.; Tang, L.; Ma, J.; He, Z.Y.; Gao, S.B. Overview of Harmonic and Resonance in Railway Electrification Systems. *IEEE Trans. Ind. Appl.* **2018**, *54*, 5227–5245. [\[CrossRef\]](#)
16. Burch, R.; Chang, G.; Hatziadoniu, C.; Grady, M.; Liu, Y.; Marz, M.; Ortmeyer, T.; Ranade, S.; Ribeiro, P.; Xu, W. Impact of aggregate linear load modeling on harmonic analysis: A comparison of common practice and analytical models. *IEEE Trans. Power Deliv.* **2003**, *18*, 625–630. [\[CrossRef\]](#)
17. Hua, H.C.; Liu, Z.; Jia, X.F. Partially linear model for harmonic contribution determination. *IEEE Trans. Electr. Electron.* **2016**, *11*, 285–291. [\[CrossRef\]](#)
18. Xu, W.; Bahry, R.; Mazin, H.E.; Tayjasanant, T. A method to determine the harmonic contributions of multiple loads. In Proceedings of the 2009 IEEE Power & Energy Society General Meeting, Calgary, AB, Canada, 22–30 July 2009.
19. Mazin, H.E.; Xu, W.; Huang, B. Determining the harmonic impacts of multiple harmonic-producing loads. *IEEE Trans. Power Deliv.* **2011**, *26*, 1187–1195. [\[CrossRef\]](#)
20. Wang, Y.; Mazin, H.E.; Xu, W.; Huang, B. Estimating harmonic impact of individual loads using multiple linear regression analysis. *Int. Trans. Electr. Energy Syst.* **2016**, *26*, 809–824. [\[CrossRef\]](#)
21. Wang, Y.; Xu, W.; Yong, J.; Chen, K.L. Estimating harmonic impact of individual loads using harmonic phasor data. *Int. Trans. Electr. Energy Syst.* **2017**, *27*, 1–12. [\[CrossRef\]](#)
22. Muscas, C.; Peretto, L.; Sulis, S.; Tinarelli, R. Investigation on multipoint measurement techniques for PQ monitoring. *IEEE Trans. Instrum. Meas.* **2006**, *55*, 1684–1690. [\[CrossRef\]](#)
23. Jain, S.K.; Jain, P.; Singh, S.N. A fast harmonic phasor measurement method for smart grid applications. *IEEE Trans. Smart Grid* **2016**, *8*, 493–502. [\[CrossRef\]](#)
24. Melo, I.D.; Pereira, J.L.R.; Variz, A.M.; Garcia, P.A.N. Harmonic state estimation for distribution networks using phasor measurement units. *Electr. Power Syst. Res.* **2017**, *147*, 133–144. [\[CrossRef\]](#)
25. Rowe, T.; Day, T. The Sampling Distribution of the Total Correlation for Multivariate Gaussian Random Variables. *Entropy* **2019**, *21*, 921. [\[CrossRef\]](#)
26. Xu, C.; Hu, C.K.; Liu, X.L.; Wang, S.J. Information Entropy in Predicting Location of Observation Points for Long Tunnel. *Entropy* **2017**, *19*, 332.
27. Ball, K.; Nguyen, V.H. Entropy jumps for isotropic log-concave random vectors and spectral gap. *Stud. Math.* **2012**, *213*, 81–96. [\[CrossRef\]](#)
28. Liu, Y.M.; Wang, L.H.; Xiao, X.Y.; Wang, Y.; Chen, F.Y. Complex blind source separation based harmonic contribution assessment. In Proceedings of the 2016 17th International Conference on Harmonics and Quality of Power (ICHQP), Belo Horizonte, Brazil, 16–19 October 2016.
29. Zhao, Y.X.; Liu, Z.Y.; Wang, Y.Y.; Wu, H.; Ding, S.X. Sparse Coding Algorithm with Negentropy and Weighted ℓ_1 -Norm for Signal Reconstruction. *Entropy* **2017**, *19*, 599. [\[CrossRef\]](#)
30. Qian, G.; Wei, P. Stability Analysis of complex ICA by negentropy maximization: A unique perspective. *Neurocomputing* **2016**, *214*, 80–85. [\[CrossRef\]](#)
31. Hashim, R.A.; Burch, R.; Chang, G.; Grady, M.; Gunther, E.; Halpin, M.; Harziadonin, C.; Liu, Y.; Marz, M.; Ortmeyer, T.; et al. Test systems for harmonics modeling and simulation. *IEEE Trans. Power Deliv.* **1999**, *14*, 579–587. [\[CrossRef\]](#)
32. Wang, F.; Liu, T.Q.; Li, X.Y. Decreasing the frequency of HVDC commutation failures caused by harmonics. *IET Power Electron.* **2017**, *10*, 215–221. [\[CrossRef\]](#)

33. Li, X.; Wang, Y.; Xu, W. A New Filtering Scheme for HVDC Terminals Based on Damped High-Pass Filter. *IEEE Trans. Power Deliv.* **2019**, *34*, 2050–2057. [[CrossRef](#)]
34. Zhu, L.Y.; Li, J.Y.; Shi, Y.H.; Rehman, H.; Ji, S.C. Audible Noise Characteristics of Filter Capacitors Used in HVDC Converter Stations. *IEEE Trans. Power Deliv.* **2016**, *32*, 2263–2271. [[CrossRef](#)]

© 2020 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).