

Article

Assessment of Performance of the Industrial Process of Bulk Vacuum Packaging of Raw Meat with Nondestructive Optical Oxygen Sensing Systems

Caroline A. Kelly ¹, Malco Cruz-Romero ² , Joseph P. Kerry ² and Dmitri P. Papkovsky ^{1,*}

¹ School of Biochemistry and Cell Biology, University College Cork, Cavanagh Pharmacy Building, College Road, Cork T12 K8AF, Ireland; carolineakelly@gmail.com

² Food Packaging Group, School of Food and Nutritional Sciences, University College Cork, Food Science Building, College Road, Cork T12 K8AF, Ireland; m.cruz@ucc.ie (M.C.-R.); joe.kerry@ucc.ie (J.P.K.)

* Correspondence: d.papkovsky@ucc.ie

Received: 23 March 2018; Accepted: 29 April 2018; Published: 2 May 2018



Abstract: The commercially-available optical oxygen-sensing system Optech-O₂ Platinum was applied to nondestructively assess the in situ performance of bulk, vacuum-packaged raw beef in three ~300 kg containers. Twenty sensors were attached to the inner surface of the standard bin-contained laminate bag (10 on the front and back sides), such that after filling with meat and sealing under vacuum, the sensors were accessible for optical interrogation with the external reader device. After filling and sealing each bag, the sensors were measured repetitively and nondestructively over a 15-day storage period at 1 °C, thus tracking residual oxygen distribution in the bag and changes during storage. The sensors revealed a number of unidentified meat quality and processing issues, and helped to improve the packaging process by pouring flakes of dry ice into the bag. Sensor utility in mapping the distribution of residual O₂ in sealed bulk containers and optimising and improving the packaging process, including handling and storage of bulk vacuum-packaged meat bins, was evident.

Keywords: packaged raw meat; bulk vacuum packaging; nondestructive assessment; residual oxygen; phosphorescent oxygen sensor; QC/QA; food safety and process optimisation

1. Introduction

Fresh raw meat represents a large and important segment of fast-moving packaged food products produced commercially on a large scale, for many different types of meats, portion sizes, and formats. To ensure the delivery of high quality and safe products to market, prevent meat deterioration, and extend product shelf life, the employment of modified atmosphere packaging, including vacuum packaging, is undertaken. By tailoring gas composition within the package, packaging materials used, and processes employed, microbial growth and other degradative processes can be inhibited and/or product appearance improved [1,2]. For example, some red meats such as steaks require medium to high levels of O₂ to allow oxygenation of the endogenous myoglobin which maintains the aesthetically pleasing red colour. In contrast, lipid (and other) oxidation-led reactions necessitate low O₂ levels to prevent a decline in product quality. Residual O₂ is a useful indicator of package integrity, packaging material defects, or signs of physical abuse of packaged goods during processing, storage, and transportation.

Close monitoring of O₂ levels within packages enables the detection of the issues described, highlights steps that need to be addressed in order to bring packaging and related processes under control, and directs attention to defective packs where the required protective atmosphere has been

lost [3]. Such products can be repackaged before they leave the factory or be removed from the line, thereby preventing any low-quality and potentially unsafe goods from reaching the retailer and consumer and circumvent other issues such as customer complaints, product removal from supermarket shelves, logistical issues such as product retrieval by manufacturers from the market, and so on.

Currently used packaging approaches do not allow for nondestructive, real-time, repetitive measurement of the environmental conditions within individual packs after they have been produced. Usually, a certain proportion of packs are sampled statistically and assessed for O₂ content by destructive methods such as gas chromatography or needle-type gas analyzers which can measure O₂ and CO₂ [2]. These methods are invasive; incapable of detecting all faulty or insufficient-quality packs, which have been shown to be rather frequent [4,5]; often require a skilled operator; consume the analyte measured; poorly suited for vacuum-packaged samples (shrunk and possessing no headspace); in addition to rendering the pack unsuitable for return to the line or release to the market.

Phosphorescent O₂ sensors, such as those developed by Mocon, Presens, Oxysense, and other vendors [3], can help address the issues highlighted above. These systems can provide simple, accurate, nondestructive, real-time measurement of residual O₂ levels in multiples of sealed containers for a wide range of packaged food and beverage products. The advantages of using these types of sensor is that they can be used on a disposable or continuous basis and offer major advantages over alternative systems in the analysis of residual O₂ levels. The sensors provide quick, quantitative, contactless readout of O₂ concentration and can serve a multitude of analytical and quality control/quality assurance (QC/QA) tasks [6,7]. Such sensors currently cost a few dollars each and efforts are being made to make them even more affordable, calibration-free, and capable of being produced on a large-scale basis and incorporated ultimately in every pack [8,9]. A number of studies employing such O₂ sensors have been conducted using food products, such as ham [10], beef [5], cheese [11], lettuce [12], bread [13], convenience foods [14], and for troubleshooting within cheese production processes [15] and to measure the depletion of O₂ in raw beef and chicken packs [16]. However, no studies of which we are aware have been performed using such sensor systems to assess the large-scale, bulk packaging of beef in a commercial meat processing plant. On the other hand, in bulk vacuum packaging of raw meat, significant heterogeneity of residual O₂ levels in packaged samples is anticipated, which may be caused by slow filling of the container with the product, trapping and creating pockets of air between meat pieces and layers of meat, incomplete flushing of large product-filled containers with inert gas, and subsequent sealing under vacuum.

In this study, we set out to demonstrate the effective use of the commercial Optech-O₂ Platinum sensor system to control the quality of bulk packaging of raw beef in an Irish commercial beef processing plant.

2. Materials and Methods

2.1. Preparation of Containers with Sensors and Meat

Twenty phosphorescent O₂ sensor stickers (Mocon, Minneapolis, MN, USA) were attached to the inner side of a bulk, laminate plastic-based pouch which was designed for vacuum packing and employment within a steel frame storage bin for the bulk transportation of beef carcass off-cuts. The sensors were distributed evenly inside the laminate pouch: ten sensors were facing the front side and ten were facing the back side of the bin (these sides contained metal grids, and the other two sides were covered with metal sheets). The sensors were positioned such that after bulk pouch filling with meat and sealing under vacuum, they could be accessed for reading purposes through the use of an external handheld Optech-O₂ Platinum reader (Mocon, Minneapolis, MN, USA). This container was then filled with approximately 300 kg of forequarter meat. Flakes of dry ice were applied periodically between layers of meat. After filling, the container was left to rest for 45 min to allow the evaporating dry ice to displace residual O₂ from within the pouch. Then, the whole container was moved by forklift

to a vacuum-packaging unit, vacuum packed, and sealed. Images of a bulk bin container containing meat and located sensors are shown in Figure 1. Thus, each sensor reported on residual O₂ levels in the specific corresponding area of the package within which it was situated. A total of three bins were produced and analysed in this manner.




Figure 1. Top view of a bulk bin with vacuum-packaged meat (**top**) and its side view in a bin (**bottom left**) showing the location of individual O₂ sensors (**bottom right**).

2.2. Storage and Measurement of O₂ Levels

After the packaging process was completed, the bulk bin container was moved to a chilled warehouse where it was stored at 1 °C for 15 days. Prior to the measurement of the O₂ sensors in bins, the Optech-O2 Platinum system was calibrated at 1 °C with a dedicated calibration card (CalCard[®], Mocon). On Days 1, 3, 7, 11, and 15, the bins were brought to the processing hall, where temperature was ~12 °C, and O₂ readings from each sensor were quickly taken with the Optech[®] reader by bringing it close to the sensor (<10 mm distance) and initiating the reading. The instrument measured the phosphorescence signals (intensity and lifetime) as well as sample temperature with a built-in infrared (IR) probe, performed the necessary correction and calculations, displayed O₂ concentration (in % or

kPa units) in the corresponding region of bag, and stored the data. Measurement of each sensor took between 1 and 3 s to complete.

3. Results and Discussion

Design of the Sensor Trial with Bulk Vacuum-Packaged Meat

In food packs that contain headspace, such as modified atmosphere packaged (MAP) foods, it is usually sufficient to employ one sensor to gather information about the average residual oxygen levels present within the whole pack. However, in products such as vacuum-packaged meats, readings from one sensor at a specific location may not be representative, since the sensor is only capable of detecting the presence of oxygen in the immediate locality to where the sensor is positioned, and consequently, the ability to determine O₂ concentration and gas exchange within such a pack is restricted, since a headspace is absent [17]. Even for small vacuum packs, this creates a problem, since physical damage or faults affecting remote areas of the package are not always detectable with one sensor, since its response is mediated by O₂ diffusion.

For large packages, such as bulk vacuum-packaged systems, one can also anticipate significant heterogeneity in residual O₂ levels throughout the package. This can arise from the slow filling of the container with the product, trapping air and creating air pockets between individual products and product layers, difficulties with efficient flushing of the large product-filled container with inert gas, and its subsequent sealing under vacuum. All of these issues apply to the bulk vacuum packaging of primal meat cuts destined for subsequent processing. From a production perspective, it is critically important to be able to visualise and control such heterogeneities in order to maintain product safety and quality. This, in turn, can open the way to optimising and minimising these heterogeneities, and by so doing, control the residual oxygen level for the whole pack.

One simple way to address these challenges is to incorporate multiple O₂ sensors per pack which can report nondestructively on local O₂ levels in various regions of the pack. Periodic measurement of these sensors would allow one to visualise maps of O₂ distribution in such packages and understand their dynamics during product handling and shelf life. With oxygen sensors becoming more affordable, accurate, and calibration-free, such trials, even with very large bulk product packs employing numerous sensors, are now becoming more simple to use, informative, and commercially justifiable. From a sustainability and environmental perspective, this means that the products examined are not wasted and the sensors can also be recovered, cleaned, and reused, if required.

Thus, we introduced an array of individual O₂ self-adhesive-based sensors in the large, laminate plastic-based pouches employed for bulk vacuum packaging of fresh meat, as described previously, to assess the efficiency of the packaging procedure, optimise it, and ensure that residual O₂ content, quality, and safety of the packaged meat were all within acceptable limits.

A total of three bins, each filled with approximately 300 kg of fresh beef, were produced and analysed in this manner. The top and side views of a bulk bin containing vacuum-packaged meat and sensors (a total of 10 sensors located on the front and back side of the vacuum-packaged laminate pouch) are shown in Figure 1.

In the first experimental trial (Bin 1), sensors detected that the laminate pouch was not vacuum-packaged correctly owing to an insufficient vacuum being pulled, thereby allowing some of the CO₂ atmosphere generated by employment of dry ice to be replaced with air (high O₂). This necessitated the package being opened again and resealed under vacuum. Owing to this containment fault, residual O₂ levels in Bin 1 were relatively high.

Individual O₂ sensor readings from Bin 1 are shown in Table 1. On the day of filling (Day 1), three out of 20 sensors were masked by the metal grid of the container and were unreadable. However, on subsequent Days 3, 8, 11, and 15, they became accessible for measurement owing to slight movements of the bag inside the bin following bin transportation within the factory by forklift. On Day 1, a significant number of sensors (9 out of 17) showed residual O₂ levels of >1%, with two

sensors indicating the presence of >6% O₂. Mean O₂ levels on Day 1 were determined to be $1.8 \pm 2.3\%$ (mean and SD values). Such levels were deemed unacceptably high, as typical specifications for small vacuum packs of beef are <0.5% O₂ [5].

Table 1. Residual O₂ level readings (%) for each sensor contained in Bin 1 over a 15-day storage period.

Location	Day 1	Day 3	Day 8	Day 11	Day 15
Front 1	0.00	0.00	0.11	0.22	0.32
Front 2	1.05	0.25	0.42	0.42	0.75
Front 3	0.45	0.46	0.29	0.33	0.57
Front 4	1.85	0.01	0.13	0.14	0.36
Front 5	0.83	1.63	0.27	0.23	0.16
Front 6	1.13	1.64	0.56	0.81	1.06
Front 7	0.00	4.47	0.97	1.02	0.98
Front 8	2.64	0.03	0.08	1.13	0.00
Front 9	6.80	0.21	0.72	0.12	0.08
Front 10	7.53	1.63	0.25	0.15	0.23
Back 1	1.17	0.00	0.11	0.14	0.43
Back 2	0.00	0.17	0.13	0.07	0.10
Back 3	0.00	0.56	0.19	0.34	0.63
Back 4	0.98	0.05	0.08	0.21	0.29
Back 5	0.06	0.02	0.04	0.14	0.19
Back 6	3.35	0.18	0.07	0.04	0.07
Back 7	2.17	0.65	0.70	0.10	0.12
Back 8	N/A	0.72	0.53	0.59	0.17
Back 9	N/A	0.35	0.07	0.99	0.49
Back 10	N/A	1.02	0.21	0.20	0.11
Mean, % O₂	1.76	0.70	0.30	0.37	0.35
SD, % O₂	2.26	1.05	0.27	0.35	0.31

N/A: sensor not accessible for measurement.

It is worth noting that during the O₂ measurements in the bins, sample/sensor temperatures typically ranged from 3.0 to 3.8 °C, being close to Optech's normal operational range (5–40 °C, according to vendor specifications). In addition, with the calibration at 1 °C using the Mocon CalCard, the Optech system provided reliable and accurate O₂ readings under experimental conditions used in this study. Thus, individual sensors measured under identical experimental conditions (1 °C, 20.86% O₂) showed O₂ values $20.6 \pm 0.8\%$ (mean and SD). They are shown in Supplementary Materials, Figure S1.

On Day 3, O₂ values decreased significantly (0.7 ± 1.1), as determined by the majority of sensors; however, five out of 20 sensors still detected >1% O₂ (Table 1). From Day 8 onwards, the majority of sensors provided O₂ readings below 0.3%. Mean O₂ values on the subsequent days stabilised and remained at around 0.3–0.4% (Table 1).

The industrial packaging process is aimed at bringing the environment of the pack from the initial 20.86% of O₂ (ambient air) down to zero levels (or as close as possible). This is particularly challenging for large and heterogeneous samples and multistep packaging processes, such as those used in our meat bins. Residual microbubbles of air trapped between meat pieces and incomplete flushing or displacement of air with CO₂, if they occur, are expected to have significant impact on local residual O₂ levels.

Our experimental results with O₂ sensor arrays in Bin 1 satisfactorily prove this and reveal prominent sample heterogeneity. They also prove that single-point O₂ measurements, currently used in process control, are not efficient and less representative for such samples. Under identical experimental conditions (1 °C, 20.86% O₂), individual sensors show variability of $\pm 0.05\%$ O₂ (see Mocon product specifications and Supplementary Materials, Figure S1), therefore sensor variability has a very minor contribution to the variability or sensor readings in the bins.

The technical and packaging processing issues highlighted in the experimental Bin 1 trial were partly addressed when conducting the second experimental trial employing Bin 2. However, vacuum packaging and sealing were problematic again, and Bin 2 had to be opened and resealed as described previously for Bin 1. As a consequence, Bin 2 indicated lower O₂ levels than Bin 1 (mean values were less than 1.2% throughout the study), but still above the anticipated, required, and achievable range (Table 2). Again, eight sensors out of 20 showed O₂ levels exceeding 1%.

In the final experimental trial involving Bin 3, in which air was properly displaced with CO₂ (dry ice) and sealed correctly following efficient vacuum application, the lowest O₂ levels were determined of the three experimental bins (Table 3). Mean residual O₂ levels within the bulk vacuum pack stayed in the range of 0.07–0.22% over the initial 11 days of storage. In addition, on Day 15 of storage, two sensors showed marked increase in O₂ (Figure 2), resulting in significantly elevated mean values and SD on that day. We credited the latter effects to the potential microrupture of the pouch while being transported from the warehouse to the production floor by forklift or following the release of air from gas pockets trapped within the bulk meat mass somewhere close to these sensors. One additional sensor in Bin 3 was rendered unreadable by puckering of some of the plastic packaging through meat movement within the container.

Having measured residual O₂ values in all three bins from all usable sensors, nondestructively, and repetitively over three repeated 15-day storage periods, we further analysed these results by comparing all three data sets. Figure 2 shows the dynamics of O₂ readings taken from all individual sensors located in Bin 1 (top) and Bin 3 (bottom). One can see that the O₂ scale for the packaging process carried out for Bin 1 is greater by almost one order of magnitude when compared to Bin 3, indicating the difference between ineffective packaging application and effective packaging application.




Figure 2. Mean O₂ readings obtained from sensor stickers placed in Bins 1 (top) and 3 (bottom) over a 15-day storage period.

Table 2. Residual O₂ level readings (%) for each sensor contained in Bin 2 over a 15-day storage period.

Location	Day 1	Day 3	Day 8	Day 11	Day 15
Front 1	0.33	0.50	0.00	0.47	0.36
Front 2	0.00	0.41	0.11	0.76	0.79
Front 3	0.45	0.46	0.11	0.15	0.00
Front 4	0.00	0.36	0.14	0.28	0.00
Front 5	0.00	0.27	0.08	0.31	0.00
Front 6	0.23	0.31	0.59	0.00	0.23
Front 7	0.51	0.36	0.13	0.11	0.34
Front 8	3.52	0.42	0.08	0.82	0.32
Front 9	0.63	0.41	0.17	0.30	0.69
Front 10	2.61	0.00	0.17	0.00	0.66
Back 1	1.24	0.38	0.18	0.39	0.43
Back 2	2.23	7.19	3.36	1.65	0.50
Back 3	0.00	0.17	0.00	0.00	0.74
Back 4	0.66	0.49	0.00	0.55	0.43
Back 5	3.32	0.80	0.26	0.50	0.21
Back 6	0.73	1.71	0.08	0.19	0.43
Back 7	2.19	0.30	0.28	0.32	0.25
Back 8	0.00	0.28	0.14	0.19	0.00
Back 9	3.17	N/A	N/A	N/A	N/A
Back 10	3.07	N/A	N/A	N/A	N/A
Mean, % O₂	1.24	0.82	0.33	0.39	0.35
SD, % O₂	1.30	1.63	0.77	0.40	0.26

Table 3. Residual O₂ level readings (%) for each sensor in Bin 3 over a 15-day storage period.

Location	Day 1	Day 3	Day 8	Day 11	Day 15
Front 1	0.00	0.28	0.07	0.08	0.20
Front 2	0.14	0.26	0.08	0.13	0.17
Front 3	0.01	0.24	0.01	0.05	0.20
Front 4	0.11	0.13	0.13	0.16	0.84
Front 5	0.00	0.26	0.08	0.19	0.10
Front 6	0.10	0.21	0.11	0.17	0.31
Front 7	0.03	0.19	0.10	0.16	0.22
Front 8	0.43	0.15	0.07	0.17	0.24
Front 9	0.20	0.00	0.05	0.21	0.32
Back 1	0.00	0.27	0.04	0.13	0.19
Back 2	0.00	0.30	0.12	0.12	0.14
Back 3	0.00	0.27	0.09	0.21	0.38
Back 4	0.00	0.28	0.06	0.09	0.80
Back 5	0.00	0.14	0.04	0.04	0.19
Back 6	0.30	0.20	0.10	0.08	0.26
Back 7	0.00	0.34	0.00	0.01	0.02
Back 8	0.00	0.20	0.10	0.00	0.27
Back 9	0.00	0.16	0.00	0.00	0.00
Back 10	0.00	0.28	0.00	0.10	0.14
Mean, % O₂	0.07	0.22	0.07	0.11	0.26
SD, % O₂	0.12	0.08	0.04	0.07	0.22

The majority of O₂ readings from the sensors in Bins 1 and 2 show a consistent downward trend over time (see individual and mean O₂ values in Tables 1–3). We attribute this to oxygen consumption by the meat and gradual equilibration of sample macroenvironment. Occasional jumps in O₂ readings are likely due to the handling of the bin with a forklift between the measurements. This can dislocate pieces of meat and sensors within the bin and/or release some air trapped in areas adjacent to the sensor, and thus affect the O₂ readings.

Figure 3 shows average O₂ readings and SD for sensors located in the three primary location areas (bottom, middle, and top) within each bulk vacuum-packaged pouch, which reveal trends in O₂ distribution within each bin. In Bin 1, on Day 1, O₂ concentration increased from the bottom to the top of the bulk pouch. The top section of the bin is seen as most vulnerable to O₂ ingress, air displacement with CO₂, and the quality of vacuum sealing applied. In particular, Bins 1 and 2 showed the highest O₂ levels in the top section of the bins, most likely due to ineffective packaging and the requirement to revacuum package and reseal. However, by Days 3, 8, and 11, the random distribution of O₂ concentrations throughout Bins 1 and 2 were similar. Day 15 showed a shift in O₂ distribution from previous storage days, possibly induced by the movement of the bulk-containing bins from the warehouse to the production floor. Bin 3 possessed a more uniform O₂ distribution pattern from the top of the pack to its bottom throughout the 15-day storage period.




Figure 3. Comparison of mean O₂ readings in top, middle, and bottom parts of Bins 1, 2, and 3, measured on Day 1 (A), Day 3 (B), Day 11 (C), and Day 15 (D).

4. Conclusions

Incorporating an array of individually addressable phosphorescence-based O₂ sensor stickers in large bins of raw meat (300 kg each) which undergo bulk packaging under vacuum has enabled nondestructive, contactless monitoring of residual O₂ levels in the various parts of the bin throughout a 15-day storage period. Such measurements performed with commercial O₂ sensors and handheld detection instrumentation helped to map O₂ distribution and dynamics in such commercial bulk meat packs, and to reveal a number of technical issues in the current packaging process. These issues were subsequently addressed and led to a significant improvement in commercial packaging processes, producing much lower and more consistent residual O₂ levels in bulk meat bins. This analytical approach and optimisation of the packaging process have been adopted by the industrial partner for

further operation. The adoption demonstrates how optical O₂ sensors are effective in detecting process failures and optimising the packaging process, particularly for bulk packaging of raw meat.

Supplementary Materials: The following are available online at <http://www.mdpi.com/1424-8220/18/5/1395/s1>, Figure S1: Measurement of O₂ with Optech sensors at 1 °C. (A) Readings from 8 individual sensors under standard experimental conditions (1 °C, 20.86% O₂) produced with an Optech-O₂ Platinum reader calibrated with CalCard at 1 °C. (B) O₂ readings from the same sensors measured at 1 °C (blue bar) and 22 °C (orange bar). Mean O₂ values are 20.6 ± 0.8 and 21.0 ± 0.5, respectively. Calculated p-value of 0.12 shows that the difference is not significant ($p > 0.05$, N = 8). Temperature readings at 1 °C were 1.7 ± 1.0 °C, and at 22 °C—22.0 ± 0.1 °C.

Author Contributions: Conceptualization, D.P.P., J.P.K.; Methodology, D.P.P., J.P.K.; Study design, J.P.K., C.A.K., Measurements, C.A.K., M.C.-R., Laboratory validation, C.A.K., M.C.-R.; Data Analysis, C.A.K., M.C.-R.; Original Draft Preparation, C.A.K.; Review & Editing, D.P.P., J.P.K., Supervision, D.P.P., J.P.K.; Project Administration, J.P.K.; Funding Acquisition, D.P.P., J.P.K.

Acknowledgments: Financial support of this work by the Irish Department of Agriculture, Food and the Marine, grant DAFM 11/F/015, is gratefully acknowledged. The authors thank the staff of the meat production plant for facilitating this study.

Conflicts of Interest: The authors C.A.K., M.C.-R. and J.P.K. declare no conflict of interest. D.P.P. was involved in the development of commercial Optech-O₂ Platinum sensor system, which was then used in this study.

References

1. Kerry, J.P.; Butler, P. *Smart Packaging Technologies for Fast Moving Consumer Goods*; John Wiley & Sons: Hoboken, NJ, USA, 2008.
2. Robertson, G.L. *Food Packaging: Principles and Practice*, 3rd ed.; Taylor & Francis: New York, NY, USA, 2012.
3. Banerjee, S.; Kelly, C.; Kerry, J.P.; Papkovsky, D.B. High throughput non-destructive assessment of quality and safety of packaged food products using phosphorescent oxygen sensors. *Trends Food Sci. Technol.* **2016**, *50*, 85–102. [[CrossRef](#)]
4. Smiddy, M.; Fitzgerald, M.; Kerry, J.P.; Papkovsky, D.B.; O'Sullivan, C.K.; Guilbault, G.G. Use of oxygen sensors to non-destructively measure the oxygen content in modified atmosphere and vacuum packed beef: Impact of oxygen content on lipid oxidation. *Meat Sci.* **2002**, *61*, 285–290. [[CrossRef](#)]
5. Smiddy, M.; Papkovsky, D.; Kerry, J. Evaluation of oxygen content in commercial modified atmosphere packs (MAP) of processed cooked meats. *Food Res. Int.* **2002**, *35*, 571–575. [[CrossRef](#)]
6. Papkovsky, D.B.; Dmitriev, R.I. Biological detection by optical oxygen sensing. *Chem. Soc. Rev.* **2013**, *42*, 8700–8732. [[CrossRef](#)] [[PubMed](#)]
7. Wang, X.-D.; Wolfbeis, O.S. Optical methods for sensing and imaging oxygen: Materials, spectroscopies and applications. *Chem. Soc. Rev.* **2014**, *43*, 3666–3761. [[CrossRef](#)] [[PubMed](#)]
8. Kelly, C.A.; Toncelli, C.; Kerry, J.P.; Papkovsky, D.B. Phosphorescent O₂ sensors based on polyolefin fabric materials. *J. Mater. Chem. C* **2014**, *2*, 2169–2174. [[CrossRef](#)]
9. Toncelli, C.; Arzhakova, O.V.; Dolgova, A.; Volynskii, A.L.; Bakeev, N.F.; Kerry, J.P.; Papkovsky, D.B. Oxygen-sensitive phosphorescent nanomaterials produced from high-density polyethylene films by local solvent-crazing. *Anal. Chem.* **2014**, *86*, 1917–1923. [[CrossRef](#)] [[PubMed](#)]
10. Papkovsky, D.B.; Smiddy, M.A.; Papkovskaia, N.Y.; Kerry, J.P. Nondestructive measurement of oxygen in modified atmosphere packaged hams using a phase-fluorimetric sensor system. *J. Food Sci.* **2002**, *67*, 3164–3169. [[CrossRef](#)]
11. O'Mahony, F.C.; O'Riordan, T.C.; Papkovskaia, N.; Kerry, J.P.; Papkovsky, D.B. Non-destructive assessment of oxygen levels in industrial modified atmosphere packaged cheddar cheese. *Food Control* **2006**, *17*, 286–292. [[CrossRef](#)]
12. Hempel, A.; Sullivan, M.; Papkovsky, D.; Kerry, J. Assessment and use of optical oxygen sensors as tools to assist in optimal product component selection for the development of packs of ready-to-eat mixed salads and for the non-destructive monitoring of in-pack oxygen levels using chilled storage. *Foods* **2013**, *2*, 213–224. [[CrossRef](#)] [[PubMed](#)]
13. Hempel, A.W.; O'Sullivan, M.G.; Papkovsky, D.B.; Kerry, J.P. Use of smart packaging technologies for monitoring and extending the shelf-life quality of modified atmosphere packaged (MAP) bread: Application of intelligent oxygen sensors and active ethanol emitters. *Eur. Food Res. Technol.* **2013**, *237*, 117–124. [[CrossRef](#)]

14. O'Mahony, F.C.; O'Riordan, T.C.; Papkovskaia, N.; Ogurtsov, V.I.; Kerry, J.P.; Papkovsky, D.B. Assessment of oxygen levels in convenience-style muscle-based sous vide products through optical means and impact on shelf-life stability. *Packag. Technol. Sci.* **2004**, *17*, 225–234. [[CrossRef](#)]
15. O'Callaghan, K.; Papkovsky, D.; Kerry, J. An assessment of the influence of the industry distribution chain on the oxygen levels in commercial modified atmosphere packaged cheddar cheese using non-destructive oxygen sensor technology. *Sensors* **2016**, *16*, 916. [[CrossRef](#)] [[PubMed](#)]
16. Morsy, M.K.; Khalaf, H.H.; Sharoba, A.M.; El-Tanahi, H.H. Applicability of biosensor and oxygen sensor for monitoring spoilage and bacterial contaminants of packed minced beef and poultry. In Proceedings of the 2nd International Conference on Biotechnology Applications in Agriculture (ICBAA), Hurghada, Egypt, 8–12 April 2014.
17. Fitzgerald, M.; Papkovsky, D.; Smiddy, M.; Kerry, J.; O'Sullivan, C.; Buckley, D.; Guilbault, G. Nondestructive monitoring of oxygen profiles in packaged foods using phase-fluorimetric oxygen sensor. *J. Food Sci.* **2001**, *66*, 105–110. [[CrossRef](#)]



© 2018 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).