

Supplementary Material

Air Exchange Rate (AER) Model

The AER has two parameters (k_s and k_w) and five inputs (A_{leak} , T_{in} , T_{out} , U , and V), where A_{leak} is the effective air leakage area; k_s is the stack coefficient; k_w is the wind coefficient; T_{in} and T_{out} are the indoor and outdoor temperatures, respectively; U is the wind speed; and V is the house volume. Parameters k_s and k_w were set to literature-reported values based on house-specific information on house height (number of stories) and local wind sheltering (Tables S1–S3). The user-provided number of stories and local wind sheltering can be determined from satellite and street-level images in Google Earth (version 7.1.7.2606; Google, Mountain View, CA, USA). The number of stories can be verified from online county and real estate databases of property records (Zillow, Seattle, WA, USA; Trulia, San Francisco, CA, USA). To determine V , we multiplied floor area by a ceiling height of 2.44 m (8 ft). The user-provided floor area can be obtained from the online county and real estate databases.

We estimate A_{leak} with a literature-reported leakage area model [1,2]. The A_{leak} is calculated as:

$$A_{\text{leak}} = \frac{NL}{NF} \quad (\text{S1})$$

where NL is the normalized leakage and NF is the normalization factor. The NL is predicted from year of construction Y_{built} and floor area A_{floor} as described by:

$$NL = \exp(\beta_0 + \beta_1 Y_{\text{built}} + \beta_2 A_{\text{floor}}) \quad (\text{S2})$$

where β_0 , β_1 , and β_2 are regression parameters. The user-provided Y_{built} and A_{floor} can be obtained from the online county and real estate databases. The NF is defined as:

$$NF = \frac{1000}{A_{\text{floor}}} \left(\frac{H}{2.5}\right)^{0.3} \quad (\text{S3})$$

where H is the building height. We set H to the number of stories multiplied by a story height of 2.5 m and adding a roof height of 0.5 m [1]. The parameters β_0 , β_1 , and β_2 were estimated by Chan et al. (2005) for conventional homes ($\beta_0 = 20.7$, $\beta_1 = -1.07 \times 10^{-2}$, and $\beta_2 = -2.20 \times 10^{-3} \text{m}^{-2}$).

For the LBLX model, the airflow from natural ventilation Q_{nat} can be calculated as:

$$Q_{\text{nat}} = \sqrt{Q_{\text{nat,wind}}^2 + Q_{\text{nat,stack}}^2} \quad (\text{S4})$$

where $Q_{\text{nat,wind}}$ and $Q_{\text{nat,stack}}$ are the airflows from the wind and stack effects, respectively. The $Q_{\text{nat,wind}}$ is defined as:

$$Q_{\text{nat,wind}} = C_v A_{\text{nat}} U \quad (\text{S5})$$

where C_v is the effectiveness of the openings, and the A_{nat} is the area of the inlet openings. Using literature-reported values, we set C_v to 0.3 and A_{nat} to one-half of the total area of window openings [1]. When window opening area is not available, we set A_{nat} to one-half of the literature-reported value of 619 cm², which is the median daily total window opening area for homes in the same region of central NC as DEPS [1]. The $Q_{\text{nat,stack}}$ is defined as:

$$Q_{\text{nat,stack}} = C_D A_{\text{nat}} \sqrt{2g\Delta H_{\text{NPL}} |T_{\text{in}} - T_{\text{out}}| / \max\{T_{\text{in}}, T_{\text{out}}\}} \quad (\text{S6})$$

where C_D is the discharge coefficient for the openings, g is the gravitational acceleration, ΔH_{NPL} is the height from midpoint of lower window opening to the neutral pressure level (NPL) of the building, and $\max\{T_{\text{in}}, T_{\text{out}}\}$ is the maximum value between T_{in} and T_{out} . Using literature-reported values, we set C_D to 0.65, the midpoint of lower window opening to 0.91 m, and NPL to one-half of H [1].

Table S1. Stack coefficient¹ k_s ((L/s)²/(cm⁴ K)).

	House Height (Stories)		
	One	Two	Three
Stack coefficient	0.000145	0.000290	0.000435

¹ ASHRAE Handbook-Fundamentals, 2009.**Table S2.** Wind coefficient ¹ k_w ((L/s)²/(cm⁴ (m/s)²)).

Shelter Class	House Height (Stories)		
	One	Two	Three
1	0.000319	0.000420	0.000494
2	0.000246	0.000325	0.000382
3	0.000174	0.000231	0.000271
4	0.000104	0.000137	0.000161
5	0.000032	0.000042	0.000049

¹ ASHRAE Handbook-Fundamentals, 2009.**Table S3.** Local sheltering ¹.

Shelter Class	Description
1	No obstructions or local sheltering
2	Typical shelter for an isolated rural house
3	Typical shelter caused by other buildings across street from building under study
4	Typical shelter for urban buildings on larger lots where sheltering obstacles are more than one building height away
5	Typical shelter produced by buildings or other structures immediately adjacent (closer than one building height): e.g., neighboring houses on same side of street, trees, bushes, etc.

¹ ASHRAE Handbook-Fundamentals, 2009.**References**

1. Breen MS, Breen M, Williams RW, Schultz BD. 2010. Predicting residential air exchange rates from questionnaires and meteorology: model evaluation in central North Carolina. Environ Sci Technol 44:9349-9356.
2. Chan WR, Nazaroff WW, Price PN, Sohn MD, Gadgil AJ. 2005. Analyzing a database of residential air leakage in the United States. Atmos Environ 39:3445-3455.
3. The 2009 ASHRAE Handbook-Fundamentals, American Society of Heating, Refrigerating, and Air Conditioning Engineers: Atlanta, GA, 2009.

Ventilation Rates for Inhaled Dose Model (L/min/kg body weight)

Table S4. Male sedentary.

< Male Sedentary Intensity	
VENTILATION RATES (L/MIN/KG BODY WEIGHT)	
1 year old	0.40
2 years old	0.34
3-5 years old	0.25
6-10 years old	0.16
11-15 years old	0.10
16-20 years old	0.08
21-30 years old	0.06
31-60 years old	0.07
61-80 years old	0.08
81 years and older	0.09

Table S5. Male light intensity.

< Back Male Light Intensity	
VENTILATION RATES (L/MIN/KG BODY WEIGHT)	
1 year old	1.01
2 years old	0.83
3-5 years old	0.63
6-10 years old	0.38
11-15 years old	0.24
16-20 years old	0.18
21-30 years old	0.15
31-70 years old	0.16
71-80 years old	0.17
81 years and older	0.18

Table S6. Male moderate intensity.

< Male Moderate Intensity	
1 year old	1.82
2 years old	1.54
3-5 years old	1.12
6-10 years old	0.71
11-15 years old	0.47
16-20 years old	0.38
21-40 years old	0.34
41-50 years old	0.35
51-60 years old	0.37
61-70 years old	0.34
71-80 years old	0.36
81 years and older	0.38

Table S7. Male vigorous intensity.

< Male Vigorous Intensity	
1 year old	3.57
2 years old	2.87
3-5 years old	2.11
6-10 years old	1.38
11-15 years old	0.91
16-20 years old	0.69
21-30 years old	0.64
31-40 years old	0.62
41-50 years old	0.63
51-60 years old	0.64
61-70 years old	0.61
71-80 years old	0.63
81 years and older	0.70

Table S8. Female sedentary.

< Female Sedentary Intensity	
VENTILATION RATES (L/MIN/KG BODY WEIGHT)	
1 year old	0.42
2 years old	0.35
3-5 years old	0.25
6-10 years old	0.16
11-15 years old	0.09
16-20 years old	0.07
21-50 years old	0.06
51-80 years old	0.07
81 years and older	0.08

Table S9. Female light intensity.

< Back Female Light Intensity	
VENTILATION RATES (L/MIN/KG BODY WEIGHT)	
1 year old	1.04
2 years old	0.89
3-5 years old	0.60
6-10 years old	0.38
11-15 years old	0.22
16-20 years old	0.17
21-40 years old	0.15
41-60 years old	0.16
61-70 years old	0.14
71 years and older	0.16

Table S10. Female moderate intensity.

 Female Moderate Intensity	
1 year old	1.87
2 years old	1.58
3-5 years old	1.11
6-10 years old	0.71
11-15 years old	0.43
16-20 years old	0.35
21-30 years old	0.32
31-40 years old	0.30
41-50 years old	0.32
51-60 years old	0.33
61-70 years old	0.28
71-80 years old	0.30
81 years and older	0.33

Table S11. Female vigorous intensity.

 Female Vigorous Intensity	
1 year old	3.24
2 years old	2.81
3-5 years old	1.90
6-10 years old	1.33
11-15 years old	0.85
16-20 years old	0.69
21-30 years old	0.63
31-40 years old	0.59
41-50 years old	0.64
51-60 years old	0.61
61-70 years old	0.53
71-80 years old	0.58
81 years and older	0.63

TracMyAir Screenshots



Figure S1. Main screen for TracMyAir.

The screenshot shows the 'Results' screen of the TracMyAir application. The status bar at the top shows 'Verizon LTE', '10:55 AM', and '99%' battery. Navigation links for '< Back' and 'Details' are at the top. The screen displays a table of exposure and dose data for a period from 4/11/19 to 4/12/19.

Start	4/11/19, 10:55 AM
End	4/12/19, 10:55 AM
Total exposure time	24:00
EXPOSURE	
PM2.5 exposure	3.7 $\mu\text{g}/\text{m}^3$
Ozone exposure	9.14 ppb
DOSE PER BODY SURFACE AREA	
PM2.5 dose	15.0 $\mu\text{g}/\text{m}^2$
Ozone dose	89.6 $\mu\text{g}/\text{m}^2$
Include past 4 days in email ☐	
Email input and output data	

Figure S2. TracMyAir output screen.




Figure S3. TracMyAir map of the nearest PM_{2.5} and O₃ stations, 24-h average temperature, and wind speed.




Figure S4. TracMyAir map of nearest weather monitors, and 24-h average concentrations.