



Study on the Coupling Effect of a Solar-Coal Unit Thermodynamic System with Carbon Capture

Jixuan Wang¹, Wensheng Liu¹, Xin Meng¹, Xiaozhen Liu², Yanfeng Gao¹, Zuodong Yu¹, Yakai Bai³ and Xin Yang^{1,*}

- ¹ School of Water Conservancy and Electric Power, Hebei University of Engineering, Handan 056000, China; wangjixuan113@163.com (J.W.); liuwensheng99@163.com (W.L.); mengxin_78@163.com (X.M.); gaoyanfeng01@126.com (Y.G.); yuzuodong123@163.com (Z.Y.)
- ² Electronic and Information Engineering, Handan Polytechnic College, Handan 056000, China; wjxlxz113@163.com
- ³ Key Laboratory of Solar Thermal Energy and Photvoltaic System of Chinese Academy of Science, Institute of Electrical Engineering, No. 6 Beiertiao, Zhongguancun, Beijing 100000, China; baiyakai@iet.cn
- * Correspondence: yangxin@hebeu.edu.cn

Received: 12 July 2020; Accepted: 8 September 2020; Published: 14 September 2020



Abstract: Based on the structural theory of thermo-economics, a 600 MW unit was taken as an example. An integration system which uses fuel gas heat and solar energy as a heat source for post-combustion carbon capture was proposed. The physical structure sketch and productive structure sketch were drawn and a thermo-economics model and cost model based on the definition of fuel-product were established. The production relation between units was analyzed, and the composition and distribution of the exergy cost and thermo-economic cost of each unit were studied. Additionally, the influence of the fuel price and equipment investment cost of the thermo-economic cost for each product was studied. The results showed that the main factors affecting the unit cost are the fuel exergy cost, component exergy efficiency, and irreversible exergy cost of each unit, and the main factors affecting the thermo-economics cost are the specific irreversible exergy cost and investment exergy cost. The main factors affecting the thermal economics of solar energy collectors and low-pressure economizers are the invested exergy cost, negentropy exergy cost, and irreversible exergy cost of each unit.

Keywords: structural theory; carbon capture; flue gas heat; parabolic trough collector field; exergetic cost; thermo-economic cost

1. Introduction

Climatic change resulting from greenhouse gases has become the most serious air pollution problem facing humanity at present [1]. The flue gas emissions from coal-fired power plants represent the largest CO_2 emission contributor, and the trend will continue in the foreseeable future [2]. Considering this, CO_2 capture and storage (CCS), resource utilization of CO_2 , and renewable energy, as three measures that appeared successively, remain the Gordian techniques for rapidly and effectively reducing CO_2 emissions. According to the prediction of the Global CCS Institute in 2018 [3], a 14% cumulative CO_2 emissions reduction must be achieved in order to reach the Paris target by 2060 [4].

The widespread use of renewable energy is deemed an effective way of reducing CO_2 emissions. As renewable energy, solar energy has a wide range of applications at home and abroad in many fields [5]. However, carbon capture is deemed the most immediate way of decreasing CO_2 emissions. Post-combustion CO_2 capture (PCC), oxygen-enriched combustion, and chemical looping combustion are prospective technologies which can be applied to active coal-fired power plants [6]. However, the



high energy consumption of carbon capture desorption impedes the development of post-combustion CO_2 capture. In the case of solvent absorption, thermal energy consumption (3.11–4.0 MJ/kgCO₂) is required for reboiler heat duty [7]. To this end, it is very important to explore a low-carbon economy-energy-saving emission reduction road. Controlling the emissions of carbon dioxide and nitrogen oxides from fossil fuel power plants is an important way of reducing greenhouse gas emissions in the environment. On the basis of coal-fired units, the rational integration of solar thermal utilization systems to form an integrated system of pollutant emission reduction for solar-assisted coal-fired units is an effective way of achieving energy conservation and emission reduction.

In recent years, many scholars have conducted research on the hybrid power generation technology of the solar generation system, CO_2 capture, and fossil fuel units [8]. To make post-combustion CO_2 capture (PCC) more suitable for coal-fired power plants, growing interest has been directed to the flexible operation of PCC [9]. The resource utilization of captured CO_2 as a carbon source for the production of energy storage media offers a technological solution for overcoming CO_2 emissions [10]. Beatrice Castellani [11] aimed to assess the carbon and energy footprint of an innovative process for carbon dioxide recycling. A techno-economic study of the proposed system, which integrated solar energy into an 800 MW coal-fired power plant, was conducted [12]. A novel solar tower-aided coal-fired power plant has also been proposed, in which solar energy is used to reheat exhaust steam from an immediate turbine to improve the operating parameter of the regenerative cycle [13].

Research on synthetic oil heated by solar energy, steam extraction, gas turbines, and so on, as the heat source of the carbon dioxide capture system, has been conducted [14,15]. Most of these studies have focused on case analysis, conventional economic evaluation, and feasibility analysis. Additionally, several solutions have been studied in an attempt to decrease the energy penalty of solar-aided CO₂ desorption capture from coal-fired power plants. The idea of solar-aided desorption for carbon capture first appeared in Australia [16]. The systemic structure, feature, and energy-efficiency performance for the integrated system of solar-aided power plants have been proposed, and life cycle theory has been used to analyze solar-aided power plants for carbon desorption processes, including life cycle assessment and cost analysis [5].

However, the study of integrated systems lacks theoretical research at the system level. To this end, according to the energy consumption characteristics of carbon capture and the energy consumption of the liquid ammonia evaporator in the denitrification system, this study proposes integrating the flue gas waste heat and solar heat into the thermal system of the coal-fired unit, with the aim of comprehensively seeking the feasibility of integrating the solar-aided CO_2 desorption with the coupling system regarding the thermo-economic cost performances of the presented system. Firstly, a process description of the proposed system is presented from a thermo-economic perspective. Specifically, in order to analyze the system performance more clearly, the physical structure and productive structure of the solar-aided coal-fired power plant are presented. We provide a new method for calculating the performance of the main equipment based on structural theory. We also use the exergy cost to evaluate the production performance of the entire system and main equipment, and quantitatively study and analyze the main reasons leading to the increase in the production cost of the coupling system. In addition, based on the thermo-economic model, the change law of the unit thermo-economic cost of the product is analyzed.

2. Methods and Models

2.1. Pollutant Emission Reduction Method of a Solar Auxiliary Coal-Fired Unit

The parabolic trough solar collector is one of the solar collectors with a medium temperature. All of the solar thermal generation systems operated commercially in America and Europe apply this technology. Currently, many research institutes are trying to find a way to combine this technology with fossil fuel power plants. When water is used as a medium which is heated by the direct steam generation (DSG) solar trough collector integrated with the coal-fired unit, there is not only energy transfer, but also the exchange of substances between the two systems. When the flue gas waste heat and the DSG solar collector provide the heat source for the post-combustion carbon capture system, and the unit steam extraction provides the heat source for the liquid ammonia evaporator in the denitration system, the matching of the material flow and energy flow needs to be considered; that is, a certain amount of water is drawn from a certain part of the thermal system to be heated by the flue gas waste heat system and the solar heat collection system, which provides a heat source for the carbon capture system.

In this paper, the N600-24.2/566/566-type generator set is taken as the research object, according to the calculated acid dew point temperature, the low-pressure economizer is used to heat the No. 3 low-pressure heater (3DJ) to draw the working fluid [17–19], and the solar heat is then collected by the DSG parabolic trough collector [20]. Furthermore, condensed water is heated to the conditions required for regeneration of the amine-based catalyst and then introduced into the reboiler as a heat source for regeneration of the desorbent solution in the carbon dioxide capture system, using its latent heat of vaporization to provide the reboiler solvent regeneration requirements. At the same time, steam extraction of the unit is used to provide a heat source for the liquid ammonia evaporator in the denitration system. In view of the unbalanced solar radiation, in order to ensure that the solar-assisted coal-fired system can produce a balanced amount of heat required for desorbent regeneration, heat storage needs to be installed in the system. Considering the parameter matching, the water returned after heating the reboiler is introduced into the inlet of the No. 5 heater. The integration scheme is shown in Figure 1.



Figure 1. Integration mode of low pressure economizer system and the solar collector field connected in parallel with heater. 1, No. 4 low-pressure heater; 2, No. 3 low-pressure heater; 3, No. 2 low-pressure heater; 4, No. 1 low-pressure heater; 5, low-pressure economizer system; 6, solar collector field; 7, carbon dioxide capture system; 8, deaerator; 9, steam feed pump; 10, No. 3 high-pressure heater; 11, No. 2 high-pressure heater; 12, No. 1 high-pressure heater; 13, superheater; 14, high-pressure cylinder; 15, intermediate-pressure cylinder; 16, low-pressure cylinder; 17, generator; 18, condenser; 19, condensate pump; 20, seal heater; 21, steam turbine; 22, denitration system.

2.2. The Model of Structural Theory for the Integration System

In general, the "fuel-product" is used to define the input and output of components in thermo-economics. The input and output of the integration system are analyzed according to

the physical structure, including the physical structure and production structure. Among them, the physical structure reflects the physical association between equipment components, and the production structure reflects the production relationship of the system. In order to clarify the input and output of each component, it is necessary to divide the physical structure of the thermal system and determine the "fuel" and "product" of each component [19,20].

2.2.1. Physical Structure

According to the function of each device, the integrated system is divided into the physical structure shown in Figure 2. According to the arrangement of the steam extraction ports, the steam turbines are divided as follows: The regulating stage serves as a component, and the remaining steam extraction ports and steam extraction ports form a component. The steam leakage and shaft seal systems are grouped into the corresponding steam turbine stage group; each device of the regenerative system is used as a component; the shaft seal heater and the adjacent low-pressure heater are combined into a component; the boiler is divided into a superheater component (13) and a reheater component (17); and the steam turbine (25), condensate pump (28), solar collector field (5), carbon dioxide capture system (6), denitration system (26), and low-pressure economizer system (4) are considered to be components, respectively.



Figure 2. Physical structure of the integration system. 1, No. 4 low-pressure heater; 2, No. 3 low-pressure heater; 3, No. 2 low-pressure heater; 4, low-pressure economizer system; 5, solar collector field; 6, carbon dioxide capture system; 7, No. 1 low-pressure heater; 8, deaerator; 9, steam feed pump; 10, No. 3 high-pressure heater; 11, No. 2 high-pressure heater; 12, No. 1 high-pressure heater; 13, superheater; 14, No. 1 high-pressure cylinder; 15, No. 2 high-pressure cylinder; 16, No. 3 high-pressure cylinder; 17, reheater; 18, No. 1 intermediate-pressure cylinder; 19, No. 2 intermediate-pressure cylinder; 20, No. 1 low-pressure cylinder; 21, No. 2 low-pressure cylinder; 22, No. 3 low-pressure cylinder; 23, No. 4 low-pressure cylinder; 24, No. 5 low-pressure cylinder; 25, steam turbine; 26, denitration system; 27, condenser; 28, condensate pump; 29, generator.

2.2.2. Production Structure

In this study, the "fuel-product" is used to define the production purpose of each piece of equipment. The product (P) is the purpose of the component which is quantified by exergy and the fuel (FB) is the exergy consumption. According to the function of the production equipment in the overall situation, the actual flow of the input and output of each piece of equipment is decomposed or combined to obtain multiple fuel flows and product flows. In this way, the physical structure diagram of the actual system can be converted into a production structure diagram represented by the "fuel-product", as shown in Figure 3. In Figure 3, rectangles represent physical components, diamonds

represent influx components, and circles represent branch components. The arrows F, P, and N of every physical component represent the fuel consumption, the product, and the negentropy consumption, respectively. In the influx or branch components, the inlet and outlet of the exergy or negentropy remain balanced.



Figure 3. Productive structure of the integration system.

The production structure diagram is a graphical representation of the production relationship of the integrated system, which intuitively reflects the production relationship in the power plant. The product P of each component is collected by the influx component J, and then redistributed to other components through the branch component B. When the investment cost of equipment (external resources) is taken into account, it can be directly input into the corresponding component, and the mathematical Equation (1) of the thermo-economics model can be obtained according to the production structure diagram.

$$B_i = g_i(B_j, x_l) \qquad \qquad i = 1, \cdots, m \tag{1}$$

where B_i is the inlet flow of each component, x_i is the internal parameter set of the component, B_j is the output stream of the component, m is the number of components in the production structure, and G_i () is the function between B_i and B_j and x_i of the *i* component. Every input and output flow in the production system is always represented by exergy, negentropy, cash, enthalpy, or entropy. The internal parameter set x_l is usually represented by pressure, temperature, efficiency, and so on.

Setting up a model based on thermo-economics usually requires the thermo-economics model to be defined with a linear equation. When the characteristic equation is a homogeneous first-order equation on subset B_{j} , according to Euler theorem, Equation (1) can be represented as

$$B_i = \sum_{j=1}^n \left(\frac{\partial g_i}{\partial B_j} \times B_j\right) = \sum_{j=1}^n k_{ij} B_j$$
(2)

where n is the number of input flows and k_{ij} is the technical product coefficient, which represents the proportion of product consumed from component i when the unit product is produced by component

j. The $n \times n$ dimensional matrix $\langle KP \rangle$ composed of k_{ij} is the unit exergy consumption matrix, which reflects the distribution of the fuel and product in the structure.

2.2.3. Characteristic Equation

Generally, three types of characteristic models are included in the thermo-economics model: Characteristic equations for production and dissipation components, structural equations for aggregate and branch components, and cost calculation equations. The sum of k_{ij} , which is the technical production coefficient of a component, is the unit exergy consumption of this component, and can be calculated by Equation (3).

$$k_j = \sum_{i=0}^n k_{ij} = \sum_{i=0}^n F_i / P_j = F_j / P_j$$
(3)

where *P* is the product, kw; *F* is the fuel, kw; and *i* and *j* represent the *i*-th component and the *j*-th component, respectively.

The characteristic equation of the production and dissipative component is calculated by Equation (4), which reflects the relationship between production functions P_i and the fuel F_i of the *i*-th component with unit exergy efficiency (k_i).

$$F_i = k_i P_i \tag{4}$$

The structural equation is composed of the aggregate component Equation (5) and the branch component Equation (6).

$$F_i = r_{ij} P_j \tag{5}$$

where r_{ij} represents the efficiency and p_j is the product of the *j*-th aggregated component.

$$F_j = \sum_{i=0}^m P_i \tag{6}$$

where F_j represents the fuel of the *j*-th branch assembly.

2.2.4. Exergy Cost Equation

The exergy cost is defined as the amount of exergy required to generate exergy flow in the system. The unit cost refers to the amount of energy consumed per unit of stream produced, and its dimension is the ratio of exergy to exergy, which is denoted as k^* . The unit exergy cost includes the exergy cost of unit product k_p^* , exergy cost of unit fuel k_{FB}^* , and unit negentropy exergy cost k_{FS}^* . Figure 4 shows the structural diagram of an energy system.



Figure 4. Structural diagram of an energy system.

In Figure 4, FB_m is the fuel input of a system, kW; FS_s is the negentropy input of a system, kW; Z is the non-energy cost input of a system; and FB_m , FS_s , Z, and P represent the fuel input of the system, the

negentropy, the non-energy input, and the product, respectively. The exergy cost equation of the above system is calculated by Equation (7), and the unit exergy cost equation is calculated by Equation (8).

$$k_{P}^{*} \cdot P = \sum_{i=1}^{m} k_{FB,i}^{*} \cdot FB_{i} + \sum_{i=1}^{s} k_{FS,i}^{*} \cdot FS_{i}$$
(7)

$$k_{P,i}^{*} = \sum_{i=1}^{m} k_{FB,i}^{*} \cdot \frac{FB_{i}}{P} + \sum_{i=1}^{s} k_{FS,i}^{*} \cdot \frac{FS_{i}}{P} = \sum_{i=1}^{m} k_{FB,i}^{*} \cdot kB_{i} + \sum_{i=1}^{s} k_{FS,i}^{*} \cdot kS_{i} = (1+kI_{i}) \cdot k_{FB,i}^{*} + kS_{i} \cdot k_{FS,i}^{*} = k_{FB,i}^{*} + kI_{i} \cdot k_{FB,i}^{*} + kS_{i} \cdot k_{FS,i}^{*}$$
(8)

There are multiple exergy flows transferring between systems or components. Therefore, the calculation equation of the unit product exergy cost is

$$k_{P,i}^* = k_{0,i} + \sum_{j=1}^n k_{ji} \cdot k_{P,j}^* \, i = 1, 2, \dots, n.$$
(9)

The cost equation expresses the investment cost of the system as a thermodynamic variable and a functional form of the component product. The unit thermo-economics cost *cp* of the product belongs to the economic dimension, and its calculation method is Equation (10).

$$\left(U - \langle KP \rangle^t\right) c_P = \left(c_e + kZ\right) \tag{10}$$

In Equation (10), *U* is a 29 × 29-dimension unit diagonal matrix, $\langle KP \rangle^t$ is the 29 × 29 dimension transpose matrix of the unit exergy cost, c_e is the product vector (10⁻⁶ ¥/kJ) of the unit price c_{Fuel} and $k_{0,i}$, c_{Fuel} is equal to the ratio of the coal-fired price to coal-fired calorific value, and $k_{0,i}$ represents the unit exergy cost of the components by directly obtaining fuel from the environment. kZ is the vector of cost capital (¥/kJ), which reflects the external investment and other costs needed by the components. Therefore, Equation (10) can be further divided as follows:

$$c_{pi} = kB_i \cdot c_{FB,i} + kS_i \cdot c_{FS,i} + kZ_i = c_{FB,i} + kI_i \cdot c_{FB,i} + kS_i \cdot c_{FS,i} + kZ_i.$$
(11)

3. The Results and Discussion

By applying the structural theory of thermo-economics in the integration system, the formation and distribution of the generation cost can be analyzed in the carbon capture system of a power plant, and the internal reasons of the generation cost increase can be revealed. Table 1 shows the unit cost of each component (product cost, negative entropy cost, fuel cost, etc.) of the solar-assisted coal-fired unit pollutant emission reduction thermal system under turbine heat acceptance (THA) conditions. The condenser is a dissipation device and is used to reduce the increase of entropy produced by the irreversibility in the thermodynamic cycle, so the work substance can return to the initial state of the thermodynamic cycles. The reduction of entropy means the production of negentropy. Some scholars [21–24] regard negentropy as the product of the condenser. In thermal economics, it means that the fuel consumption allocates the fuel resources consumed by the waste heat discharge of the condenser to each piece of equipment according to the irreversible degree of each piece of equipment, as the additional fuel consumed by each piece of equipment due to the irreversible entropy increase. In the integrated system, since the functions of the reboiler and the evaporator are similar to the condenser, the negative entropy generated by it will be distributed as a product to each piece of production equipment in the production system. Therefore, in the entire system, except for the condenser, reboiler, evaporator, and generator, all equipment consumes negative entropy.

C _{ar}	Har	O _{ar}	Nar	Sar
60.40	2.89	3.07	0.87	0.68

Table 1. Composition of the coal.

Here, Car, Har, Oar, Nar, and Sar represent carbon, hydrogen, oxygen, nitrogen, and sulfur in the fuel, as received (%).

The system in Figure 1 was studied and the composition of the coal is shown in Table 1. In addition, the chemical exergy of the coal was 24,209.82 kJ/kg [25], and the radiation exergy model of solar thermal power generation was calculated [26,27]. The expression applies in the case of fully concentrated solar radiation and blackbody absorbers. If solar collectors consider a small concentration ratio and their absorbers are not blackbody, but selective, exergy factors refer to other literature [28].

According to the equation of the exergy cost, the unit product exergy cost is composed of the fuel exergy cost, irreversibility exergy cost, and negentropy exergy cost. It can be seen from Table 2 that the product exergy cost, negative entropy cost, and fuel exergy cost in the integrated system are higher than those in the original system. This is due to the low efficiency of the solar heat collecting field and the increased consumption of the integrated system.

There is a different unit fuel exergy $\cos t k_{FB}^*$ in the irreversibility produced by different equipment in the original system and integration system. When the product is determined, the k_{FB}^* equals the irreversible unit exergy cost. The unit product exergy cost and unit fuel exergy cost have a decreasing trend along the direction of the thermodynamic cycle. Specifically, for the feedwater heater system components, k_P^* gradually decreases from the low-pressure heater to the high-pressure heater, reaching a minimum value at 1 GJ. The original system and the integrated system are 2.178 and 2.631 kw/kw, respectively. For the steam turbine stage group, the exergy costs of the high-pressure cylinder adjustment stage group HP1 and the low-pressure cylinder final stage group LP5 are larger than other stage groups. The main reason for this is that the HP1 has a larger steam loss, and the LP5 wet steam loss is greater. The unit cost k*P of the generator (GEN) in the integrated system is relatively high, equaling 2.764 kw/kw, mainly due to the higher unit cost of fuel. The unit product exergy cost of superheater assembly (B-SH) and reheater assembly(RH) is much higher than their unit fuel exergy cost, because of the irreversible loss in the boiler.

The unit product exergy cost of the low-pressure economizer is the highest (5.795 kw/kw). The reason for this is that the exergy loss of the low-pressure economizer is high and the exergy efficiency is low. The unit product exergy cost of solar collector field (SF) is 4.538 kw/kw. This is mainly because of the high exergy loss and the low exergy efficiency. The exergy efficiency of the solar collector field is low, and it consumes so much solar exergy to heat the condensate water that the unit exergy costs of most of the components in the integration system are higher than those of the original system. The reason for the increasing exergy cost of No. 4 low-pressure heater (4DJ), B-SH, RH, Small steam turbine(BFPT), reboiler (RB) and denitration system (SG) is mainly the high specific irreversible exergy cost and high specific negentropy cost. Moreover, the increase of the exergy cost caused by specific negentropy is much lower than that caused by specific irreversibility. The specific irreversible exergy cost of 4DJ is the highest among all heaters. This is mainly because of the increase of internal exergy loss caused by heat exchange at a low temperature. The fuel exergy cost of SF and LPE is 0, which is due to the zero consumption of fossil fuel. The increase in cost due to the negative entropy of condenser (CND), GEN, RB, and SG is zero, mainly because CND is a condenser component, and GEN, RB, and SG are similar condenser components, which do not consume negative entropy. Furthermore, the reason for the higher cost of other component products is the higher cost of fuel consumed.

The unit exergy cost reflects the structure of the energy cost. However, it cannot precisely reflect the effect of the energy price, equipment investment, and other non-energy costs. In order to precisely reflect the unit thermo-economic cost, the elements, including the impact of the energy price, equipment investment, and other non-energy costs, must be considered. It can be seen from Equation (11) that the thermo-economic cost of the system is composed of the fuel unit thermo-economic cost, unit thermo-economic cost caused by irreversibility, unit thermo-economic cost caused by the consumption of negentropy, and investment thermo-economic cost. Table 3 reflects the thermo-economic cost and its distribution law of the original system and integration system, without considering the investment cost.

Serial Number	Component	Product Exergy Cost		Fuel Exergy Cost		Specific Irreversible Exergy Cost		Specific Negentropy Exergy Cost	
		Original System	Integration System	Original System	Integration System	Original System	Integration System	Original System	Integration System
1	4DJ	3.196	3.931	2.086	2.524	1.026	1.153	0.084	0.254
2	3DJ	2.477	2.976	2.086	2.524	0.373	0.402	0.017	0.049
3	2DJ	2.381	2.717	2.086	2.524	0.282	0.079	0.013	0.113
4	LPE	-	5.795	-	1	-	3.596	-	1.199
5	SF	-	4.538	-	1	-	2.651	-	0.886
6	RB	-	0.952	-	2.524	-	0.952	-	-
7	1DJ	2.354	2.865	2.086	2.524	0.256	0.23	0.012	0.11
8	DTR	2.284	3.073	2.086	2.524	0.151	0.486	0.047	0.062
9	FWP	2.943	3.712	2.728	3.626	0.2	0.075	0.015	0.011
10	3GJ	2.329	2.791	2.086	2.524	0.231	0.236	0.011	0.031
11	2GJ	2.214	2.679	2.086	2.524	0.122	0.137	0.006	0.018
12	1GJ	2.178	2.631	2.086	2.524	0.087	0.094	0.004	0.012
13	B-SH	2.022	2.204	1	1	0.941	0.94	0.081	0.264
14	HP1	2.535	2.984	2.086	2.524	0.427	0.406	0.021	0.054
15	HP2	2.185	2.665	2.086	2.524	0.094	0.124	0.005	0.016
16	HP3	2.195	2.681	2.086	2.524	0.104	0.139	0.005	0.018
17	RH	2.015	2.109	1	1	0.934	0.868	0.081	0.242
18	IP1	2.185	2.678	2.086	2.524	0.095	0.135	0.005	0.018
19	IP2	2.143	2.606	2.086	2.524	0.054	0.072	0.003	0.01
20	LP1	2.176	2.648	2.086	2.524	0.086	0.109	0.004	0.014
21	LP2	2.145	2.6	2.086	2.524	0.056	0.067	0.003	0.009
22	LP3	2.144	2.615	2.086	2.524	0.055	0.08	0.003	0.011
23	LP4	2.174	2.633	2.086	2.524	0.084	0.096	0.004	0.013
24	LP5	2.445	2.994	2.086	2.524	0.342	0.414	0.017	0.055
25	BFPT	2.728	3.626	2.086	2.524	0.611	0.973	0.03	0.129
26	SG	-	1.263	-	2.524	-	1.263	-	-
27	CND	0.103	0.108	2.086	2.129	0.102	0.104	0	0
28	СР	2.892	3.577	2.27	2.764	0.595	0.725	0.027	0.088
29	GEN	2.27	2.764	2.225	2.709	0.045	0.055	0	0

Table 2. Unit exergy costs of the integration system and original system.

It can be seen from Table 3 that the unit product thermo-economic cost of the components in the integration system is lower than that in the original system. The reason for this is that the exergy cost consumption of the solar collector field in the integration system is 0, which reduces the energy cost. The unit product thermo-economic cost of the low-pressure economizer and solar collector field equals their negentropy thermo-economic cost, without considering the investment cost.

Serial Number	Component	Product Unit Thermo-Economic Cost		Fuel Unit Thermo-Economic Cost'		Increase of the Thermo-Economic Cost Caused by Irreversibilities		Increase of the Thermo-Economic CostCased by Negentropy	
		Original System	Integration System	Original System	Integration System	Original System	Integration System	Original System	Integration System
1	4DJ	97.179	96.435	63.428	61.931	31.197	28.275	2.554	6.23
2	3DJ	75.305	72.998	63.428	61.931	11.351	9.855	0.526	1.212
3	2DJ	72.38	66.66	63.428	61.931	8.559	1.947	0.394	2.782
4	LPE	-	29.404	-	0	-	0	-	29.404
5	SF	-	21.746	-	0	-	0	-	21.746
6	RB	-	85.282	-	61.931	-	23.351	-	-
7	1DJ	71.576	70.28	63.428	61.931	7.787	5.642	0.361	2.707
8	DTR	69.441	75.383	63.428	61.931	4.587	11.927	1.426	1.525
9	FWP	89.487	91.066	82.938	88.959	6.092	1.842	0.457	0.265
10	3GJ	70.813	68.478	63.428	61.931	7.038	5.781	0.347	0.766
11	2GJ	67.32	65.735	63.428	61.931	3.71	3.359	0.183	0.445
12	1GJ	66.207	64.552	63.428	61.931	2.649	2.315	0.131	0.307
13	B-SH	61.49	65.447	30.404	30.404	28.61	28.572	2.475	6.471
14	HP1	77.061	73.214	63.428	61.931	12.992	9.964	0.642	1.32
15	HP2	66.421	65.37	63.428	61.931	2.852	3.037	0.141	0.402
16	HP3	66.743	65.78	63.428	61.931	3.159	3.399	0.156	0.45
17	RH	61.264	62.712	30.404	30.404	28.404	26.381	2.456	5.926
18	IP1	66.445	65.687	63.428	61.931	2.876	3.317	0.142	0.439
19	IP2	65.148	63.924	63.428	61.931	1.64	1.76	0.081	0.233
20	LP1	66.172	64.952	63.428	61.931	2.615	2.668	0.129	0.353
21	LP2	65.203	63.781	63.428	61.931	1.692	1.634	0.084	0.216
22	LP3	65.184	64.156	63.428	61.931	1.674	1.965	0.083	0.26
23	LP4	66.113	64.589	63.428	61.931	2.559	2.347	0.126	0.311
24	LP5	74.343	73.444	63.428	61.931	10.402	10.167	0.514	1.346
25	BFPT	82.938	88.959	63.428	61.931	18.592	23.867	0.918	3.161
26	SG	-	30.973	-	61.931	-	30.973	-	0
27	CND	3.132	2.646	63.428	61.931	3.098	3.025	-	0
28	СР	87.938	87.73	69.023	67.806	18.093	17.774	0.821	2.15
29	GEN	69.023	67.806	67.65	66.456	1.374	1.349	0	0

Table 3. Structure of the thermo-economic cost (without considering the investment costs).

When the investment cost is considered, the thermo-economic cost of the system is composed of the unit fuel exergy cost, the thermo-economic cost caused by irreversibility, and the thermo-economic cost caused by the consumption of negentropy. The installation and acquisition cost is included in the investment cost and the construction cost of other equipment is not considered [19,29–31]. When the radiant intensity is 800 W/m², the solar collector field can be calculated according to its area. The composition of the unit thermo-economic cost and its distribution law in the original system and the integration system considering the investment cost are shown in Table 4.

It can be seen from Table 4 that the product thermo-economic cost of the components in the integration system is higher than that in the original system. The reason for this is that the investment costs of the solar collector field, CO₂ removal system, low-pressure economizer, and denitration system increase the cost. It can also be seen from Table 4 that the cost increase caused by the irreversible ratio of components such as 4DJ, B-SH, RH, LPE, SF, RB, and SG accounts for the largest proportion of the unit thermo-economic cost, because these components display relatively big irreversible losses. The unit product thermo-economic cost of the low-pressure economizer and solar collector field is composed of the thermo-economic cost caused by irreversibility and the consumption of negentropy. Their fuel exergy cost is 0. The large irreversible loss and large negative entropy consumption of the low-pressure economizer and heat collector field are mainly caused by the low efficiency of the heat collector field. The unit product thermal economic cost caused by the investment cost of the liquid ammonia evaporator in the denitration system is very high, mainly because the investment cost of the denitration system is large and the product negative entropy is small.

11	of	14

Serial Number	Component	Product Unit Thermo-Economic Cost t		Fuel Unit Thermo-Economic Cost'		Increase of the Thermo-Economic Cost Caused by Irreversibilities		Increase of the Thermo-Economic Cost Cased by Negentropy	
		Original System	Integration System	Original System	Integration System	Original System	Integration System	Original System	Integration System
1	4DJ	211.383	278.481	101.198	136.918	49.775	62.512	5.999	27.927
2	3DJ	148.653	191.59	101.198	136.918	18.111	21.789	1.236	5.435
3	2DJ	140.66	193.79	101.198	136.918	13.656	4.305	0.925	12.472
4	LPE	-	155.11	-	0	-	0	-	131.814
5	SF	-	232.249	-	0	-	0	-	97.485
6	RB	-	105.131	-	136.918	-	51.625	-	0
7	1DJ	135.977	185.402	101.198	136.918	12.424	12.473	0.848	12.137
8	DTR	124.902	183.184	101.198	136.918	7.318	26.369	3.349	6.838
9	FWP	188.473	256.887	156.599	230.329	11.503	4.769	1.074	1.189
10	3GJ	126.1	165.552	101.198	136.918	11.229	12.782	0.816	3.432
11	2GJ	119.104	157.721	101.198	136.918	5.919	7.427	0.43	1.994
12	1GJ	117.333	154.818	101.198	136.918	4.226	5.117	0.307	1.374
13	B-SH	96.34	119.613	30.404	30.404	28.61	28.572	5.813	29.01
14	HP1	142.51	182.477	101.198	136.918	20.729	22.028	1.507	5.915
15	HP2	119.981	159.486	101.198	136.918	4.551	6.715	0.331	1.803
16	HP3	125.221	165.277	101.198	136.918	5.04	7.514	0.366	2.018
17	RH	82.673	100.883	30.404	30.404	28.404	26.381	5.767	26.567
18	IP1	121.429	157.37	101.198	136.918	4.588	7.333	0.334	1.969
19	IP2	119.431	158.416	101.198	136.918	2.616	3.891	0.19	1.045
20	LP1	120.629	160.697	101.198	136.918	4.172	5.899	0.303	1.584
21	LP2	122.872	162.492	101.198	136.918	2.699	3.613	0.196	0.97
22	LP3	123.2	162.482	101.198	136.918	2.67	4.345	0.194	1.167
23	LP4	125.013	162.98	101.198	136.918	4.084	5.189	0.297	1.394
24	LP5	134.825	181.248	101.198	136.918	16.596	22.477	1.207	6.036
25	BFPT	156.599	230.329	101.198	136.918	29.663	52.766	2.156	14.17
26	SG	-	16180.037	-	136.918	-	68.477	-	0
27	CND	7.357	8.12	101.198	136.918	4.943	6.688	0	0
28	СР	178.603	237.517	129.17	169.641	33.86	44.468	1.929	9.638
29	GEN	129.17	169.641	124.323	164.035	2.524	3.331	0	0

Table 4. Structure of the thermo-economic cost (considering the investment costs).

Solar radiation is changing at any time, so in the integrated system of the carbon dioxide emission reduction of solar-assisted coal-fired power generation, there are many optional solar radiation design intensities. Different radiation intensities not only affect the thermal economy of the unit, but also have a certain impact on the technical economy. As a result, the efficiency of the collector will change, and the heat released by the solar collector will also change. When the radiant intensity changes, the storage device or the 5 section extraction steam will be used as the heat source of the carbon emission reduction system and will provide the heat needed by the regeneration of the desorbent. The efficiency and area of the solar collector field can be calculated according to the radiation intensity. When the energy produced by the solar collector is certain and the radiant intensity is changing, the relationship between the efficiency and area is as shown in Figure 5. It can be seen from Figure 5 that the efficiency of solar collectors has an increasing trend with an increasing radiation intensity. The area of the solar collector field is closely related to the heat release and the efficiency. When the heat release is certain, the area of the collector field decreases with the increase of the radiation intensity. For the radiation distribution of a certain area, if a high radiation intensity is selected, the area of the solar collector field can be reduced, but if the solar radiation intensity in this area is always lower than the design value, the collector is in a low-load operating state, which reduces the thermal efficiency. If the actual radiation intensity is greater than this design value, the collector field will be operated under the rated working conditions. According to the designed heat storage device, the excess heat generated can be saved by the heat storage device. When the radiation intensity is zero, and the heat storage device has no stored heat, the standby steam source is activated to provide regenerative heat.



Figure 5. Variation curves of the collector efficiency and collector area vs. solar irradiance.

The increase in energy consumption and investment costs raises the cost of generating electricity for the pollutant emission reduction system of solar-assisted coal-fired units, and it also highlights the economic obstacles to the reduction of pollutant emissions of solar-powered coal-fired units. However, if taxes are imposed on CO_2 emissions and the CO_2 product is sold, the integrated system is expected to break through economic obstacles and achieve massive CO_2 emission reductions. Considering the environmental impact, CO_2 removal is necessary and beneficial. Therefore, the integrated system is not only environmentally friendly, but also has high economic competitiveness.

4. Conclusions

In this present paper, an integrated system combining fuel gas and solar-aided CO_2 desorption with a 600 MW coal-fired power plant is proposed and studied. The information provided by the conventional thermodynamic methods to evaluate the production performance of the system and devices has proved to be insufficient, and only considers the thermal performance evaluation of the system, while neglecting the cost factors. In this paper, the cost analysis method based on the structural theory of thermo-economics is applied to the integrated system. The thermo-economic model and the exergy cost model for the integrated system based on the fuel-product concept have been defined to quantify the productive interaction between different devices. The physical structure sketch and the productive structure sketch were drawn and a thermo-economic model and a cost model based on the definition of the fuel-product were established. The production relation between units was analyzed, and the composition and distribution of the exergy cost and thermo-economic cost of each unit were studied. The influence of the fuel price and equipment investment cost of the thermo-economic cost for each product was studied. According to the presented results, several conclusions can be drawn, as follows:

- The insufficiency of the traditional thermodynamics analysis is compensated for by the structural theory of thermo-economics. The information of the cost structure and energy transformation of the relevant equipment can be analyzed based on this theory;
- (2) The unit exergy cost and its distribution law in every component in the integration system and the original system are calculated based on the structural theory. The high exergy cost of the components in the integration system is mainly due to the increase of the irreversible exergy cost. The unit exergy cost of the component is impacted by the exergy efficiency and fuel exergy cost of the component. The unit exergy cost can be reduced by increasing the exergy efficiency of the boiler and solar collector field;

(3) The composition and distribution law of the unit product thermo-economic cost of the integration system and the original system is analyzed based on the equation of the thermo-economic cost. The influence of the fuel price and equipment investment on the product thermo-economic cost of every component is studied.

Author Contributions: Conceptualization, X.Y.; Data curation, W.L., X.M. and Y.G.; Methodology, Z.Y.; Project administration, J.W.; Writing—review & editing, X.L. and Y.B. All authors have read and agreed to the published version of the manuscript.

Funding: This research was funded by Natural Science Foundation of Hebei Province of China grant number [E2017402084]; Key Science and Technology Program of Hebei Province of China grant number [E2017402084]; and Research Foundation of Education Bureau of Hebei Province of China grant number [ZD2020182].

Conflicts of Interest: The authors declare no conflict of interest.

References

- 1. EU. Global and European Sea-Level Rise. Available online: http://www.eea.europa.eu/data-and-maps/ indicators/sea-level-rise-2/assessment (accessed on 18 May 2018).
- 2. IEA. *Electricity Information* 2017; IEA Publications: Paris, France, 2017. Available online: https://euagenda.eu/ publications/electricity-information-2017 (accessed on 18 May 2018).
- 3. Global CCS Institute. The Global Status of CCS: 2018, GCCSI, Oct. 2018. Available online: https://www.globalccsinstitute.com/resources/global-status-report/ (accessed on 18 May 2018).
- 4. UNFCCC. Historic Paris Agreement on Climate Change. Available online: http://newsroom.unfccc.int/ unfccc-newsroom/finale-cop21/ (accessed on 18 May 2018).
- 5. Zhao, R.; Deng, S.; Zhao, L.; Liu, Y.; Tan, Y. Energy-saving pathway exploration of CCS integrated with solar energy: Literature research and comparative analysis. *Energy Convers. Manag.* **2015**, *102*, 66–80. [CrossRef]
- Petrescu, L.; Bonalumi, D.; Valenti, G.; Cormos, A.-M.; Cormos, C.-C. Life Cycle Assessment for supercritical pulverized coal power plants with post-combustion carbon capture and storage. *J. Clean. Prod.* 2017, 157, 10–21. [CrossRef]
- Lindqvist, K.; Jordal, K.; Haugen, G.; Hoff, K.A.; Anantharaman, R. Integration aspects of reactive absorption for post-combustion CO 2 capture from NGCC (natural gas combined cycle) power plants. *Energy* 2014, 78, 758–767. [CrossRef]
- 8. Bai, Z.; Liu, Q.; Lei, J.; Jin, H. Investigation on the mid-temperature solar thermochemical power generation system with methanol decomposition. *Appl. Energy* **2018**, 217, 56–65. [CrossRef]
- 9. Wu, X.; Wang, M.; Liao, P.; Shen, J.; Li, Y. Solvent-based post-combustion COpost>2 capture for power plants: A critical review and perspective on dynamic modelling, system identification, process control and flexible operation. *Appl. Energy* **2020**, 257, 113941. [CrossRef]
- Castellani, B.; Gambelli, A.M.; Morini, E.; Nastasi, B.; Presciutti, A.; Filipponi, M.; Nicolini, A.; Rossi, F. Experimental investigation on CO₂ methanation process for solar energy storage compared to co2-based methanol synthesis. *Energies* 2017, *10*, 855. [CrossRef]
- Castellani, B.; Rinaldi, S.; Morini, E.; Nastasi, B.; Rossi, F. Flue gas treatment by power-to-gas integration for methane and ammonia synthesis–Energy and environmental analysis. *Energy Convers. Manag.* 2018, 171, 626–634. [CrossRef]
- 12. Zhao, R.; Liu, L.; Zhao, L.; Deng, S.; Li, S.; Zhang, Y.; Li, H. Techno-economic analysis of carbon capture from a coal-fired power plant integrating solar-assisted pressure-temperature swing adsorption (PTSA). *J. Clean. Prod.* **2019**, *214*, 440–451. [CrossRef]
- 13. Li, C.; Zhai, R.; Zhang, B.; Chen, W. Thermodynamic performance of a novel solar tower aided coal-fired power system. *Appl. Therm. Eng.* **2020**, *171*, 115–127. [CrossRef]
- 14. Wang, C.; He, B.; Sun, S.; Wu, Y.; Yan, N.; Yan, L.; Pei, X. Application of a low pressure economizer for waste heat recovery from the exhaust flue gas in a 600 MW power plant. *Energy* **2012**, *48*, 196–202. [CrossRef]
- 15. Madhlopa, A. *Thermodynamic Cycles of Solar Gas Turbines*; Springer: Berlin/Heidelberg, Germany, 2018.
- 16. Mokhtar, M.; Ali, M.T.; Khalilpour, R.; Abbas, A.; Shah, N.; Hajaj, A.A.; Armstrong, P.; Chiesa, M.; Sgouridis, S. Solar-assisted post-combustion carbon capturefeasibility study. *Appl. Energy* **2012**, *92*, 668–676. [CrossRef]

- 17. Wang, W.; Fu, Y.W.; Fan, Q.W.; Huang, J.S.; Chang, D.F. Thermodynamic analysis of a solar aided coal-fired power plant. *IOP Conf. Ser. Earth Environ. Sci.* **2018**, 153, 042020. [CrossRef]
- 18. Xu, X.; Chen, Q.; Ren, M.; Cheng, L. Combustion optimization for coal fired power plant boilers based on improved distributed ELM and distributed PSO. *Energies* **2019**, *12*, 1036. [CrossRef]
- 19. Zhao, W.; Bai, R.; Wang, J.; Bai, R. Analysis thermodynamic performances and techno-economic of solar coal-fired units based on carbon capture. *Chem. Ind. Eng. Prog.* **2014**, *34*, 724–733.
- 20. Hou, H.; Gao, S.; Yang, Y. Thermodynamics analysis of coal-fired power generation system aided by parabolic trough collective fields. *Acta Energ. Sol. Sin.* **2012**, *32*, 1772–1776.
- 21. Zhang, C.; Liu, L.-M.; Chen, S.; Zheng, C.-G. Performance evaluation of thermal power system based on the structure theory of thermo-economic. *Proc. Chin. Soc. Electr. Eng.* **2005**, *25*, 108–113.
- 22. Frangopoulos, C.A. Application of the thermo-economic functional approach to the CGAM problem. *Energy* **1994**, *19*, 323–342. [CrossRef]
- 23. Von Spakovsky, M.R. Application of engineering functional analysis to the analysis and optimization of the CGAM problem. *Energy* **1994**, *19*, 343–364. [CrossRef]
- 24. Valero, A.; Lerch, F.; Serra, L.; Royo, J. Structural theory and thermo-economic diagnosis: Part II: Application to an actual power plant. *Energy Convers. Manag.* **2002**, *43*, 1519–1535. [CrossRef]
- 25. Wang, J.; Wu, Z.; Han, Z.; Liu, X.; Qian, J. Calculation and analysis of the chemical exergy based on high heating values of fuel. *J. Chin. Soc. Power Eng.* **2012**, *32*, 804–808.
- 26. Saidur, R.; Boroumandjazi, G.; Mekhlif, S.; Jameel, M. Exergy analysis of solar energy applications. *Renew. Sustain. Energy Rev.* **2012**, *16*, 350–356. [CrossRef]
- 27. Li, S.; Zhang, H.; Zhan, D.; Zhuang, J. Analysis of exergy in thermal power generation system using steam directly produced from the parabolic trough type solar energy facility. *Therm. Power Gener.* **2008**, *37*, 39–43.
- 28. Badescu, V. How much work can be extracted from diluted solar radiation? *Sol. Energy* **2018**, *170*, 1095–1100. [CrossRef]
- 29. Chena, S.; Lib, Y.; Qin, Y. The health costs of the industrial leap forward in China: Evidence from the sulfur dioxide emissions of coal-fired power stations. *China Econ. Rev.* **2018**, *49*, 68–83. [CrossRef]
- 30. Warman, E.; Nasution, F.S.; Fahmi, F. Energy cost unit of street and park lighting system with solar technology for a more friendly city. *IOP Conf. Ser. Earth Environ. Sci.* **2018**, *126*, 012033. [CrossRef]
- 31. Wegeng, R.S.; Humble, P.H.; Krishnan, S.; Leith, S.D.; Palo, D.R.; Dagle, R.A. *Solar Thermochemical Processing System and Method*; Battelle Memorial Institute Inc: Columbus, OH, USA, 2018.



© 2020 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (http://creativecommons.org/licenses/by/4.0/).