



Article Comparative Analysis of High-Voltage Power Line Models for Determining Short-Circuit Currents in Towers Earthing Systems

Rafał Tarko *🗅, Jakub Gajdzica 🗅, Wiesław Nowak 🗅 and Waldemar Szpyra 🗅

Department of Electrical Engineering and Power Engineering, Faculty of Electrical Engineering, Automatics, Computer Science and Biomedical Engineering, AGH University of Science and Technology, al. Mickiewicza 30, 30-059 Krakow, Poland; jakub.gajdzica@agh.edu.pl (J.G.); wieslaw.nowak@agh.edu.pl (W.N.); wszpyra@agh.edu.pl (W.S.)

* Correspondence: rtarko@agh.edu.pl; Tel.: +48-12-617-36-53

Abstract: The article deals with the problems of single-phase short-circuit current distribution in overhead power lines. Short-circuit disturbances cause many negative phenomena in power networks. Since experimental studies of short-circuits in real networks are practically impossible to perform, these effects can be evaluated only theoretically, based on short-circuit current calculations with the use of appropriate mathematical models. Although short-circuit modeling is considered to be one of the simplest power system calculations, the exact mathematical description of the phenomena occurring at short-circuits is complex. Simplified normative methods are often used for short-circuit current calculations; however, this does not give ground for a thorough analysis of short-circuit current distribution in power lines. The distributions are analyzed using power line models with different degrees of complexity in line with the assumptions made for a given model. The paper presents the problem of current distribution analysis in high-voltage overhead lines for single-phase faults to the tower structures. Simulation studies were conducted on the models developed for the calculation of short-circuit currents in the high-voltage power line earthing. The objective of the analysis was to assess the validity of simplification assumptions followed by practical recommendations on the applicability of the models.

Keywords: overhead power line; short-circuit; earthing current; mathematical model; fault current distribution; shock hazard

1. Introduction

Short circuits are one of the most common disturbances occurring in power systems. A short circuit is a connection between two or more points of a power system that is not expected in the normal operating state, whereby the voltages of the shorted points in the normal operating state are different [1,2]. Short circuits can be single-phase, two-phase, two-phase-to-earth, and three-phase. In overhead high- and extra-high-voltage power networks, single-phase shorts-circuits are the dominant disturbances type (more than two-thirds of all the short-circuits). The causes of short circuits can be different. They are classified into electrical and non-electrical. In overhead lines, the main cause of short circuits are atmospheric overvoltages.

Short-circuit disturbances can cause many negative phenomena in power networks. This results from the flow of short-circuit currents where values are many times greater than the currents in the normal operating state. The effects of short circuits can be both local—limited to the faulted system elements, or global—affecting the entire power system. The most important effects of short circuits include heavy heating of the conductors by the short circuit current, the occurrence of high electrodynamic forces between the electric conductors and the generation of shock hazard. To evaluate the effects of these phenomena,



Citation: Tarko, R.; Gajdzica, J.; Nowak, W.; Szpyra, W. Comparative Analysis of High-Voltage Power Line Models for Determining Short-Circuit Currents in Towers Earthing Systems. *Energies* 2021, *14*, 4729. https:// doi.org/10.3390/en14164729

Academic Editor: Gianfranco Chicco

Received: 13 May 2021 Accepted: 31 July 2021 Published: 4 August 2021

Publisher's Note: MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Copyright: © 2021 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (https:// creativecommons.org/licenses/by/ 4.0/). short-circuit currents have to be calculated, as experimental studies of short circuits in real networks are practically impossible. Accordingly, the analysis of short-circuit currents can be performed only theoretically with the use of appropriate mathematical models.

The short-circuit current distributions are analyzed both in power lines and in substations. In the case of power lines, it is the short-circuit currents returning via the earth and short-circuit currents returning in earth wires to the short-circuit supply sites that are determined most frequently. The knowledge of the value of earth return currents is indispensable for determining the earth potential rise (EPR), on the basis of which the assessment of the electric shock hazard to humans and animals during single-phase earth faults is assessed [3].

Ensuring the safety of bystanders and workers is always a top priority in the operation of overhead transmission lines. The publication [4] analyzed the influence of many factors on the EPR in a 230 kV line. They emphasized that, due to the complexity of the problem and the large amount of data required, there are no simple methods for calculating the EPR for short circuits in high voltage transmission lines. Such calculations can only be performed using computer simulation programs, and there is only limited information on this subject in the literature. Another example are the publications [5,6], which analyzed the EPR in the system of a 138 kV transmission line and a 25 kV distribution line, which are placed on common towers. In these cases, advanced computer models were used for these studies as well. The knowledge of return currents through earth wires is important in view of their proper selection of these wires, which have to withstand the short-circuit conditions. Publication [7] presents a model and a method that allows the calculation of short-circuit current distribution in the earth wires of high-voltage power lines. This publication proposed a procedure to calculate the initial short-circuit current for a shortcircuit at any tower of an overhead line and, then, to calculate the current distribution in each span of the line. In publication [8], an advanced short-circuit current distribution model was used to analyze an earth fault in a 220 kV overhead transmission line. The aim of this research was to explain the causes of earth wire breaking. In publication [9], equations for accurate calculation of the short-circuit current distribution in earth wires of overhead transmission lines were derived. Their validity was confirmed by the excellent agreement occurring between the calculation and measurement results. Apart from that, analyses of short-circuit current distribution in power lines can be also conducted for other purposes, e.g., localization of short-circuits in transmission lines based on currents flowing in earth wires [10].

The analysis of short-circuit current distribution in substations is mainly conducted to evaluate the shock hazard. In this case, the scale of the hazard greatly depends on part of short-circuit current flowing to the substation earthing electrode. This electrode is connected to all conductive elements of the construction objects within the substation, transformer neutral points, metallic sheaths and armors of power cables, as well as power line earth wires.

During a single-phase short-circuit in the substation, all above-mentioned elements create a pathway for short-circuit current in this extensive system of connections. These issues are covered, among others, by IEEE guidelines [11]. The determination of short circuit current distribution in substations requires the extensive use of models that also consider transformers and connected power lines. An integral part of these models are clearly the models of overhead lines. An example is the publication [12], as well as the authors' research presented in [13].

A precise mathematical description of short-circuit current distribution in power lines is a complex issue. This is a result of electromagnetic couplings between the line conductors as well as the fact that overhead lines are not a homogeneous structure due to the variation in the length of individual sections (spans) and tower footing resistance. According to these reasons, simplified models are used in practical calculations of shortcircuit current distributions. We developed, and present in this paper (Section 2), a set of such models varying in complexity. These models were then submitted to simulation studies. The aim of this research was a critical comparative analysis in the aspect of errors of calculations of short-circuit currents flowing in the earth electrodes of high-voltage overhead line towers (Section 3). This analysis allowed for an assessment of the validity of the simplifying assumptions made and recommendations for practical applications of the proposed models.

Although numerous models for the analysis of short-circuit current distributions in lines are presented and used in the literature, studies concerning comparative analyses and accuracy assessment of such models are very rare. An example is the publication [14]. Therefore, it can be expected that the original and innovative research results presented in this publication will find application in the design and operation of high-voltage overhead power lines in the scope of electric shock safety as well as protection automation systems configuration.

The paper is organized as follows:

- a review of the specific literature on short-circuit current distribution in overhead lines is presented in Section 2;
- models developed by the authors for the determination of earth currents during single-phase short-circuit are presented in Sections 2.1–2.5;
- calculation results and comparative analysis of the proposed models are presented in Section 3; and
- our conclusions are presented in Section 4.

2. Power Line Models for Determining Short-Circuit Currents in Towers Earthing Systems

The subject of this study was high-voltage overhead power lines. Figure 1 shows the layout of a power line, double-sided supplied from substations *SA* and *SB*. The power line consists of *n* sections (spans) of specified length and n-1 towers. All abbreviations and symbols used in the article are explained in detail in Appendix A.



Figure 1. Analyzed overhead HV power line: *SA*, *SB*—supply power substations; R_{SA} , R_{SB} —substation earthing resistance; *T*—towers; R_T —tower footing resistance; *F*—short-circuit; I_A , I_B —short-circuit currents flowing from substations *SA* and *SB* to short-circuit site; I_W —short-circuit currents in span earth wires; and I_E —short-circuit current flowing to tower earthing.

We assumed that a single-phase short-circuit *F* to tower $T_{(i)}$ takes place in the power line, resulting in flow of short-circuit currents I_A , I_B from the supply substations *SA*, *SB* to the short-circuit site. These currents return to the supply substations through earth wires (I_W) , also earth (I_E) , and tower earthing systems connected to the earth wires.

The development of mathematical model to determine the distribution of I_A , I_B , I_W , I_E currents is a complex problem because a power line is not homogenous. It results both from the various lengths of particular sections (spans) and different tower footing resistances. A variety of approaches to this problem has been presented in the literature. Despite this diversity, the models can be classified into two basic groups [14,15].

The first group includes models based on the long line theory. The theoretical basis for these models was formulated in [16] and further developed in [9]. Their special feature

is that they are applicable only to homogeneous power line structures. Models belonging to this group can be either continuous or discrete. The circuit representation of discrete models has a ladder structure. Although these models have limitations, they find practical application due to their relatively simple analytical form. An example of such applications can be found in the CIGRÉ guidelines [3].

In the second group of models, the current and voltage equations are directly formulated for discrete power lines. The theoretical basis of these models has been formulated in publications [17,18]. These models are multidimensional systems of algebraic equations. Appropriate numerical methods and computer programs must be used to solve them.

Despite these inconveniences, the considered models have many advantages. Specifically, these models can be applied to non-homogeneous power line structures. Therefore, they are widely used, among others, in the research being the subject of the publications cited in the first section [4–8,10,13]. Moreover, in the publication [19], concerning the analysis and optimization of earthing systems in substations, and, in the publication [20], concerning the study of appropriate selection of earth wire, these models were also used.

Due to the high practical importance of discrete models belonging to the second group, they became the subject of the authors' research. The development of a model for the short circuit current distribution requires the appropriate model of the line sections (spans) to be applied. For the analysis of short-circuit currents, line models with lumped parameters (Figure 2), the values of which are determined for a network frequency and a given soil resistivity, are sufficient [21].



Figure 2. π —Section equivalent circuit model of a power line span with one earth wire [22].

Consequently, taking into account above aspects, we obtain multiphase models (M) of non-homogeneous power line structures, in which specialized simulation programs, e.g., EMTP-ATP have to be used for practical calculations [4–6,8,10,13,20]. The multiphase model can be used for determining the short-circuit current distribution in overhead power lines of any wire configuration. There are no limitations as to the number of circuits and earth wires, their construction and spatial distribution, the number and length of spans, etc. The spans are modeled by capacitively and magnetically coupled π —section equivalent circuits (Figure 1), the parameters of which are determined by the program based on typical power line design data [22].

Despite its evident advantages, the multiphase model (M) has also some disadvantages. The most important is the complexity of its creation. Therefore, we proposed five power line models for determining currents in the towers earthing systems: reference model (R) and models (A), (B), (C), and (D), which are simplifications of the reference model. These models were compared for their accuracy of calculating short-circuited tower earthing currents (Section 3).

2.1. Reference Model (R)

A single-phase model with high computational accuracy was adopted as a reference model (R), as a significant simplification of multiphase model (M). The following assumptions were made for this model:

• Only short-circuited phase wire and earth wires are taken into account.

- The short-circuit place is current-powered, and the short-circuit current values are determined with a common normative method.
- The model consists of *n* spans.

A scheme of the single-phase model for a line with one earth wire is shown in Figure 3. A similar model structure was adopted in studies published in [14].



Figure 3. Scheme of a single-phase power line model with one earth wire: I_A , I_B —short-circuit currents flowing from substations *SA* and *SB* to the short-circuit place; I_E —the short-circuit current flowing to the tower earthing system of tower affected by short-circuit; R_S —substation earthing resistance; R_T —tower footing resistance; Z_W —earth return impedance of one-span-long earth wire sections; E_A , E_B —voltages induced in earth wire affected by short-circuit; and U—node voltage (earth voltage).

The model shown in Figure 3 can be analyzed based on the nodal voltage method with a set of *n*-1 earth voltages U_1, \ldots, U_{n-1} . In this method, the current balance equations are written for individual points in which the tower footing is connected to the earth wire. The matrix form of these equations can be described by:

$$\mathbf{Y} \cdot \mathbf{U} = \mathbf{I},\tag{1}$$

where Y is the nodal admittance matrix, U is the node voltage vector, and I is the current vector.

$$\mathbf{Y} = \begin{bmatrix} Y_A & Y_C & 0 & \cdots & \cdots & 0 \\ Y_C & Y_B & Y_C & \ddots & \ddots & \ddots & \vdots \\ 0 & \ddots & \ddots & \ddots & \ddots & \ddots & \vdots \\ \vdots & \ddots & \ddots & Y_B & Y_C & \ddots & \vdots \\ \vdots & \ddots & \ddots & Y_C & \ddots & \ddots & 0 \\ \vdots & \ddots & \ddots & \ddots & \ddots & Y_B & Y_C \\ 0 & \cdots & \cdots & \cdots & Y_C & Y_A \end{bmatrix}_{(n-1,n-1)}$$
(2)

$$Y_A = \frac{1}{R_S + Z_W} + \frac{1}{Z_W} + \frac{1}{R_T},$$
(3)

$$Y_B = \frac{1}{R_T} + \frac{2}{Z_W},\tag{4}$$

$$Y_{\rm C} = -\frac{1}{Z_W},\tag{5}$$

where Z_W is the self earth return impedance of one-span-long earth wire, R_T is the tower footing resistance, and R_S is the substation earthing resistance.

$$\mathbf{U} = \begin{bmatrix} U_{1} \\ U_{2} \\ \vdots \\ U_{i-1} \\ U_{i} \\ U_{i+1} \\ \vdots \\ U_{n-2} \\ U_{n-1} \end{bmatrix}, \quad \mathbf{I} = \begin{bmatrix} I_{1} \\ 0 \\ \vdots \\ 0 \\ I_{i} \\ 0 \\ \vdots \\ 0 \\ I_{n-1} \end{bmatrix}, \quad (6)$$

$$I_1 = -E_A \left(\frac{1}{R_S + Z_W} - \frac{1}{Z_W} \right),$$
(7)

$$I_i = -(E_A + E_B)\frac{1}{Z_W} + I_A + I_B,$$
(8)

$$I_{n-1} = E_B \left(\frac{1}{R_S + Z_W} - \frac{1}{Z_W} \right),$$
(9)

where I_A , I_B are the short-circuit currents flowing from substations *SA* and *SB* to the short circuit place, and E_A , E_B are the voltages induced in earth wires by short-circuit currents in phase wires:

$$E_A = Z_M I_A,\tag{10}$$

$$E_B = Z_M I_B, \tag{11}$$

where Z_M is the mutual impedance between phase conductor and one-span-long earth wire. Power lines with two earth wires are replaced with one earth wire according to

the procedure:

- Assumed impedance values *Z_W* are two times smaller.
- Impedance values *Z_M* are determined for the geometrically averaged distance between earth wires and phase wire.
- Coupling effects between earth wires are neglected.

The earth currents I_E are determined by calculating nodal voltages *U* from Equation (1) and dividing them by the tower footing resistance R_T :

$$\mathbf{I}_{\mathbf{E}} = \mathbf{Y}^{-1} \mathbf{I} \frac{1}{R_T},\tag{12}$$

The earth current in the *i*-th tower footing affected by short circuit equals to:

$$I_E^{(\mathbf{R})} = I_{E_i},\tag{13}$$

Single-phase short-circuit currents I_A and I_B are determined based on the normative method in compliance with standard no. IEC 60909 [23]. The current values in *i*-th tower with a short circuit are established with Equations (14) and (18):

$$I_A(i) = \sqrt{3} \frac{cU_n}{Z_{0A} + 2Z_{1A}}, \quad i = 1, \dots, n-1,$$
(14)

$$Z_{0A} = k_{0A} \frac{cU_n^2}{S_{kA}} + a \frac{i}{n} Z_{0L},$$
(15)

$$Z_{1A} = \frac{cU_n^2}{S_{kA}} + a\frac{i}{n}Z_{1L},$$
(16)

$$k_{0A} = \frac{X_{0A}}{X_{1A}},\tag{17}$$

$$H_B(i) = \sqrt{3} \frac{cU_n}{Z_{0B} + 2Z_{1B}}, \quad i = 1, \dots, n-1,$$
 (18)

$$Z_{0B} = k_{0B} \frac{cU_n^2}{S_{kB}} + a \frac{n-i}{n} Z_{0L},$$
(19)

$$Z_{1B} = \frac{cU_n^2}{S_{kB}} + a\frac{n-i}{n}Z_{1L},$$
(20)

$$x_{0B} = \frac{X_{0B}}{X_{1B}},$$
 (21)

where *l* is the length of power line, *a* is the length of span, *n* is the number of spans, U_n is the rated voltage, *c* is the voltage factor, S_{kA} , S_{kB} are the short-circuit power in substations *SA* and *SB*, and X_{0A}/X_{1A} , X_{0B}/X_{1B} are the ratios of zero-sequence reactance to positive-sequence reactance in substations *SA* and *SB*.

k

Four simplifications of the model (R) involving a reduction of the number of model elements and, thus, a reduction of the number of equations, are presented further in this Section.

2.2. Simplified Model (A)

A scheme of the simplified model (A) is shown in Figure 4. It consists of five passive elements: the R_T resistance of the tower where the short-circuit occurred, the R_S resistances of the *SA* and *SB* substations, and the Z_{WA} and Z_{WB} self impedances of the earth wires. The elimination of the ladder structure was achieved by omitting all line towers except the tower where the short circuit occurred and omitting electromagnetic coupling between the phase wires and the earth wires.



Figure 4. Scheme of simplified model (A): I_A , I_B —short-circuit currents flowing from substations *SA* and *SB* to the short-circuit place; I_E —short-circuit current flowing to the tower earthing system of tower affected by short-circuit; R_S —substation earthing resistance; R_T —tower footing resistance; and Z_{WA} , Z_{WB} —self impedances of earth wire sections between substations *SA* and *SB* and the short-circuit place.

In this model, the impedances of the earth wires Z_{WA} and Z_{WB} are equal to the sum of the impedances of the particular spans earth wires between the short-circuit location and the substations *SA* and *SB*. As a result, the currents flowing into the earth wires at the short-circuit location are equal to the currents flowing into the *SA* and *SB* substation earth electrodes. In addition, there are two current sources in this model, with the I_A and I_B values determined in the same way as in the reference model (R).

In model (A), the current flowing into the tower earthing system where the shortcircuit occurred is expressed by the equation:

$$I_E^{(A)} = \frac{\frac{(Z_{WA} + R_S)(Z_{WB} + R_S)}{Z_{WA} + Z_{WB} + 2R_S}}{Z_{WA} + Z_{WB} + 2R_S + R_T} \cdot (I_A + I_B),$$
(22)

where Z_{WA} , Z_{WB} are the self-impedances of earth wire sections between substations *SA* and *SB* and the short-circuit place. In the case of power lines with two earth wires, they are replaced by one earth wire, analogously as in the reference model (R).

2.3. Simplified Model (B)

A scheme of simplified model (B) is shown in Figure 5. In this model, as in simplified model (A), all towers in the power line were neglected except the tower affected by short-circuit. However, the coupling between the earth wire and the phase wire in which the short-circuit currents flow has not been neglected. These couplings are represented in the model by voltage sources E_A and E_B , whose values are proportional to the mutual impedances between the phase conductors and the earth wires along the sections between the short-circuit site and the *SA* and *SB* substations.



Figure 5. Scheme of simplified model (B): I_A , I_B —short-circuit currents flowing from substations SA and SB to the short-circuit place; I_E —short-circuit current flowing to the tower earthing system of tower affected by short-circuit; R_S —substation earthing resistances; R_T —tower footing resistance; Z_{WA} , Z_{WB} —self impedances of earth wire sections between substations SA and SB and the short circuit place; and E_A , E_B —voltages induced in earth wires by the short-circuit currents flowing in short-circuited phase wire.

The earth current is expressed by the relation:

$$I_E^{(B)} = \frac{I_A + I_B - \frac{E_A}{Z_{WA} + R_S} - \frac{E_B}{Z_{WB} + R_S}}{1 + \frac{R_T}{Z_{WA} + R_S} + \frac{R_T}{Z_{WB} + R_S}},$$
(23)

where Z_{WA} , Z_{WB} are the self impedances of the earth wire sections between substations *SA* and *SB* and the short-circuit place, and E_A , E_B is the voltages induced in earth wires by short-circuit currents flowing in phase wires:

$$E_A = I_A Z_{MA}, \tag{24}$$

$$\Xi_B = I_B Z_{MB},\tag{25}$$

where Z_{MA} , Z_{MB} are the mutual impedances between the phase conductors and the earth wires on sections with lengths resulting from the distance of the short-circuit location from the substation *SA* and the substation *SB*, respectively.

1

2.4. Simplified Model (C)

A scheme of simplified model (C) is shown in Figure 6. In this model, as in simplified model (A) (Section 2.2), the couplings between earth wires and phase wires were neglected.

The earth current is expressed by a relation analogous to that in the simplified model (A), except that self-impedances Z_{WA} , Z_{WB} are substituted for equivalent impedances of the ladder systems Z_{WAd} , Z_{WBd} shown in Figure 7:

$$I_E^{(C)} = \frac{\frac{(Z_{WAd} + R_S)(Z_{WBd} + R_S)}{Z_{WAd} + Z_{WBd} + 2R_S}}{Z_{WAd} + Z_{WBd} + 2R_S + R_T} \cdot (I_A + I_B),$$
(26)



Figure 6. Scheme of simplified model (C): I_A , I_B —short-circuit currents flowing from substations *SA* and *SB* to the short-circuit place; I_E —short-circuit current flowing to the tower earthing system of tower affected by short-circuit; R_T —tower footing resistance; and Z_{WAd} , Z_{WBd} —equivalent impedances of ladder systems.



Figure 7. Equivalent impedances Z_{WAd} , Z_{WBd} of ladder systems: R_S —substation earthing resistance; R_T —tower footing resistance; and Z_W —earth return impedance of one-span-long earth wire sections.

However, the significant difference from models A and B here is the way of determining the impedances of the earth wires. Their values are the equivalent impedances Z_{WAd} , Z_{WBd} of the ladder systems shown in Figure 7.

2.5. Simplified Model (D)

A scheme of simplified model (D) is shown in Figure 8. It is an extension of the simplified model (C), in which the resultant coupling of the phase wire and earth wire was taken into consideration, analogous to the simplified model (B).

The earth current is expressed by the relation:

Ι

$${}_{E}^{(D)} = \frac{I_{A} + I_{B} - \frac{E_{A}}{Z_{WAd}} - \frac{E_{B}}{Z_{WBd}}}{1 + \frac{R_{T}}{Z_{WAd}} + \frac{R_{T}}{Z_{WBd}}},$$
(27)

$$E_A = Z_{MA} I_A, \tag{28}$$

$$E_B = Z_{MB}I_B, \tag{29}$$

where Z_{MA} , Z_{MB} are the mutual impedances between the phase wire and earth wire.



Figure 8. Scheme of simplified model (D): I_A , I_B —short-circuit currents flowing from substations *SA* and *SB* to the short-circuit place; I_E —short-circuit current flowing to the tower earthing system of tower affected by short-circuit; R_T —tower footing resistance; Z_{WAd} , Z_{WBd} —equivalent impedances of ladder systems; and E_A , E_B —voltages induced in earth wires by short-circuit currents flowing in the short-circuited phase wire.

3. Results and Discussion—Comparative Analysis of the Proposed Models

The models used for determining expected earth currents in the supports are burdened with errors resulting from the introduced assumptions and simplifications. To assess the applicability of these models for practical calculations, a multivariate comparative analysis was performed to determine relative calculation errors of simplified models (A)–(D) in relation to the exact models (M) and (R).

A 110 kV overhead power line with a triangular asymmetrical arrangement of three phase wires and with one earth wire was selected for the study. Uniform, averaged values of line parameters were assumed along the entire line length. The tower shape is based on data from catalogues of single-circuit lines typical structures [24]. The cross-section of the phase wires equaled to 240 mm², and that of the earth wire was 70 mm².

The tower footing resistances and the span lengths were assumed to be equal along the entire power line. Detailed data of the power line are shown in Figure 9. On the basis of these parameters, the models of the line spans were determined in the form of self- and mutual impedances (30), and, after their transformation, the impedances in the domain of symmetrical components were obtained (31).



Figure 9. Technical parameters and tower construction of analyzed 110 kV overhead power line [24].

The self and mutual impedances matrix of the analyzed line, determined in the EMTP-ATP program for the multiwire model and soil resistivity equals to 100 Ω m, has the following form:

$$Z_{L} = \begin{bmatrix} Z_{11} & Z_{12} & Z_{13} & Z_{14} \\ Z_{12} & Z_{22} & Z_{23} & Z_{24} \\ Z_{13} & Z_{23} & Z_{33} & Z_{34} \\ Z_{14} & Z_{24} & Z_{34} & Z_{44} \end{bmatrix} = \begin{bmatrix} (0.173 + j0.727) & (0.048 + j0.314) & (0.048 + j0.312) & (0.048 + j0.305) \\ (0.048 + j0.314) & (0.173 + j0.727) & (0.048 + j0.349) & (0.048 + j0.302) \\ (0.048 + j0.312) & (0.048 + j0.349) & (0.172 + j0.727) & (0.048 + j0.339) \\ (0.048 + j0.305) & (0.048 + j0.302) & (0.048 + j0.339) & (0.525 + j0.757) \end{bmatrix}$$
(30)

This matrix, after the earth wire aggregation and mutual impedance averaging, can be transformed to a domain of symmetrical components:

$$Z_L^S = \begin{bmatrix} Z_{0L} & 0 & 0\\ 0 & Z_{1L} & 0\\ 0 & 0 & Z_{2L} \end{bmatrix} = \begin{bmatrix} (0.368 + j1.061) & 0 & 0\\ 0 & (0.125 + j0.402) & 0\\ 0 & 0 & (0.125 + j0.402) \end{bmatrix} \begin{pmatrix} \Omega\\ km \end{pmatrix},$$
(31)

The per unit impedance $Z_{44} = (0.525 + j0.757) (\Omega/\text{km})$ is the basis for determining the Z_W impedance in model (R), the Z_{WA} and Z_{WB} impedances in models (A) and (C), and the

 Z_{WAd} and Z_{WBd} impedances in models (B) and (D). In addition, the per unit impedance $Z_{34} = (0.048 + j0.339) (\Omega/\text{km})$ is the basis for determining the Z_M impedance in model (R) and the Z_{MA} and Z_{MB} impedances in models (B) and (D). Moreover, the per unit impedances $Z_{0L} = (0.368 + j1.061) (\Omega/\text{km})$ and $Z_{1L} = (0.125 + j0.402) (\Omega/\text{km})$ are the basis for determining the short-circuit currents I_A and I_B according to Equations (14) and (18).

The analysis was conducted for nine variants of power line (Table 1) differing in the line length, spans length, tower and substation earthing resistances, and short-circuit powers at line ends.

Variant	l (km)	a (m)	n	R _T (Ω)	R _S (Ω)	ρ (Ω·m)	Substation SA		Substation SB	
							S _k (GVA)	X_0/X_1	S _k (GVA)	X_0/X_1
1	5	250	20	10	0.5	100	2	2	1	2
2	10	250	40	10	0.5	100	2	2	1	2
3	20	250	80	10	0.5	100	2	2	1	2
4	50	250	200	10	0.5	100	10	2	2	2
5	10	357	28	10	0.5	100	2	2	1	2
6	10	200	50	10	0.5	100	2	2	1	2
7	10	250	40	5	0.5	100	2	2	1	2
8	10	250	40	15	0.5	100	2	2	1	2
9	10	250	40	10	0.1	100	2	2	1	2
10	10	250	40	10	0.5	300	2	2	1	2

Table 1. Overhead power line and substations parameters for the analyzed variants.

l—line length; *a*—span length; *n*—number of spans; R_T —tower footing resistance; R_S —*SA* and *SB* substation earthing resistance; ρ —soil resistivity; S_k —short-circuit power; X_0 —zero-sequence reactance; and X_1 —positive-sequence reactance.

Variants (1)–(4) differ in length *l* of the line, where $l \in \{5 \text{ km}; 10 \text{ km}; 20 \text{ km}; 50 \text{ km}\}$. For these variants, the span length *a*, tower footing resistances R_T , and substation earthing resistances R_S are the same. The short-circuit powers S_k and the X_0/X_1 ratio in the supply substations are also the same, except for variant (4), which assumes five-times higher short-circuit power values in substation *SA* and double values in substation *SB*.

Variants (5) and (6) have reference to variant (2); however, in this case, the span lengths are, respectively, longer (357 m) and shorter (200 m) than length *a* in variant (2). Variants (7) and (8) are also referenced to variant (2); however, in these cases, the tower footing resistances are lower (5 Ω) and higher (15 Ω), respectively. On the other hand, variant (9) differs from variant (2) in the lower earthing resistance (0.1 Ω) of supply substations *SA* and *SB*. Variant (10) is similar to variant (2) but differs in the soil resistivity value equal to 300 Ω m.

The power line variants were represented in multiphase model (M), reference model (R) and in simplified models (A)–(D). Model (M) was developed in the EMTP-ATP program, while the remaining ones were developed in a MATLAB environment. The simulations revealed that the multiphase (M) and reference (R) models gave practically identical values of earthing currents in power lines with a single earth wire. For this reason, further analyses concentrated on the comparison of results obtained with simplified models (A)–(D) and reference model (R).

The analysis results for variants (1)–(10) are presented in Figures 10–15. The plots visualize currents I_E flowing to the tower earthing system of tower affected by short-circuit, determined for models (R), (A)–(D), as a function of short-circuit place. The figures also present the values of relative errors ε of determining the I_E currents for the analyzed variants:

$$\varepsilon^{(x)} = \frac{I_E^{(x)} - I_E^{(R)}}{I_E^{(R)}} \cdot 100\%, \quad x \in \{A; B; C; D\}.$$
(32)



Figure 10. Results of the comparative analysis of models in variants (1), (2), and (3): (**a**,**c**,**e**) earthing current I_E values for the towers affected by single-phase short-circuit; and (**b**,**d**,**f**) relative error ε .

Figure 11. Results of the comparative analysis of models in variant (4): (**a**) earthing current I_E values for the towers affected by single-phase short-circuit; and (**b**) relative error ε .

Figure 12. Results of the comparative analysis of models in variants (5) and (6): (**a**,**c**) earthing current I_E values for the towers affected by single-phase short-circuit; and (**b**,**d**) relative error ε .

Figure 13. Results of the comparative analysis of models in variants (7) and (8): (**a**,**c**) earthing current I_E values for the towers affected by single-phase short-circuit; and (**b**,**d**) relative error ε .

Figure 14. Results of the comparative analysis of models in variant (9): (**a**) earthing current I_E values for the towers affected by single-phase short-circuit; and (**b**) relative error ε .

Figure 15. Results of the comparative analysis of models in variant (10): (**a**) earthing current I_E values for the towers affected by single-phase short-circuit; and (**b**) relative error ε .

In Figure 10, the results of the comparative analysis for Variants (1), (2), and (3) are presented. These variants differ in the lengths of the analyzed line being 5, 10, and 20 km, respectively. From this figure, it can be seen that the values of currents flowing into the earthing of the towers where the short circuit occurred significantly depended on the model used. From the calculations using model (R), it can be seen that the length of the line had a minor influence on the values of the earth currents.

The relative errors using models (A) and (B) reached very high values, up to several hundred percent. Whereas, model (D), for short sections, obtained good convergence with model (R), but its errors increased with the length of the analyzed line. In addition, this model did not correctly determine at which line towers the largest values of earth currents occur. The smallest errors were obtained using model (C) with the error value increasing slightly with line length.

Figure 11 shows the analysis results for variant (4). The analyzed case was characterized by a significant line length (50 km) and higher short-circuit powers at the supply substations. The increase in short-circuit powers caused an increase in the values of earth currents during short-circuits, especially on towers near the substations. In this case, only model (C) gave results with an error not exceeding 25%, while the errors of the other models reached values ranging from about 300% (model (A)), to about 700% (model (B)).

Figure 12 shows the results of the analysis for variants (5) and (6). These variants were characterized by different span lengths (357 and 200 m, respectively), with the same total line length of 10 km (as in variant (2)). The values of earth currents depended on the span length with the values increasing with the span length. The relative errors of all models decreased with increasing span length. For these variants, model (C) had the lowest relative errors as well. In these variants, model (D) did not allow to determine correctly in which towers of the line the highest values of earth currents occurred.

The results of the analysis for variants (7) and (8) are shown in Figure 13. These variants had different tower footing resistances (5 and 15 Ω , respectively) with the other parameters the same as in variant (2). As expected, higher values of footing resistance corresponded to lower values of earth current. In variant (7), the smallest relative errors were obtained with model (C), while in variant (8) with model (D).

Figure 14 shows the results of the analysis for variant (9). The analyzed case was characterized by a five-times lower value of the substation earthing system resistance ($R_S = 0.1 \Omega$) than in the other variants. This change caused a decrease in the value of earth currents only in a few towers in the substation vicinity. The error values for all analyzed models practically did not depend on the value of substations earthing system resistance and are comparable to the errors in variant (2).

The results of the analysis for variant (10) are shown in Figure 15. This variant had different soil resistivity equal to 300 Ω m, with the other parameters the same as in variant (2). Higher value of soil resistivity caused a slight decrease of the earth current values determined by model (R) and model (B), whereas the other models were characterized by slightly higher values of earth currents. This change caused an increase of relative errors. It should be noted that the simplified model (C), as well as the other variants, was characterized by the lowest values of relative errors and not exceeding 23%.

The analysis showed that model (A) and model (B) in all analyzed variants generated considerable errors up to several hundred percent. The higher power line length *l* was, the higher the relative error was. Despite the fact that models (A) and (B) are mathematically simple, they should not be used to determine the earthing current values.

In model (C), the error ranged from a few to about 25%. Generally, the earthing current values were only slightly overestimated along the entire power line. Therefore, we recommend that this model is used in calculations conducted for lines with one earth wire. In model (C), the relative error did not exceed the value of +25% in any of the analyzed variants. A negative error value in model (C) was observed in few variants in some of the first power line towers (1 to 3 towers) from substations where the short-circuit power was higher. However, the error value did not exceed -5%. The negative error can increase when assuming relatively small values of tower footing resistance (<5 Ω).

Very good results were obtained in model (D) for considerably short power lines (up to a dozen or so km) or lines with high tower footing resistance ($R_T \ge 10 \Omega$). However, the relative error increased with the distance between the short-circuit site and the substation, and for long power lines (several tens of km long). In this case, the error values can reach even several hundred percent. Additionally, this model does not allow to identify correctly in which line towers the highest earth currents values occur. Moreover, it should be noted that model (D) is the most complex of the analyzed simplified models.

The research showed that, for power lines with two earth wires, reference model (R) did not ideally comply with multiphase model (M). This stems from the assumption of equal mutual impedances between the short-circuited phase wire and the earth wires as well as omission of the magnetic coupling between earth wires. To check the accuracy of the proposed computational models, tests were performed for a power line with two earth wires. Figure 16 shows an example of the analysis results for line models with two earth wires with parameters from variant (1).

Figure 16. Results of the comparative analysis of models for a power line with two earth wires in variant (1): (**a**) earthing current I_E values for the towers affected by single-phase short-circuit; and (**b**) relative error ε .

As can be seen, all simplified models generated significant relative error values, while reference model (R), relative to multiphase model (M), had a negative error of several

percent value (Figure 16b). Among the simplified models, model (C) also had the smallest relative error as in the case of the power lines with one earth wire. However, with reference to model (R), its errors reached up to +60%.

4. Conclusions

Although the construction of overhead power lines varies considerably, the method of their modelling in short-circuits calculations is the same. The mathematical description of accurate multiphase models of these lines is complex due to the electromagnetic couplings between the wires and the multi-site connections of the earth wires to the tower earthing system. The quantitative analysis of short-circuit conditions is complex and requires the use of advanced mathematical models. On the other hand, many technical decisions in operation and design practice must take into account the values of short-circuit currents and other related parameters.

Therefore, it is necessary to develop simplified methods of short-circuit calculations that do not require the use of complicated mathematical methods and with reference to the distribution of short-circuit currents in power lines. We proposed two precise models (multiphase model (M), reference model (R)), and four simplified models (named A–D). These models were analyzed for their applicability to the determination of earth currents during short circuits.

The developed and proposed models and the comparative analysis made in the article are the authors' contributions to the field of short-circuits in power networks. Multivariate calculations were performed for different values of line parameters, which were the line length, span length, number of spans, tower footing resistance, substation earthing resistance, soil resistivity, and substations short-circuit powers. The parameter used to evaluate the individual models was the relative error of determining the earth currents values.

Based on the analysis of the proposed models, the following models, ranked according to increasing calculation relative error, are recommended for the determination of earth currents in lines with a single earth wire: multiphase model (M), reference model (R), and simplified model (C). However, earth currents in power lines equipped with two earth wires should be determined with multiphase model (M) or at least reference model (R). The use of simplified model (C) is permissible, although the error involved should be considered.

The use of multiphase model (M) in short-circuit calculations requires specialized simulation programs, such as EMTP-ATP. The calculations performed with reference model (R) require computer programs in which complex admittance matrices can be easily created and inverted, e.g., a MATLAB computing environment. In turn, simplified model (C) requires using simple computational tools, such as an EXCEL spreadsheet.

The research results presented in this article can support the design and operation of high-voltage overhead power lines in the field of electric shock protection assessment. One of the elements of this analysis is the determination of earth voltages resulting from the flow of short-circuit currents in the power line towers. Due to the fact that the allowed values of earth voltages depend on the duration of the short circuit, the results of the research can also be used in the coordination of the protection automation systems settings. The simplified models proposed by the authors are currently used by some power distribution operators to assess the shock hazard around line towers during earth faults.

Author Contributions: Conceptualization, W.N. and R.T.; methodology, W.N. and R.T.; software, W.N., R.T., W.S. and J.G.; validation, W.N., R.T. and W.S.; formal analysis, W.N. and R.T.; investigation, J.G. and R.T.; writing—original draft preparation, W.N., R.T., W.S. and J.G.; writing—review and editing, R.T.; visualization, W.N., R.T.; supervision, R.T. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Conflicts of Interest: The authors declare no conflict of interest.

Appendix A

The appendix contains a list of symbols relating to the abbreviations, equations, and figures presented in the article.

 Table A1. List of abbreviations and symbols used in the article.

Symbol	Description					
HV	high voltage					
EMTP-ATP	Electromagnetic Transients Program—Alternative Transients Program					
SA, SB	supply substation SA, SB respectively					
R _S	substation earthing resistance					
R_{SA}, R_{SB}	earthing resistance of substation SA, SB respectively					
Т	tower of power line					
R_T	tower footing resistance					
F	single-phase short-circuit location					
I. I_	short-circuit currents flowing from substations SA and SB to					
1 _A , 1 _B	short-circuit site					
I_W	short-circuit currents in span earth wires					
$ \begin{split} &I_{E}, I_{E}{}^{(R)}, I_{E}{}^{(A)}, I_{E}{}^{(B)}, I_{E}{}^{(C)}, \\ &I_{E}{}^{(D)} \end{split} $	short-circuit current flowing to tower earthing (I_E) determinate for specific power line models: (R)—reference model, (A)–(D)—simplified models (A)–(D)					
7	self earth return impedance of one-span-long earth wire					
Σ_W	self impedances of earth wire sections between substations SA					
$Z_{W\!A}$, $Z_{W\!B}$	and SR respectively and the short-circuit place					
ZIALA J. ZIALD J	equivalent impedances of the ladder systems					
— _{(VAa} , — _{VVBa}	mutual impedance between phase conductor and one-span-long					
Z_M	earth wire					
	mutual impedances between the phase conductors and the earth					
	wireson sections with lengths resulting from the distance of the					
Z_M, Z_{MA}, Z_{MB}	short-circuit location from the substation SA and the substation					
	SB, respectively					
	voltage induced in earth wire affected by short-circuit currents in					
E_A, E_B	phase wires from substation SA and SB, respectively					
U_n	rated voltage					
С	voltage factor (according to IEC 60909)					
i	number of towers with a short-circuit					
а	length of span					
п	number of spans					
1	length of power line					
Zot Zor	zero-sequence impedance from SA and SB substations to					
	short-circuit place					
Z14.Z1P	positive-sequence impedance from <i>SA</i> and <i>SB</i> substations to					
	short-circuit place					
Z_{0L}	zero-sequence impedance of power line					
Z_{1L}	positive-sequence impedance of power line					
S_{kA}, S_{kB}	short-circuit power in substations <i>SA</i> and <i>SB</i> , respectively					
	tactor determining ratios of zero-sequence reactance to					
<i>k</i> _{0A} , <i>k</i> _{0B}	positive-sequence reactance in substations <i>SA</i> ($k_{0A} = X_{0A}/X_{1A}$) and <i>SB</i> ($k_{0B} = X_{0B}/X_{1B}$), respectively					

References

- 1. Tleis, N.D. *Power Systems Modelling and Fault Analysis: Theory and Practice;* Newnes (imprint of the Elsevier): Oxford, UK; Burlington, MA, USA, 2008.
- Das, J.C. Power Systems Handbook. Vol. 1, Short-Circuits in AC and DC Systems: ANSI, IEEE, and IEC Standards; CRC Press (imprint of the Taylor & Francis Group): Boca Raton, FL, USA; London, UK; New York, NY, USA, 2018.
- 3. International Council on Large Electric Systems, Working Group B2.56. TB 694. *Ground Potential Rise at Overhead ac Transmission Line Structures during Power Frequency Faults;* CIGRE: Paris, France, 2017.
- 4. Liang, X.; Wang, C. Factors Affecting Ground Potential Rise and Fault Currents Along Transmission Lines With Multigrounded Shield Wires. *IEEE Trans. Ind. Appl.* **2017**, *53*, 888–900. [CrossRef]
- Acharya, J.; Xu, W. Ground potential rise of multi-grounded neutral and shield wires in joint systems. *Electr. Power Syst. Res.* 2010, 80, 1074–1081. [CrossRef]
- 6. Acharya, J.; Wang, Y.; Xu, W. Temporary Overvoltage and GPR Characteristics of Distribution Feeders with Multigrounded Neutral. *IEEE Trans. Power Del.* **2010**, 25, 1036–1044. [CrossRef]
- Klucznik, J.; Lubośny, Z.; Dobrzyński, K. Calculations of Short-Circuit Current Flows in Earth Wires of HV Lines. *Acta Energetica* 2016, 1, 45–50. [CrossRef]
- 8. Cai, Y.; Zhou, K.; Yang, L.; Li, C.; Zhang, R.; Zhao, L. The Analysis of the Reasons for the Disconnection of Overhead Ground Wire. In Proceedings of the IEEE Sustainable Power and Energy Conference (iSPEC), Beijing, China, 20–24 November 2019. [CrossRef]
- 9. Desieno, C.F.; Marchenko, P.P.; Vassell, G.S. General Equations for Fault Currents in Transmission Line Ground Wires. *IEEE Trans. Power App. Syst.* **1970**, *89*, 1891–1900. [CrossRef]
- Silva, D.T.; Silvino, J.L.; Paulino, J.O.; de Melo, J.C.D. Fault location on overhead power transmission lines by measuring currents from shield wires. In Proceedings of the 9th IEEE/IAS International Conference on Industry Applications-INDUSCON 2010, Sao Paulo, Brazil, 8–10 November 2010. [CrossRef]
- 11. IEEE. IEEE Guide for Safety in AC Substation Grounding, IEEE Std 80-2013 (Revision of IEEE Std 80-2000/ Incorporates IEEE Std 80-2013/Cor 1-2015); IEEE: Minneapolis, MN, USA, 15 May 2015; pp. 1–226. [CrossRef]
- 12. Unde, M.G.; Maske, R.N. Analysis of Fault Current Distribution. In Proceedings of the International Conference on Information, Communication, Engineering and Technology (ICICET), Pune, India, 29–31 August 2018. [CrossRef]
- Gajdzica, J.; Nowak, W.; Szpyra, W.; Tarko, R. Modelling and Analysis of Currents Flowing in High Voltage Power Substations During Ground Short–Circuits. In Proceedings of the 14th Selected Issues of Electrical Engineering and Electronics (WZEE), Szczecin, Poland, 19–21 November 2018. [CrossRef]
- 14. Vintan, M.A. Comparative Parametric Analysis of the Ground Fault Current Distribution on Overhead Transmission Lines. *Adv. Electr. Comput. Eng.* **2016**, *16*, 107–114. [CrossRef]
- 15. Dawalibi, F.; Niles, G.B. Measurements and Computations of Fault Current Distribution on Overhead Transmission Lines. *IEEE Trans. Power App. Syst.* **1984**, 103, 553–560. [CrossRef]
- 16. Endrenyi, J. Analysis of Transmission Tower Potentials during Ground Faults. *IEEE Trans. Power App. Syst.* **1967**, *86*, 1274–1283. [CrossRef]
- 17. Sebo, S.A. Zero-Sequence Current Distribution along Transmission Lines. *IEEE Trans. Power App. Syst.* **1969**, *88*, 910–919. [CrossRef]
- Gooi, H.B.; Sebo, S.A. Distribution of Ground Fault Currents along Transmission Lines-An Improved Algorithm. *IEEE Trans.* Power App. Syst. 1985, 104, 663–670. [CrossRef]
- 19. Wu, X.; Simha, V.; Wellman, R.J.; Thakur, M.; Dimpfl, S.S. Substation Grounding Study Input Parameter Sensitivity Analysis and Simulation Strategies. *IEEE Trans. Ind. Appl.* **2019**, *55*, 2272–2280. [CrossRef]
- Crisafulli, C.A.; Spoor, D.J. A case study on the appropriate selection of optical ground wire. In Proceedings of the Australasian Universities Power Engineering Conference, Sydney, NSW, Australia, 14–17 December 2008; pp. 1–5.
- 21. Ametani, A. Electromagnetic Transients Program: History and Future. IEE J. Trans. 2020. [CrossRef]
- 22. Dommel, H.W. EMTP Theory Book; B.P.A.: Portland, OR, USA, 1986.
- 23. International Electrotechnical Commission. IEC 60909-0:2016. Short-Circuit Currents in Three-Phase A.C. Systems-Part 0: Calculation of Currents; International Electrotechnical Commission: Geneva, Switzerland, 2016.
- 24. Enprom. *Lattice Tower Catalogue for 110 kV Power Lines;* Enprom Ltd.: Warszawa, Poland, 2018; (In Polish). Available online: https://www.enprom.pl/wp-content/uploads/2019/10/Katalog-110kV_2010_wydanie-2018.pdf (accessed on 21 July 2021).