




Article

ENIGMA—A Centralised Supervisory Controller for Enhanced Onboard Electrical Energy Management with Model in the Loop Demonstration

Sharmila Sumsurooah ^{1,*}, Yun He ² , Marcello Torchio ³, Konstantinos Kouramas ³, Beniamino Guida ⁴, Fabrizio Cuomo ⁵, Jason Atkin ², Serhiy Bozhko ¹, Alfredo Renzetti ⁴, Antonio Russo ⁶ , Stefano Rivero ³ and Alberto Cavallo ⁶ 

- ¹ Power Electronics Machines and Control Research Group, Faculty of Engineering, University of Nottingham, Nottingham NG7 2TU, UK; Serhiy.bozhko@nottingham.ac.uk
- ² School of Computer Science, University of Nottingham, Nottingham NG8 1BB, UK; yun.he@nottingham.ac.uk (Y.H.); jason.atkin@nottingham.ac.uk (J.A.)
- ³ Applied Research & Technology, Collins Aerospace, T23 XN53 Cork, Ireland; marcello.torchio@collins.com (M.T.); konstantinos.kouramas@collins.com (K.K.); stefano.rivero@collins.com (S.R.)
- ⁴ Aeromechs, 81031 Aversa, Italy; beniamino.guida@aeromechs.eu (B.G.); alfredo.renzetti@aeromechs.eu (A.R.)
- ⁵ Leonardo Aircraft Division, Leonardo Aircraft, 80038 Pomigliano D'Arco, Italy; fabrizio.cuomo@leonardocompany.com
- ⁶ Department of Engineering, Università degli Studi della Campania "Luigi Vanvitelli", 81031 Aversa, Italy; antonio.russo1@unicampania.it (A.R.); alberto.cavallo@unicampania.it (A.C.)
- * Correspondence: sharmila.sumsurooah@nottingham.ac.uk



Citation: Sumsurooah, S.; He, Y.; Torchio, M.; Kouramas, K.; Guida, B.; Cuomo, F.; Atkin, J.; Bozhko, S.; Renzetti, A.; Russo, A.; et al. ENIGMA—A Centralised Supervisory Controller for Enhanced Onboard Electrical Energy Management with Model in the Loop Demonstration. *Energies* **2021**, *14*, 5518. <https://doi.org/10.3390/en14175518>

Academic Editor: Sangheon Pack

Received: 30 June 2021

Accepted: 30 August 2021

Published: 3 September 2021

Publisher's Note: MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.

Abstract: A centralised smart supervisor (CSS) controller with enhanced electrical energy management (E2-EM) capability has been developed for an Iron Bird Electrical Power Generation and Distribution System (EPGDS) within the Clean Sky 2 ENhanced electrical energy Management (ENIGMA) project. The E2-EM strategy considers the potential for eliminating the 5 min overload capability of the generators to achieve a substantial reduction in the mass of the EPGDS. It ensures optimal power and energy sharing within the EPGDS by interfacing the CSS with the smart grid network (SGN), the energy storage and regeneration system (ESRS), and the programmable load bank 1 secondary distribution board (PLB1 SDU) during power overloads and failure conditions. The CSS has been developed by formalizing E2-EM logic as an algorithm operating in real time and by following safety and reliability rules. The CSS undergoes initial verification using model-in-the-loop (MIL) testing. This paper describes the EPGDS simulated for the MIL testing and details the E2-EM strategy, the algorithms, and logic developed for the ENIGMA CSS design. The CSS was subjected to two test cases using MIL demonstration, and based on the test results, the performance of the ENIGMA CSS is verified and validated.

Keywords: supervisory control; enhanced electrical energy management (E2-EM); coordination of aircraft smart grid; model-in-the-loop



Copyright: © 2021 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

Recent trends in aircraft development and related research and development (R&D) programs show the increasing role and importance of electrically powered onboard equipment that was traditionally powered by hydraulic or pneumatic systems. This has resulted in an increased onboard power generation capacity, exceeding 1 MW in civil aircraft programs in some cases. The primary motivation behind this transition to the electrification of the aviation sector is to reduce pollution while increasing the reliability and maintainability of the affected systems [1]. The trend is clearly a move toward a more-electric aircraft (MEA) or even an eventual all-electric Aircraft.

Looking ahead, further and even more radical increases in airborne energy usage above the few MW level are expected from the partial or the even full electrification of primary or propulsive power within the next generation of MEA technology (hybrid-electric and full-electric). The current vision is that the potential for weight saving and efficiency improvement of onboard EPS and MEA can only be unlocked if we consider the triage of the weight–efficiency–power level and their interactions. As an essential brick of this integrated approach, efficient E2-EM (Enhanced Electrical Energy Management) strategies shall be implemented. E2-EM is defined as the advanced smart control of aircraft electrical loads and power sources that aims at obtaining a reduction of generator weight and size, while also increasing reliability. The state of the art [2] is represented in Figure 1a for a generic aircraft, where the electrical load management (ELM) is based on the complete switch-off of non-essential loads (e.g., galley, IFE, cabin lights). The disconnection order is decided by the pilot on smaller a/c or is automatically performed by control units on larger a/c.




Figure 1. (a) State of the art of a generic aircraft electrical load management (ELM); (b) advanced smart control of aircraft electrical loads and power sources.

E2-EM overcomes this fundamental limit of simple ELM and instead considers an advanced smart control of aircraft electrical loads and power sources rather than just ON/OFF actions. This is achieved by the following two features:

- (1) A supervisor is introduced as the key means to send and receive specific messages on a communication network;
- (2) Power conversion equipment is implemented in the advanced control algorithm to implement the E2-EM functions.

A general reference scheme is shown in Figure 1b. The green-dotted line may represent any of the currently available onboard communication networks, e.g., AFDX, CAN, ARINC. Moreover, the introduction of secondary energy storage sources (e.g., batteries, supercapacitors, fuel cells) provides an extra degree of freedom and aligns the E2-EM to the most recent advancement in the field of hybrid/all electric aircraft, where the role of any component other than the main generator source(s) is a decisive factor.

The “energy management” concept was already exploited in the numerous initiatives taken through the European Commission, such as the I-PRIMES [3], MOET [4], and EPOCAL [5] projects. This paper extends these results by proposing E2-EM as a new integrated approach, and it is based on the research work being conducted within the ENIGMA Clean Sky 2 project. The aim of the ENIGMA project is to design, develop, manufacture, test, and integrate an innovative CSS embedding E2-EM strategy into the EPGDS of Leonardo Aircraft Iron Bird ground demonstrator.

According to the literature, energy management schemes mainly involve the efficient management of energy storage devices [6–11] and the management of loads, including priority-based load shedding [2,12,13]. Furthermore, the idea of extending the energy storage and load management techniques to eliminate the overload capabilities of a generator has been considered by researchers and engineers due to its obvious operational

and environmental benefits and the inclusion techniques to manage overload through generators [14], batteries [6], supercapacitors, and power distribution to loads [14]. However, energy management strategies involving the elimination of the overload capability of generators has not been fully exploited in the literature.

The work conducted within the ENIGMA project exploits the “5 s and 5 min” overload capability of the generator. The energy management strategy is designed to ensure that overloads are cleared within 5 s. Since the 5 s capability is ensured, the 5 min capability is no longer required. This enables the overload capability requirement for the main generator sizing to be removed, leading to a substantial reduction in the mass of generators, which is estimated to be up to 15% for existing airborne class W generators. This can lead to a significant contribution in achieving more efficient, greener aviation. In addition, the developed ENIGMA CSS will be interfaced with the lower-level controllers of the smart grid network (SGN), the energy storage and regeneration system (ESRS), and the programmable load bank 1 secondary distribution board (PLB1 SDU) of the Iron Bird EPGDS to provide the optimal management and the sharing of available on-board electric power during overloading and failure conditions. The SGN, ESRS, and the PLB1 SDU are currently being developed within the Regional Integrated Aircraft Demonstration Platform projects ASPIRE, ESTEEM, and IDEN respectively.

The ENIGMA CSS embeds E2-EM control logic based on the aforementioned E2-EM strategies. The overall CSS development has been conducted by employing a formal mathematical approach based on the formalisation of the E2-EM as an algorithm operating in real time under safety and reliability rules, including the optimisation mathematics at its core. The developed CSS will also be capable of expansion in order to include interfaces with other lower-level subsystems to be developed by future regional projects.

Prior to the integration of the ENIGMA CSS in the Leonardo aircraft ground demonstrator, the CSS needs to undergo a number of testing phases comprised of model-in-the-loop (MIL) and then hardware-in-the-loop tests. This paper focusses on MIL testing. For this purpose, a set of simulation models of the ENIGMA CSS, the Iron Bird EPGDS including the SGN, ESRS, and PLB1 SDU, have been developed at the functional level within the software environment MATLAB/Simulink. This paper aims to verify and validate the performance of the ENIGMA CSS through MIL demonstration.

This paper is organised in six sections. After this introductory section, the energy management strategy that will be adopted for the ENIGMA CSS is detailed in Section 2. Section 3 describes the Iron Bird EPGDS and its subsystems, while Section 4 provides an in-depth explanation of the E2-EM algorithms and logic to be implemented in the ENIGMA CSS. Section 5 gives the MIL demonstration of the E2-EM control strategy through the presented test results. Finally, the paper is concluded with the mention of future works.

2. ENIGMA Energy Management Strategy

As mentioned in the Introduction section, the aerospace industry is moving towards the MEA paradigm from different perspectives. One of the beaten paths involves the adoption of more sophisticated energy management systems (EMSs) to enable the smart and optimized management of onboard available power and to counteract it with appropriate actions in the presence of possible generator failures and overload conditions. The objective of the ENIGMA CSS is to optimally coordinate the sharing of available onboard power during generator overloads and failure conditions. This objective is achieved by the ENIGMA CSS controlling the power consumption and the generation of the EPGDS subsystems that include the SGN, ESRS, and PLB1, as will be detailed in the next section. ENIGMA action, supported by the flexibility provided by each subsystem, controls and maintains the power output of the generators below the maximum rated power in the event of overload and/or failure conditions.

Aircraft generators are generally sized according to the 5-min, 5-s rule. Conventionally, the 5-min capability means that the generator can be overloaded for 5 min with a power of up to 150% of its nominal rated power, and the 5-s capability implies that the generator can

be overloaded for 5 s with a power of up to 200% of its nominal rated power. An overload condition may occur as the result of an extra load being connected to the aircraft EPGDS. The time at which an overload condition appears and the amount of power it requires are unknown a priori. The objective of the CSS described in this work is to counteract the presence of unpredicted overload conditions in a smart and optimized way. In particular, the main requirement that the CSS has to satisfy is to clear the generator overload within 5 s from its detection, with the implication that the 5 min capability can be removed from the generator design, thus reducing the weight and size of the generator.

Figure 2 is the graphical representation of the generator overload conditions that can occur in the EPGDS and that are used to define the ENIGMA CSS strategy. It uses the following key quantities:

- P_{THy} (W) represents the threshold above which the CSS starts to take action in coordination with the different subsystems to clear the overload. If the generator power exceeds this threshold, an overload condition is detected;
- $P_{g,max}$ (W) is the maximum rated power that a generator can sustain. This value generally reflects the generator's specifications;
- $P_g(t)$ (W) represents the instantaneous actual power of the generator at time (t).




Figure 2. ENIGMA CSS managing the overload within the 5-s generator capability.

In general, the condition $P_{THy} \leq P_{g,max}$ holds. If an aircraft is equipped with multiple generators, the value of $P_{g,max}$ is generally the same for all of the generators.

The ENIGMA CSS monitors three main conditions: A, B and C, as depicted in Figure 2, in order to take appropriate actions:

- **Condition A:** if the threshold power $P_{THy} \leq P_{g,max}$, and $P_g(t)$ exceeds P_{THy} , ENIGMA CSS triggers preliminary corrective actions to lower the generator power to be less than P_{THy} within approximately 5 s. These preliminary actions do not entail stringent actions such as load shedding and aim to reduce the probability of the generator overloading;
- **Condition B:** By setting the threshold power P_{THy} equal to (and not greater than) $P_{g,max}$, as soon as $P_g(t)$ exceeds P_{THy} , ENIGMA CSS must initiate stringent actions to lower the generator power below $P_{g,max}$ within 5 s. These actions may include an additional set of measures such as load shedding;
- **Condition C:** When $P_g(t)$ is less than P_{THy} and is therefore also less than $P_{g,max}$, ENIGMA CSS will not initiate any action and will let the local controllers of the subsystems perform their energy management roles. The CSS only works when there is an overload condition. If no overload is taking place—and if suitable conditions take place—the CSS can set the supercapacitor to recharge.

The threshold P_{THy} is used as a hysteresis to activate the CSS earlier before the maximum generator limit $P_{g,max}$ is reached, where the overloading of the generator happens. Condition B is obviously a subcase of Condition A when $P_{THy} = P_{g,max}$.

Based on this high-level description, three main operating stages of the ENIGMA CSS can be defined:

- **Normal stage:** the EPGDS is not subject to overload conditions and no CSS intervention is required. The CSS does not send any control actions to the SGN, ESRS, and PLB, and the supercapacitor of the ESRS is set to the recharge mode;
- **Overload management stage:** ENIGMA CSS detects an overload condition and is activated. The CSS manages the overload by coordinating the power consumption and the generation of the SGN and the ESRS, and the PLB ensures that the generators operate in safe conditions. The three subsystems are invoked in a specific order. The stage concludes when the overload condition disappears;
- **Recovery stage:** In this stage, which happens after the overload management stage, ENIGMA CSS recovers the SGN, ESRS, and PLB1 SDU subsystems and re-establishes them to their normal conditions, i.e., the conditions they were in before the overload occurred. The three subsystems are recovered in the opposite order to the one adopted in the overload management stage.

3. Iron Bird EPGDS Architecture

This section presents the Iron Bird EPGDS under study, as depicted in Figure 3, and its subsystems, namely the generators, primary power centers (PPCs), SGN(ASPIRE), ESRS(ESTEEM), and PLB1 SDU (IDEN). It describes how the ENIGMA CSS controller integrates within the EPGDS and how it interfaces with these subsystems. The functional simulation model of the EPGDS, as shown in Figure 3, has been developed in MATLAB Simulink 2017b. The simulation model will be used to verify the functionality and validity of the ENIGMA CSS algorithm, as will be shown in a later section.




Figure 3. Iron Bird EPGDS and its subsystems SGN(ASPIRE), ESRS(ESTEEM), PLB1 SDU.

3.1. The Generators, Batteries and PPCs

A total of two 21 kW primary generators (Gen 1, Gen 2) each interfaced with AC/DC power electronic converters (PEC) generate 270V controlled HVDC power to the high-voltage PPC (HV PPC). An external ground power source (EXT) may also be used to power the EPGCS. The batteries (BAT 1, BAT 2) supply power to the low-voltage PPC (LVPPC). The battery is modelled using the first order frequency response of a 28 V/44 Ah NiCd

battery. The HV PPC and the LV PPC simulation models emulate the functional behaviour of the physical HV PPC and the LV PPC devices, respectively. They open and close solid state power controllers (SSPCs) and relays according to external activation signals. The models also provide current and voltage measurements as well as the activation state of the different SSPCs and relays.

3.2. Smart Grid Network (SGN)

The EPGDS consists of a decentralized, modular and flexible smart grid network. The SGN, when coupled with E2-EM functionalities, aims to achieve substantial improvements in system efficiency, safety, power quality, and eco-friendliness compared to existing solutions. The Clean Sky project ASPIRE [15] developed DC/DC dual active bridge bidirectional converter units for the four cells of the SGN. It also developed and implemented advanced EM control approaches to optimally manage the distribution of power among the four cells and for selecting the operating mode (step-up or step-down mode) for the individual cells. When interfaced with the ENIGMA CSS controller, the SGN can assist in reducing or even deleting the overload capabilities of the main generators, thus saving weight for electrical machine integration.

The normal operating mode of the SGN cells is the step-down mode used to charge the batteries and to feed the LV loads. The reversal or step-up mode of the cells is only used in case of emergency; it is enabled when one generator is in fault, the healthy generator is in overload, and at least one HV load has a priority greater than one or both LV busbars. During the reversal mode, one or both batteries are discharged. The SGN cannot manage the loads connected to the discharging battery. The reversal mode is allowed as long as one or both batteries have a state of charge (SOC) greater than the minimum allowed SOC.

The SGN can also work with a reduced number of cells in case one or more cells are in fault with some loads underpowered or if the required power is greater than the available power.

3.3. Energy Storage and Regenerative System (ESRS)

The ESRS in the Iron Bird EPGCS, developed within the Clean Sky project ESTEEM [16], consists of a regenerative electro-mechanical actuator (EMA) and an embedded supercapacitor (SC) energy storage device. The smart energy management developed for the EMA contributes to two key capabilities of the ESRS. First, it smooths the generator power profile when a sudden variation in the EMA current demand occurs. It also provides power to the grid in the case of generator overload, which is in coordination with the ENIGMA CSS controller.

3.4. Programmable Load Bank 1 Secondary Distribution (PLB1 SDU)

The PLB1 SDU is used to interface the 270 V DC-bus with the PLB 1, as depicted in Figure 3. The PLB1 SDU is equipped with a DC/DC controller to control and manage the power to the PLB1. Of note is that the EPGDS comprises two other PLBs, namely PLB 2 and PLB 3. In contrast to PLB1, the loads PLB 2 and PLB3 are not controlled independently by an SDU DC/DC converter but are connected directly to the high voltage (HV) bus, as depicted in Figure 3.

The PLB 1, rated at 270 V/15 kW, is connected to HV Bus 1 through a SDU. The PLB 2, rated at 270 V/15 kW, is connected to HV Bus 2 while the PLB3, rated at 270 V/8 kW, is connected to the HV Emergency Bus. The PLB1 SDU and the corresponding DC/DC converter are being developed under the Clean Sky project IDEN [17]. The key capability of the PLB1 SDU is to achieve load chopping and load shedding for energy management purposes. During load chopping, the power supplied to the PLB 1 may be reduced from 15 kW down to 13 kW by reducing the voltage from 270 V to 250 V by means of a DC/DC PEC located within the PLB1 SDU. Similarly, the power to the PLB1 may be increased from 13 kW up to 15 kW by increasing the voltage.

3.5. ENIGMA CSS within the EPGCS

The subsystems of the EPGCS, namely the SGN, PLB1 SDU, and ESRS, are smart systems with their own local controllers. The ENIGMA high-level supervisory controller sends appropriate control signals in the form of power set points to the local controllers of the aforementioned subsystems to achieve its EM objective. This will be further elaborated upon in the next section.

3.6. Iron Bird–CSS Communication Protocol and ENIGMA Firmware

The Iron Bird uses a CAN bus for communication between the different elements of the system, including ENIGMA CSS, SGN, ESRS, and PLB1 SDU. A number of items for monitoring information are exchanged on the CAN bus, such as generator current and energy storage states of charge. CAN is a multi-master (peer-to-peer) communication system where all systems broadcast messages regarding their status or decisions, and each system chooses the messages that are relevant to its operation. Each message has a priority. If messages collide, the higher priority message will be re-sent, while the lower priority message will be slightly delayed before being re-sent.

The ENIGMA CSS will utilise information about the current power requirements on the CAN bus, including information regarding any generator overloads and the status of the SGN, ESRS, and PLB1 SDU to make real-time decisions for the EPGCS. It will then broadcast these decisions as supervisory commands to the relevant subsystems. ENIGMA has to solve real-time optimization problems while simultaneously receiving and transmitting CAN messages and processing this information in the background.

Model based design (MBD) has been used in the implementation of the ENIGMA CSS; it was vital that the ENIGMA CSS be able to interface with software tools such as MATLAB/Simulink for this purpose. For the consideration of software and hardware implementation requirements, such as fixed-point and timing behavior, automatic code generation has been used for embedded deployment and to create test benches for system verification. This saves time and avoids the introduction of manually coded errors. The use of MBD and automated code generation means that it is possible to target different processors and architectures without re-writing code as well as to profile and verify embedded code on microcontrollers.

4. E2-EM Algorithm and Logics

This section describes the E2-EM algorithm and logic. An optimization-based approach has been selected for the mathematical formulation of the energy management control algorithm to account for the individual system performance and constraints, the global energy system performance and the overall system power balance. To formulate the optimization problem, it is important to have online and offline knowledge about the EPGDS and its subsystems, to identify the feasibility constraints, and to define the intended objective function. Moreover, we consider the constraints induced by the bounds for the set points and system variables and the constraints due to the dynamic behaviour of the storage and power actuation. The mathematical formulation is important for the scalability of the solution. With a well-formulated optimization problem, future subsystems can be added, and new rules can be derived based on the established procedures.

This section first describes the mathematical models and constraints for the SGN, ESRS, and PLB1 SDU subsystems. It then explains the CSS optimization formulation and finally describes the E2-EM logic and heuristics.

4.1. System Models and Constraints

This subsection describes the mathematical models of each of the controllable subsystems SGN, ESRS, and PLB1 SDU.

4.1.1. Energy Storage and Regeneration System

As described in the earlier section, the ESRS consists of an EMA and a supercapacitor. During an overload, ENIGMA CSS sends a signal to the ESRS, and the supercapacitor provides power to the EPGDS. When the overload is cleared, ENIGMA CSS sends another signal to the ESRS to recover and return to the nominal condition (i.e., to the state prior to the overload).

The dynamic model of the supercapacitor state of charge (SOC) at time $(t + 1)$ can be modelled as

$$SOC_E(t + 1) = SOC_E(t) - \frac{P_E(t) \cdot T_s}{CAP_E} \quad (1)$$

where t (s) is the current discrete time instant (which is a multiple of the sampling time T_s), $P_E(t)$ (W) represents the instant power reference signal sent by ENIGMA CSS to the ESRS, CAP_E (J) is the energy capacity of the supercapacitor, and $SOC_E(t)$ (%) represents the SOC at time (t) . The $SOC_E(t)$ and $P_E(t)$ are limited by their physical characteristics, so the following constraints are added:

$$SOC_E \leq SOC_E(t) \leq \overline{SOC_E} \quad (2)$$

$$P_E \leq P_E(t) \leq \overline{P_E}. \quad (3)$$

where SOC_E and $\overline{SOC_E}$ are the minimum and maximum of the $SOC_E(t)$, respectively, and P_E and $\overline{P_E}$ are the minimum and maximum values of $P_E(t)$, respectively. The convention considered in this work is that when $P_E(t) > 0$, the supercapacitor yields power, i.e., discharges, and when $P_E(t) < 0$, the supercapacitor absorbs power, i.e., charges.

In condition of a fault (when $\delta_E(t) = 0$ as explained below), the set point $P_E(t) = 0$; thus, Equation (3) can be written as

$$P_E \cdot \delta_E(t) \leq P_E(t) \leq \overline{P_E} \cdot \delta_E(t), \quad (4)$$

where $\delta_E(t) \in \{0, 1\}$ is a binary signal sent to ENIGMA CSS by the ESRS that represents the health state of the module, i.e., whether the ESRS is faulty or not (0 = fault, 1 = nominal state). If we replace Equations (1) in (2):

$$SOC_E \leq SOC_E(t) - \frac{P_E(t) \cdot T_s}{CAP_E} \leq \overline{SOC_E} \quad (5)$$

An additional signal state of device $SOD_E(t)$ that describes failure conditions of the ESRS is introduced. It is a code that provides information about the status of the ESRS. The value of $SOD_E(t)$ is “0” when the ESRS is functioning properly, “1” during an over voltage, “2” during an under voltage, “3” during high temperature condition, and “4” during a converter failure.

Remark 1. The supercapacitor may be recharged by setting $P_E(t) = -1$. The recharging can be enabled by ENIGMA CSS if two conditions are met:

- i. No overload is taking place;
- ii. $P_g(t) \leq P_{g,max} - P_{E,r}$.

where $P_{E,r}$ (W) represents a design parameter (safety margin) of the ESRS. The second condition is used as safety constraint to ensure that the supercapacitor charging does not start close to $P_{g,max}$ since this could cause the generator power to exceed this maximum and could cause the system to overload again. When the CSS is operating in the overload management stage, no recharge can take place.

4.1.2. Programmable Load Bank1 Secondary Distribution Board

During an overload, the ENIGMA CSS sends a power set point $P_I(t)$ to the PLB1 SDU. Through voltage chopping action, the PLB1 SDU may reduce its actual power consumption by a value equal to $P_I(t)$. Due to limitations inherent in the PLB1 SDU controller, the power set points are bounded between a minimum value P_I and a maximum value $\overline{P_I}$; hence, $P_I \leq P_I(t) \leq \overline{P_I}$. Considering the functional state of the PLB1 SDU, the aforementioned equation can be rewritten as

$$\delta_I(t) \cdot P_I \leq P_I(t) \leq \overline{P_I} \cdot \delta_I(t) \quad (6)$$

where $\delta(t) \in \{0, 1\}$ is a binary signal sent to ENIGMA CSS by the PLB1 SDU that represents the state of the PLB (0 = faulty state, 1 = normal state).

4.1.3. Smart Grid Network

The ENIGMA CSS sends a power reference signal $P_A(t)$ to the SGN to activate and resolve an overload in coordination with the other two subsystems (PLB1 SDU and ESRS) during an overload condition. The SGN can thus be called to provide additional support to reduce an EPGDS overload condition. To achieve this, the SGN locally controls and actuates the DC/DC converters such that the generator's power is maintained under the overload threshold. Similar to the ESRS and PLB1 SDU subsystems, the SGN communicates its fault condition through the use of a binary signal δ_A to the ENIGMA CSS. The value of δ_A can be either "0" when the SGN is operating normally or "1" when the SGN has a fault. The power reference signal $P_A(t)$, which has a minimum value of zero and a maximum value $\overline{P_A}$, can be expressed in terms of δ_A as

$$0 \leq P_A(t) \leq \overline{P_A} \cdot (1 - \delta_A(t)) \quad (7)$$

The signal sent by the ENIGMA CSS to the SGN corresponds to a power reference value. The SGN controller algorithm is coded such that it triggers appropriate actions for the SGN that is connected to the batteries to provide the necessary power such that the generator power does not exceed that power reference level. In the event that the ENIGMA CSS either does not require the SGN to support the overload clearing or needs to re-establish the SGN back to its normal state after an overload, it sends a signal with the high value "255" to the SGN.

4.2. CSS Optimization Formulation

The previous sections defined the mathematical models and feasibility constraints for the power resources that the CSS needs to monitor and coordinate. The objective function of the CSS optimization formulation can now be defined. The E2-EM has to maintain the power balance in the EPGDS in addition to resolving the overload. This can be interpreted as balancing the difference between the total generated power of the N_g generators $P_g(t)$ and the overload threshold value P_{THy} , i.e., $P_g(t) - P_{THy}$. The total power of the N_g generators can be given as

$$P_g(t) = \sum_{i=1}^{N_g} \delta_{gi}(t) \cdot P_{gi}(t) \quad (8)$$

where $P_{gi}(t)$ is power of the i th generator, and $\delta_{gi}(t)$ is a binary status value sent to ENIGMA CSS by the generators representing the availability of the i th generator and is assigned "0" if the generator is faulty or as "1" if the generator is healthy. Since the EPGDS of the aircraft under study is equipped with two generators $N_g = 2$, the power balance of the system is given by

$$\delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy} = P_E(t) + P_I(t) + P_A(t) \quad (9)$$

where $P_A(t)$, $P_E(t)$, and $P_I(t)$ are the ENIGMA CSS power set points to the SGN, ESRS, and PLB1 SDU subsystems, respectively. Equation (9) states that the difference between the generated power and the overload threshold value can be balanced by using extra power from the SGN, ERSN, and PLB subsystems.

Before proceeding to the CSS optimisation formulation, it is important to introduce the quantity $\Lambda_E(t)$, which will be used for the algorithm formulation:

$$\Lambda_E(t) = \delta_E(t) \cdot \gamma_E(t) \text{ where } \gamma_E(t) = \begin{cases} 1 & \text{if } SOD_E(t) = 0 \\ 0 & \text{otherwise} \end{cases}$$

The new quantity is used to ensure that the ESRS power constraint (4) holds only when the ESRS is in healthy condition, i.e., when $\delta_E(t) = 1$ or $SOD_E(t) = 0$ (shown in (11) below). Since Equation (9) must be satisfied at all times, we define the ENIGMA CSS optimization problem OP as:

$$\text{OP: } J = \min_{P_E(t), P_I(t), P_A(t)} [\delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}(t) - P_E(t) - P_I(t) - P_A(t)] \quad (10)$$

Which is subject to ((5), (6), and (7)):

$$\Lambda_E(t) \cdot P_E \leq P_E(t) \leq \overline{P_E} \cdot \Lambda_E(t) \quad (11)$$

For the optimization, $P_E(t)$, $P_I(t)$, and $P_A(t)$ are considered as the optimization variables while T_s , P_E , $\overline{P_E}$, SOC_E , $\overline{SOC_E}$, CAP_E , P_I , and $\overline{P_I}$ are known parameter values provided offline, and $\delta_E(t)$ and $\delta_I(t)$ are the online measurements made available from ESRS and PLB1 SDU, respectively, at each time instant t . The CSS OP, as shown in (10) and (11), is a mixed-integer linear programming (MILP) and can be solved using state-of-the-art MILP solvers. The OP is solved at each time instant t based on the system measurements and the known system parameters. The computed optimal power set points $P_E(t)$, $P_I(t)$, and $P_A(t)$ are then implemented in the system in a model predictive control (MPC) fashion. However, the computational complexity of solving a MILP and its limitations for real-time deployment prohibits directly deploying the OP for CSS implementation. The next section describes a method for simplifying the OP into heuristic rules that are compatible with real-time hardware deployment and that do not compromise the optimal performance of energy management.

Please note that the above formulation does not include any reference to the possibility of recharging the supercapacitor but instead focusses on the required actions for clearing overload conditions.

4.3. E2-EM Logic and Heuristics

In order to simplify the CSS OP, three assumptions are made:

Assumption 1. When an overload is detected, the CSS actuates the SGN, ESRS, and PLB1 SDU subsystems in a sequential manner, depending on their assigned priorities. The ESRS has the highest priority and will be the foremost solution in case of an overload condition. If the ESRS is unavailable or its power contribution is insufficient to clear the overload condition, the ENIGMA CSS calls the PLB as the next available subsystem to clear the overload. Further, if both the ESRS and the PLB are not available or not sufficient to resolve the overload condition; as a last resource, the SGN will be used to solve the overload condition.

Assumption 2. Only one set point is implemented at each sampling time.

Assumption 3. Only one-step ahead dynamics are considered given the uncertain and non-predictable nature of the overload conditions.

The above assumptions represent simplification to the E2-EM operation to allow for resource prioritization while considering uncertainties and real-time implementation limitations. The process described in Assumption 1 is depicted in Figure 4.




Figure 4. Flowchart of the system prioritization in the case of overloading conditions.

The E2-EM estimates the set point for the active system, and the set points for other inactive systems are considered to be inaccessible and out of scope. Based on these assumptions, the OP can now be simplified, avoiding the use of computationally expensive MILP algorithms.

4.3.1. ESRS Rule-Based Logic

If available, the ESRS is the foremost resource to be activated when an overload is detected. Since it is the only resource selected to support the overload or fault condition at this stage, both $P_I(t)$ and $P_A(t)$ are set to zero. The OP can then be written as

$$J = \min_{P_E(t)} [\delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}(t) - P_E(t)] \quad (12)$$

which is subject to

$$\Lambda_E(t) \cdot P_E \leq P_E(t) \leq \overline{P_E} \cdot \Lambda_E(t) \quad (13)$$

$$SOC_E \leq SOC_E(t) - \frac{P_E(t) \cdot T_s}{CAP_E} \leq \overline{SOC_E} \quad (14)$$

Since the objective function J represents the power balance for the system at each time t , it can be set to zero and solved with respect to P_E :

$$P_E(t) = \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}(t) \quad (15)$$

The bounds for $P_E(t)$ can be obtained by replacing (15) in (13):

$$\begin{aligned} \max \left(P_E, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}, \frac{CAP_E}{T_s} (SOC_E(t) - \overline{SOC_E}) \cdot \Lambda_E(t) \right) &\leq P_E(t) \\ &\leq \min \left(\overline{P_E}, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}, \frac{CAP_E}{T_s} (SOC_E(t) - SOC_E) \cdot \Lambda_E(t) \right) \end{aligned}$$

The aforementioned formulation implicitly covers two main aspects. First, through the $\max(\cdot)$ and $\min(\cdot)$ operators, it ensures the enforcement of constraint (13) and proper actuation of the set point $P_E(t)$ in the presence of low/high SOC conditions as defined through (14). Moreover, in the presence of an over/under voltage condition, we have $\Lambda_E(t) = 0$, and the variable $P_E(t)$ would be constrained to be 0.

Then, the CSS OP problem can be written in the following simplified rule-based logic:

Simplified Rule 1:

1. **IF** $\Lambda_E(t) == 0$
2. $P_E(t) = 0$
3. **ELSE**
4. $P_E = \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}(t)$
5. **IF** $P_E(t) \leq 0$
6. $P_E(t) = \max\left(P_E, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}(t), \frac{CAP_E}{T_s} (SOC_E(t) - \overline{SOC_E})\right)$
7. **ELSEIF** $P_E(t) > 0$
8. $P_E(t) = \min(\overline{P_E}, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}(t), \frac{CAP_E}{T_s} (SOC_E(t) - SOC_E))$
9. **END**
10. **END**

Note that this simplified control rule is only valid during an overload event and does not take into account the recovery of the ESRS when the overload is concluded. For the recovery, we assume the simple heuristic rule described in Remark 1, Section 4.1.1.

4.3.2. PLB1 SDU Rule-Based Logic

The same approach discussed for the ESRS is applied when the PLB1 SDU unit is activated. The PLB1 SDU is activated either when the ESRS is not available (i.e., $P_E(t) = 0 \forall t$) or when the contribution of the ESRS is not enough to cope with the overload condition acting on the power network (i.e., $P_E(t) = \overline{P_E}$). In both cases, the variable $P_E(t)$ acts as a constant offset to the overall power balance. Assumption 2 provides information about the set point of for the SGN, which is $P_A(t) = 0$. When the PLB1 SDU is activated, the objective function (10) and constraint (6) are considered along with the aforementioned parameter settings for $P_E(t)$ and $P_A(t)$. Equation (10), when solved for $P_I(t)$ and then substituted in (6), produces the following inequality:

$$\begin{aligned} & \max\left(P_I, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy} - P_E(t)\right) \cdot \delta_I(t) \leq P_I(t) \\ & \leq \min(\overline{P_I}, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy} - P_E(t)) \cdot \delta_I(t) \end{aligned}$$

Note that the presence of $P_E(t)$ provides an offset with respect to the overall power balance, irrespective of the value of the variable itself. The OP problem in this case can be written with the following simplified rule-based logic:

Simplified Rule 2:

1. **IF** $\delta_I = 0$
2. $P_I(t) = 0$
3. **ELSE**
4. $P_I(t) = \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy}(t) - P_E(t)$
5. **IF** $P_I(t) \leq 0$
6. $P_I(t) = \max\left(P_I, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy} - P_E(t)\right)$
7. **ELSEIF** $P_I(t) > 0$
8. $P_I(t) = \min(\overline{P_I}, \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy} - P_E(t))$
9. **END**
10. **END**

4.3.3. SGN Rule-Based Logic

Finally, the SGN system is activated when both the ESRS and PLB1 SDU are unavailable or cannot provide sufficient power to cope with the overload. The rule-based logic is given by:

Simplified Rule 3:

1. **IF** $\delta_A(t) == 1$
2. $P_A(t) = 0$
3. **ELSE**
4. $P_A(t) = \delta_{g1}(t) \cdot P_{g1}(t) + \delta_{g2}(t) \cdot P_{g2}(t) - P_{THy} - P_E(t) - P_I(t)$
5. **END**

Based on the above analysis, the CSS OP problem can be replaced by three simplified rule-based logic controls, which were summarized in the above simplified rules 1–3. The simplified rules are optimal when assumptions 1 to 3 hold. They simplify the implementation of the CSS control from a complex MILP optimization to a simple inequality and function evaluation. In order to test the optimality and performance of the proposed rule-based logic solution, a MIL study of the control algorithms is presented in the next section.

5. Model in the Loop Demonstration

This section investigates two case scenarios to demonstrate and validate the operation and performance of the ENIGMA CSS based on MIL simulations. The simulation models of the ENIGMA CSS and the Iron Bird EPGDS, as described in Section 2, which have been built in the MATLAB/Simulink modelling environment for the MIL demonstration.

5.1. Case Scenarios

During normal operation, the loads of the EPGDS, as depicted in Figure 3, are given in Table 1, whereby Generator 1 supplies 21 kW, and Generator 2 supplies 18 kW.

Table 1. Load distribution during the normal operation of EPGDS.

Loads and Generator	Power (kW)	Loads and Generator	Power (kW)
PLB 1	15	PLB 2	15
ESTEEM	0	LV load2	3
PLB 3	0		
LV Load 1	6		
Generator 1	21	Generator 2	18

The simulation is started at time 0.2 s. Both case scenarios assume that Generator 2 fails at time 0.4 s after the start of the simulation, causing Generator 2 to supply the total of 39 kW to the entire EPGDS. The two case scenarios consider different variations in the aircraft nominal load profile. In Case Scenario 1, a single overload event is considered, where the PLB3 load is activated and causes the EPGDS to go into overload, as shown in Figure 5a. In Case Scenario 2, the load profile representing the total load power of PLB2 and PLB3 are considered with two overload occurrences, as shown in Figure 5b. Both test cases aim to verify the capability of the ENIGMA CSS to address the overload in the EPGDS. In addition, Case 2 verifies that the ENIGMA CSS can coordinate with the ESRS to recharge the supercapacitors between the two overload events. The control parameter values used during the simulations are given in Table 2.




Figure 5. (a) Scenario 1, overload profile; (b) Scenario 2, overload profile; (c) Scenario 1, total generator power profile and controller overload detection, and resolution bounds; (d) Scenario 2, total generator power profile and controller overload detection and resolution bounds; (e) Scenario 1, CSS set points sent to ESRS, PLB1, and SGN; (f) Scenario 2, CSS set points sent to ESRS, PLB1, and SGN.

Table 2. Control parameter values.

Parameters	Value
Overload Threshold— P_{THy}	40 kW
ESRS maximum power set-point— $\overline{P_E}$	2 kW
PLB1 SDU maximum choppable power— $\overline{P_I}$	2 kW
SGN activation set-point— $P_{A,th}$	40

5.2. Simulation Results

5.2.1. Case Scenario 1

The total power of Generators 1 and 2 is shown in Figure 5c. At time 0.4 s, Generator 2 fails, and the total load 39 kW is supplied by Generator 1. At time 0.4 s, the generator power, being below the overload threshold of 40 kW, requires no action from the ENIGMA CSS. At time 0.5 s, a PLB3 load of 8 kW is activated, causing the total load of the EPGDS to increase from 39 kW to 47 kW, as shown in Figure 5a. This is also reflected in the Generator

1 power increasing from 39 kW to 47 kW, as shown in Figure 5c. The overload is detected when the Generator 1 power crosses the overload detection bound, as shown by the upper red dashed line in Figure 5c. The sudden spike on the generator profile observed at time 0.4 s when Generator 2 fails is due to the numerical error linked to the simulation solver.

The ENIGMA CSS activates the three subsystems sequentially by sending the set points given in Table 2 first to the ESRS; next, to the PLB1 SDU; and finally, to the SGN, based on the prioritisation in Figure 4 with a time difference of 0.01 s. The time difference is too small to be seen in Figure 5c. Figure 5e shows how the ESRS and the PLB1 SDU each supplies 2 kW to the EPGDS. The SGN is activated to supply the remainder of the 4 kW to the EPGDS. These actions cause the generator power to drop below the 40-kW upper threshold level at time 0.54 s, as seen in Figure 5e, thus clearing the overload well within 5 s, as required. After the overload clearing at time 0.65 s, the ENIGMA CSS sends signals to the aforementioned subsystems to restore them back to their normal operation, as shown in Figure 5e; the set points to the ESRS and the PLB1 SDU are 0 and those directed to the SGN are 255 instead of 40.

5.2.2. Case Scenario 2

This case scenario verifies whether the ENIGMA CSS allows for the supercapacitor of the ESRS to recharge when there are no overloads and when the generator power is below the overload threshold by more than a certain value, referred to as the safety margin, which is designed to avoid the EPGDS going straight back into overload. The variations in the total load profile of the EPGDS is considered as shown in Figure 5b, which depicts the overall variations of the load around its nominal value of 39 kW. Up to at time 0.2 s, the total load is 39 kW as shown in Figure 5b.

At time 0.4 s, the total load increases from 39 kW to 40.5 kW. The ENIGMA CSS detects an overload at time 0.4 s as the generator power exceeds 40 kW, as shown in Figure 5d, and sends a set point of 1.5 kW to the ESRS. Since the overload of 1.5 kW can be handled by the ESRS alone, the number of set points sent by the ENIGMA CSS to the PLB1 SDU is “0” and “255” for the SGN, as shown in Figure 5f. In this scenario, the SGN, ESRS, and PLB1 SDU are all available, but the overload conditions do not require their activation. It can be seen from the state of charge (SOC) profile in Figures 5f and 6 (black dashed line) that the supercapacitor charges from 0.2 to 0.4 s, at which point it stops charging and discharges to provide the requested power to the EPGDS.




Figure 6. SOC of the ESRS supercapacitor for scenario 2.

At time 0.6 s, the total load power decreases to 36.5 kW. The total generator power decreases below the overload threshold power, as shown in Figure 5d. Since the difference is more than the 1 kW, which is the set safety margin, the ENIGMA CSS sends the signal $P_E(t) = -1$ in order to start the recharge of the supercapacitor. The supercapacitor starts recharging, as seen at time 0.6 s in Figures 5f and 6.

A second overload occurs at time 0.8 s, where the total load power and consequently the Generator 1 power increase to 40.2 kW, which is above the overload threshold level of

40 kW, as depicted in Figure 5b,d respectively. At this point, the ENIGMA CSS detects an overload and sends a set point of 1.2 kW to the ESRS to counteract the new overload. The ESRS provides the requested power from time 0.8 s to 1 s when the overload is eliminated.

At time 1 s, the total load power decreases to 36.5 kW. Since the generator load power decreases below the overload threshold value by more than the safety margin, the ENIGMA CSS sends the signal to the ESRS to recover, enabling the supercapacitor to recharge, as seen at time 1 s in Figures 5f and 6.

At time 1.15 s, the total load power goes back to 39 kW, as in the nominal case. The total generator power is 39 kW, which is below the overload threshold value. No action is required from the ENIGMA CSS.

5.3. Test Results Analysis

The test results for the first case scenario have demonstrated that the ENIGMA CSS is able to clear an overload well within the 5 s time interval by activating the relevant subsystems to intervene in the correct order. It also verifies that the ENIGMA CSS can recover the three subsystems back to their normal conditions after the overload is cleared according to the defined activation sequence and priority.

The test results from the second case scenario have shown that in addition to taking the required actions to clear the overload within 5 s, the ENIGMA CSS sends the signal to the ESRS to recharge when the generator power is below the overload threshold by a value that is higher than the agreed upon safety margin.

Through the two test cases presented in this section, the MIL demonstration has verified and validated the behaviour and performance of the ENIGMA CSS.

6. Conclusions and Future Works

This work has described the E2-EM strategy adopted for the ENIGMA CSS based on the elimination of the 5 min generator overload capability. It has explained how the ENIGMA CSS interfaces with the low-level controllers of the SGN, the ESRS, and the PLB1 SDU subsystems to ensure that any overload is cleared within 5 s. The CSS has been tested by subjecting it to two case scenarios using model-in-the-loop (MIL) testing. The tests results demonstrate that the CSS took appropriate actions in coordination with the ESRS, SGN, and PLB1 SDU to first clear the overload within the required 5 s during the overload and then to re-establish the subsystems back to their normal states after the overload was cleared. The correctness of the CSS has thus been verified using the MIL demonstration. The CSS is currently undergoing hardware-in-the-loop (HIL) testing before it can be integrated into the Leonardo Aircraft Ground Demonstrator. The findings for that part of our work will be presented in a future publication.

Author Contributions: Conceptualization, S.S., S.R., B.G. and J.A.; methodology, S.S., M.T., S.R. and B.G.; software, M.T., J.A. and Y.H.; validation, S.S., M.T. and B.G.; formal analysis, M.T., J.A. and Y.H.; investigation, S.S. and M.T.; resources, F.C. and B.G.; data curation, S.S., B.G. and A.R. (Antonio Russo); writing—original draft preparation, Y.H., K.K. and M.T.; writing—review and editing, S.S., Y.H., K.K. and M.T.; visualization, K.K. and M.T.; supervision, M.T., S.R., S.B., J.A., A.R. (Alfredo Renzetti), F.C. and A.C.; project administration, K.K. and M.T.; funding acquisition, S.R., S.B., B.G. and F.C. All authors have read and agreed to the published version of the manuscript.

Funding: The project received funding under the European Union's Horizon 2020 research and innovation program under grant agreement No 101006771.

Acknowledgments: The authors would like to acknowledge Giorgio Manganini, GSSI, Scuola Universitaria Superiore, and Teju Darure, CNRS Perpignan, for the support in the MIL demonstration and result discussions.

Conflicts of Interest: The authors declare no conflict of interest.

References

1. Izquierdo, D.; Azcona, R.; del Cerro, F.J.L.; Fernandez, C.; Delicado, B. Electrical Power Distribution System (HV270DC), for Application in More Electric Aircraft. In Proceedings of the 2010 Twenty-Fifth Annual IEEE Applied Power Electronics Conference and Exposition (APEC), Palm Springs, CA, USA, 24–25 February 2010; pp. 1300–1305.
2. Schlabe, D.; Lienig, J. Energy management of aircraft electrical systems—State of the art and further directions. In Proceedings of the 2012 Electrical Systems for Aircraft, Railway and Ship Propulsion, Bologna, Italy, 16–18 October 2012; pp. 1–6. [CrossRef]
3. I-PRIMES: An Intelligent Power Regulation Using Innovative Modules for Energy Supervision. Available online: <https://cordis.europa.eu/article/id/173624-smart-control-of-aircraft-electrical-loads> (accessed on 15 March 2021).
4. More Open Electrical Technologies (MOET). Available online: <https://cordis.europa.eu/project/id/30861> (accessed on 15 March 2021).
5. EPOCAL: An Electrical POver Center for Aeronautical Loads. Available online: <https://cordis.europa.eu/project/id/323408> (accessed on 15 March 2021).
6. Cavallo, A.; Canciello, G.; Guida, B. Energy Storage System Control for Energy Management in Advanced Aeronautic Applications. *Math. Probl. Eng.* **2017**, *2017*, e4083132. [CrossRef]
7. Canciello, G.; Cavallo, A.; Guida, B. Control of Energy Storage Systems for Aeronautic Applications. *J. Control Sci. Eng.* **2017**, *2017*, e2458590. [CrossRef]
8. Saenger, P.; Deschinkel, K.; Devillers, N.; Pera, M. An Optimal Sizing of Electrical Energy Storage System for an Accurate Energy Management in an Aircraft. In Proceedings of the 2015 IEEE Vehicle Power and Propulsion Conference (VPPC), Montreal, QC, Canada, 19–22 October 2015; pp. 1–6. [CrossRef]
9. Zhang, H.; Mollet, F.; Saudemont, C.; Robyns, B. Experimental Validation of Energy Storage System Management Strategies for a Local DC Distribution System of More Electric Aircraft. *IEEE Trans. Ind. Electron.* **2010**, *57*, 3905–3916. [CrossRef]
10. O’Connell, T.; Russell, G.; McCarthy, K.; Lucas, E.; Zumberge, J.; Wolff, M. Energy Management of an Aircraft Electrical System. In Proceedings of the 46th AIAA/ASME/SAE/ASEE Joint Propulsion Conference & Exhibit, Nashville, TN, USA, 25–28 July 2010. [CrossRef]
11. Saenger, P.; Devillers, N.; Deschinkel, K.; Péra, M.; Couturier, R.; Gustin, F. Optimization of Electrical Energy Storage System Sizing for an Accurate Energy Management in an Aircraft. *IEEE Trans. Veh. Technol.* **2017**, *66*, 5572–5583. [CrossRef]
12. Rubino, L.; Iannuzzi, D.; Rubino, G.; Coppola, M.; Marino, P. Concept of Energy Management for Advanced Smart-Grid Power Distribution System in Aeronautical Application. In Proceedings of the 2016 International Conference on Electrical Systems for Aircraft, Railway, Ship Propulsion and Road Vehicles International Transportation Electrification Conference (ESARS-ITEC), Toulouse, France, 2–4 November 2016; pp. 1–6. [CrossRef]
13. AC 21-38 v2.0—Aircraft Electrical Load Analysis and Power Source Capacity 2017. Available online: <https://www.casa.gov.au/files/021c38pdf> (accessed on 30 June 2021).
14. Canciello, G.; Cavallo, A.; Guida, B. Robust Control of Aeronautical Electrical Generators for Energy Management Applications. *Int. J. Aerosp. Eng.* **2017**, *2017*, e1745154. [CrossRef]
15. ASPIRE: Facilitating Europe’s Aspirations for Electric Flight. Available online: <https://www.cleansky.eu/aspire-facilitating-europes-aspirations-for-electric-flight> (accessed on 30 June 2021).
16. ESTEEM Project: Advanced Energy STorage and Regeneration System for Enhanced Energy. Available online: <https://cordis.europa.eu/project/id/755485> (accessed on 30 June 2021).
17. IDEN Project: Innovative Distributed Electrical Network. Available online: <https://cordis.europa.eu/project/id/821328> (accessed on 30 June 2021).