Article

Impact of an Ultraviolet Reactor on the Improvement of Air Quality Leaving a Direct Evaporative Cooler

Wonjun Kim ¹, Hye-Won Dong ¹, Junseok Park ¹, Minki Sung ² and Jae-Weon Jeong ^{1,*} ¹ Department of Architectural Engineering, Hanyang University, Seoul 04763, Korea;

wuwtc@naver.com (W.K.); hwdong3@hanyang.ac.kr (H.-W.D.); junpark@hanyang.ac.kr (J.P.)

² Department of Architectural Engineering, Sejong University, Seoul 05006, Korea; mksung@sejong.ac.kr

* Correspondence: jjwarc@hanyang.ac.kr; Tel.: +82-2-2220-2370

Received: 17 March 2018; Accepted: 5 April 2018; Published: 9 April 2018

Abstract: The purpose of this study is to improve microbial air quality by improving water quality, particularly concerning microbiological aspects, by applying an ultraviolet water purifier system to a direct evaporative cooling (DEC) system. A direct evaporative cooler is an air cooling technique that uses the evaporation of water. Most DEC systems recirculate water to reduce water use. Evaporative cooling pads and water are biologically contaminated by recirculating water. This contamination can develop into air contamination and cause respiratory illnesses in occupants. It is necessary to use sterilized water in a DEC to prevent respiratory diseases and maintain air quality. In this study, we examine whether improvements in water quality in a DEC affect air quality by dividing experiments into a control group (Control) and a treated group (UV-treated). In the control group, the degree of contamination was measured when a DEC operated for four weeks without ultraviolet water treatment. In UV-treated, the degree of contamination was measured when UV water treatment was applied to a DEC for four weeks. In both Control and UV-treated, microbes were sampled from the water, the evaporative cooling pad surface, and the DEC inlet and outlet air samples in order to compare the levels of contamination. The surface was measured once at four points, and the air was measured four times at two points. A comparison of the two experiments indicated that the degree of microbial contamination of water and air was significantly reduced in the UV-treated group when compared to that in the control group. When the pollution degree of the evaporative cooling pad was compared to the degree of air pollution, it was difficult to obtain a correlation between the two factors, although the results confirmed that the contamination of the evaporative cooling pad caused water pollution. Therefore, it is necessary to operate a water treatment system to maintain the clean air in DEC systems.

Keywords: direct evaporative cooler; ultraviolet reactor; indoor air quality; microorganism; water sterilization

1. Introduction

Evaporative cooling technology is a non-vapor compression heating, ventilating, and air conditioning (HVAC) technology that is used as to simultaneously induce the adiabatic cooling of process air with the evaporation of water by performing a heat exchange with water and process air [1]. Several studies focus on environmentally-friendly technology that cools the air without using refrigerants [2–5]. One of these evaporative cooling technologies is an indirect evaporative cooler (IEC), which consists of two channels of plastic material: On the secondary air channel, adiabatically cooled air exchanges sensible heat with process air and on the primary air channel, cools the process air. Another one of these technologies is a direct evaporative cooler (DEC), which is a device that induces adiabatic cooling by passing air through an evaporative cooling pad of wet cellulosic material. Finally,

indirect-direct evaporative cooler (IDEC) uses IEC and DEC collectively and is a typical evaporative cooling technology [6].

A cooling tower and an evaporative condenser form a system that chills cooling water by using evaporative cooling, based on a principle similar to a DEC. It is necessary for the cooling tower, evaporative condenser, and a DEC to provide sufficient water to facilitate adiabatic evaporation. Water is recirculated in most systems to reduce water consumption. However, recirculating water used in cooling towers and evaporative condensers leads to the accumulation of microbial contamination. This type of contamination causes respiratory diseases such as Legionnaires' disease and may result in casualties [7–9]. *Legionella* bacteria were observed in a dehumidification system by using a lithium chloride solution, according to a principle similar to that of a direct evaporative cooling system [10].

Legionnaires' disease occurs when water-borne *Legionella pneumophila* bacteria are transferred by aerosols and adhere to the lungs. The functioning of direct evaporative coolers is similar to that of cooling towers and evaporative condensers. However, there has been no known outbreak of Legionnaires' disease through direct evaporative coolers. This is potentially due to two main reasons. The first is temperature conditions in which it is difficult to activate *Legionella* bacteria. Cooling towers and evaporative condensers exhibit higher water temperatures when compared to those in a DEC during operation. Most DEC's operate at water temperatures of 20–24 °C. *Legionella* bacteria do not multiply in a dormant state at temperatures below 20 °C and are active at 20–45 °C [11]. Therefore, it is difficult to proliferate *Legionella* bacteria in a direct evaporative cooling system (DEC). In areas requiring direct evaporative cooling, the wet bulb temperature is below 25 °C. In DEC, the wet bulb temperature of inlet process air, dry bulb temperature of outlet process air, and temperature of recirculating water are almost equal, thus the DEC is operating at a temperature at which *Legionella* does not reproduce [12].

The second reason is that the droplet size in a direct evaporative cooler is very low. The size of *Legionella* is 0.3–0.9 µm wide and 2–20 µm long. For *Legionella* to stick to the lungs, it must enter the lungs through droplets with a diameter less than 5 µm (i.e., aerosol). The size of water droplets produced by the direct evaporative cooler differs based on the type of evaporator, however; small water droplet evaporates and the larger is difficult to stick to lungs [13].

Legionnaires' disease is unlikely to occur due to the operation temperature range and the droplet sizes in a DEC. However, temperature varies within an annual HVAC system, and other microbes in addition to *Legionella* also lead to air pollution [14].

Several researchers have confirmed that water contamination by microorganisms diffuses into the air and causes pollution in a DEC's. Macher and Girman [15] measured the microbial contamination of a sump, indoor air, and outdoor air when DEC's was used, and confirmed a correlation between sump contamination and indoor air quality. Strindehag and Josefsson [16] compared the bacterial counts of humidified air released from a spray type humidifier and an evaporative humidifier in experiments and simulations that added *Pseudomonas aeruginosa* to water. Macher et al. [17] used tracer bacteria (i.e., *Micrococcus luteus*) to determine the number of microorganisms detected in the discharge air based on the microbial air volume.

The United States Environmental Protection Agency has registered several water biocides to control algae, slime, and bacteria growth in cooling towers, air washers, and evaporative condensers. However, when water biocides are used in DEC's, hazardous residual gases and by-products generated by the biocide enter spaces in conjunction with the process air, and this is hazardous to occupants [6]. Therefore, various methods were examined to solve the problem.

Several studies focused on efforts to prevent contamination of DEC outlet air. Kang and Kato [18] experimented with microwave disinfection of elements in an evaporative humidifier (EH) by using *Legionella*'s germicidal effect temperature characteristics (it is difficult for *Legionella* to survive at temperatures exceeding 60 °C). The EH pad was heated to 60 °C for 12 min without a blower and water spray. However, the results confirmed that temperature distribution was irregular, irrespective of wetness, and was not suitable for disinfecting an EH pad. Sung et al. [19] experimented with UV lamps

and a water filter to suppress microbial growth of EH. The results confirmed that the microorganisms on the surface of the element, microorganisms inside the air handling unit (AHU), and pollutants in the recirculating water were significantly reduced when an ultraviolet sterilizer was used, although the internal microorganisms of the element were not removed. It is also difficult to disinfect an EH pad surface by using a UV lamp or a microwave. Additionally, degradation may occur after a certain period of time and cause defects in the equipment.

UV reactors are specifically used to treat drinking water, wastewater, industrial process water, and ballast water by exposing flowing water to the light of a UV lamp, thus inactivating the microorganisms in water. There is no residual effect, and chemicals are not added once the water leaves the UV reactor [20]. Yamamoto et al. [21] confirmed the killing rate of *Legionella*, based on a dose of UV light when a UV sterilizer generating a wave length of 254 nm was used. The results of the experiments confirmed that a UV sterilizer could be used to control *Legionella* in a cooling tower.

In this study, the experiments confirmed that the microbial contamination of a DEC improved when the disinfected water was supplied to the direct evaporative cooling system using a UV reactor.

2. Experimental Methods

2.1. System Overview

The system consists of an environmental chamber, DEC, a recirculation pump, a sump, a UV reactor, and a fan, as shown in Figure 1.

Figure 1. Schematic diagram of the direct evaporative cooling system.

The process air was pre-filtered and conditioned in an environmental chamber and supplied to the DEC. The air temperature and humidity conditions of the environmental chamber were set as dry bulb temperature (DBT) 30 °C and wet bulb temperature (WBT) 20 °C based on the DEC experiment recommended range in ASHRAE [22].

The evaporative cooling pad (CELdek®7060-15, Munters, Stockholm, Sweden) had a corrugated shape, and the material was composed of cellulose. The evaporative cooling pad size was 300 mm × 400 mm × 500 mm. There were four nozzles that supplied water to the DEC, which sprayed water at 120°. The size of the sump was 40 L, and this was responsible for the water usage per day without make-up water.

The UV reactor was a typical commercial UV sterilization system (Min-3), with a UV lamp that irradiated and sterilized running water. Specifically, Min-3 provided an ultraviolet dosage exceeding 30,000 $\mu\text{Ws}/\text{cm}^2$ during the operation. The system was sufficient for water treatment given that the ultraviolet dosage required for 99% inactivation of *L. pneumophila* and *Bacillus subtilis* spores is 12,300 and 22,000 $\mu\text{Ws}/\text{cm}^2$, respectively. In the experiment, the piping of the UV reactor was designed in two ways. The valve was adjusted to pass or bypass the UV reactor. Figure 2 shows the direct evaporative cooling system combined with the UV reactor, as well as the piping configuration. Detailed specifications for the UV reactor are shown in Table A1.

Figure 2. Direct evaporative cooling system and UV reactor.

2.2. System Operation Method

The system operated from 9:00 a.m. to 6:00 p.m. on weekdays, according to the occupancy schedule of ASHRAE 90.1 [23]. As recommended in the ASHRAE guidelines, the water used for the DEC was drained after a day of operation and fresh water was used on the next day. To reduce microbial growth in the evaporative cooling pad, the pad had to remain dry while the DEC was not in operation. Therefore, the recirculation pump was turned off and the fan was turned on for 30 min after the system operation was finished [12].

2.3. Sampling Method

Experiments were divided into a control group not using a UV reactor (Control) and an experimental group using a UV reactor (UV-treated). Table 1 shows the number of sampling times and sampling points during the operation periods in the Control and UV-treated experiments.

Table 1. Bio-contamination sampling cases.

Case	Operation Period	Number of Samplings	Number of Samples by Sample Type
Control (Not using UV reactor)	4 Weeks	2 Times/Week	Water: 1 point Surface: 4 points Air: 2 points
UV-treated (Using UV reactor)	4 Weeks	2 Times/Week	Water: 2 points Surface: 4 points Air: 2 points

Both the Control and UV-treated cases involved sampling air, water, and surface twice a week for four weeks. The sampling positions based on the sample objects are shown in Figure 3.

Figure 3. Sampling position in direct evaporative cooling system (DEC) (water, air, and surface).

Evaporative cooling pads, nozzles, and pipes were sterilized with hydrogen peroxide water two days before the experiment to ensure that the conditions for Control and UV-treated cases were identical.

2.3.1. Water Sampling

A sample cock was installed to sample the water supplied to the DEC. The sample cock was sterilized with alcohol to prevent cross-contamination during water sampling. The sample cock was opened, 1 L of water was drained, and water was sampled from the sample bottle. In UV-treated cases, the water treated by the UV reactor and the bypassed water were separately sampled by using the valve control.

2.3.2. Surface Sampling

There are several methods to collect surface microorganisms (such as the Rodac plate method, the tape lift method, and the swab method). However, the Rodac plate method and the tape lift method are not suitable for sampling corrugated evaporative cooling pads. In the experiment, swabs were inserted into the wrinkled holes to sample internal microorganisms. There was one sampling point at the inlet and outlet of the evaporative cooling pad, respectively, and two points at the top of it. Inlets and outlets were measured at specific holes at a height of 35 cm from the bottom of the evaporative cooling pad.

2.3.3. Air Sampling

An impactor air sampler (i.e., BUCK BioCulture Model B30120 [24]) was used to detect microorganism contaminants in the process air. The specifications of the air sampler are summarized in Table 2.

Table 2. Specification of the bio-contaminants air sampler [24].

Device	Type	Characteristics	
Bio-contaminants sampler	Impactor type	Detection flow	30 to 120 L/min
		Compatibility	90 mm agar plate
		Detecting accuracy	±5% of set point
		Holes	380 (1 mm diameter)

The calibration of the air sampler was performed for every experiment to improve the accuracy of microbial counting. At the sampling time, the sample should not have been affected by air other than process air. In the experiment, an acrylic chamber was installed in the flexible duct upstream and downstream of the DEC. Air sampling was measured in an installed acrylic chamber. The size of the acrylic chamber was 20 cm × 20 cm × 25 cm. Prior to sampling, the disinfectant (ethanol, 70% volume fraction) was sprayed onto the acrylic chamber and air sampler to prevent cross-contamination. Four agar plates (with two different sampling times that were analyzed in parallel) were used per sample. The fungi and bacteria of the inlet and outlet air were simultaneously sampled (Figures 1 and 3) [25,26]. The sampling time of the air sampler were set as 1 min and 2 min for bacteria and as 1 min, 2 min, and 5 min for fungi.

Samples (agar plate, water, cotton swab) were maintained below 25 °C to prevent growth after sampling. In the experiment, the samples were stored in insulated and refrigerated containers during transfer to the incubator. Table 3 shows the sampling and culture methods of bacteria and fungi in air, water, and on the surface.

Table 3. Sampling and incubation details of microbial contamination.

Sample Type	Sample Material	Sampling Method	Agar and Petri Film	Incubate Temperature	Incubate Times
Bacteria	Water	Sterile sample bottle	AC Film	32 °C	3 Days (72 h)
	Surface	Swab method	AC Film		
	Air	Impactor air sampler	TSA		
Fungus	Surface	Swab method	YM Film	25 °C	5 Days (120 h)
	Air	Impactor air sampler	PDA		

* AC Film: Aerobic count plate, indicator that facilitates colony enumeration. * YM Film: Yeast and mold culture film. * TSA: Trypticase soy agar. * PDA: Potato dextrose agar.

3. Results

The DEC operated for eight weeks under the conditions listed in Table 4. The direct saturation effectiveness of the DEC was derived by Equation (1) as follows:

$$\varepsilon_{DEC} = 100 \times \frac{DBT_{in} - DBT_{out}}{DBT_{in} - WBT_{out}} \quad (1)$$

Table 4. Operating details and conditions of the DEC.

Air Handling System	Direct Evaporative Cooling System
Operating time	9:00 a.m.–6:00 p.m.
Supply air flow rate	300–370 m ³ /h
Face velocity	0.75–0.88 m/s
Inlet air temperature	28–32 °C
Outlet air temperature	19–22 °C
DEC cooling effectiveness (ϵ_{DEC})	95–98%
Sump water temperature	21–26 °C
Water flow rate	5–6 L/min

3.1. Water Bio-Contamination

Bacterial contamination of recirculating water was measured by dividing it into three types of samples as follows: The first water sample was the water collected from the sump (in Control, not UV-sterilized), the second water sample was the water collected through the evaporative cooling pad (in UV-treated, it was UV-sterilized and sampled at the outlet of the evaporative cooling pad), and the third water sample was the water collected prior to passing through the evaporative cooling pad (in UV-treated, it was UV-sterilized and sampled before passing through the evaporative cooling pad). There were significant variations in the bacterial contamination of recirculating water in the first, second, and third water samples. The first and second water samples were cultured and the bacteria counts were obtained from the 10^{-4} dilutions because the contamination was high. In the third water sample that was passed through the ultraviolet reactor, the contamination was relatively low, and it was cultured after it was diluted twice. Figure 4 shows the bacterial contamination counts for the three types of water samples during the operation of the DEC.

Figure 4. Bacteria contamination of water from Control and UV-treated samples.

As shown in Figure 4, the number of colonies per 1 mL of the first water sample was approximately 3 to 43 times that of the second water sample. The second water sample was 1.1 to 480 times that of the third water sample. Water-borne bacteria colonies in the 3-1 Control case accidentally decreased. This

could be because the running water, which was outside of our control, was used in every experiment. This could mean that the temperature and quality of the water could have varied and influenced this result.

3.2. Surface Bio-Contamination

In both Control and UV-treated cases, the results confirmed that the surface microbial contamination of the evaporative cooling pad during the operation of the DEC. Figures 5 and 6 are graphs that show the average number of bacterial and fungal colonies sampled at four sites on the evaporative cooling pad for four weeks.

Figure 5. Bacterial contamination of the evaporative cooling pad surface in the Control and UV-treated samples.

Figure 6. Fungal contamination of the evaporative cooling pad surface in the Control and UV-treated samples.

Based on the surface microbial contamination data of the Control and UV-treated samples, we confirmed the correlation between ultraviolet water treatment and surface microorganisms by performing a *t*-test. In the case of bacteria, the average contamination in Control samples was 182.7, and the average contamination in UV-treated cases was 157.2. Control cases displayed 25.5 times the contamination of UV-treated samples, although this was not statistically significant (*p*-value = 0.602). However, in the case of fungi, the average contamination in Control cases was 237.9, and the average contamination in UV-treated cases was 81.7. Control cases displayed 156.2 times the contamination of UV-treated samples, and this was statistically significant (*p*-value = 0.033). This indicates that the degree of surface microbial contamination due to water quality improvement is more sensitive in fungi when compared to bacteria.

3.3. Airborne Bio-Contamination

To confirm the air quality improvement effect of a UV reactor in the DEC, we used a bio-contamination sampler with TSA and PDA to sample the bacteria and fungi in the inlet side and outlet side of the DEC. To compare the pollution degree (*F*) to the inlet air and outlet air in the DEC, a colony-forming unit (CFU) extracted from four agar media was converted by Equation (1) as follows:

$$F = \frac{N}{T} \quad (2)$$

Table 5 summarizes the bacterial contamination measurements of process air at the inlet and outlet of the DEC when recirculated water bypassed the UV reactor (Control). The air supplied to the DEC exhibited a very low level of bacterial contamination, although the air was observed as highly contaminated with bacteria after passing through the DEC.

Table 5. Number of bacteria colonies in the Control case.

Week	Measuring Date	Inlet		Outlet	
		1 min	2 min	1 min	2 min
1	7.10
Number of colonies CFU/m ³		0, 0	7, 6	19, 29	44, 26
		22		197	
2	7.17
Number of colonies CFU/m ³		1, 0	2, 1	465, 357	TNTC, TNTC
		7		4110	

Table 5. Cont.

Week	Measuring Date	Inlet		Outlet	
		1 min	2 min	1 min	2 min
3	7.27
Number of colonies CFU/m ³		1, 3 27	4, 8	TNTC, TNTC TNTC	TNTC, TNTC
4	8.2
Number of colonies CFU/m ³		0, 2 12	2, 3	TNTC TNTC	TNTC

Table 6 summarizes the bacterial contamination measurements of process air at the inlet and outlet of DEC when the recirculation water was sterilized by a UV reactor (UV-treated). As observed in the Control case, the air supplied to DEC in UV-treated samples exhibited low bacterial contamination, although the outlet air increased bacterial contamination after passing through DEC. However, the bacterial contamination levels shown in the outlet column of Table 6 indicates a significant reduction in the number of bacterial populations compared to those of Table 5.

Table 6. Number of bacteria colonies in the UV-treated case.

Week	Measuring Date	Inlet		Outlet	
		1 min	2 min	1 min	2 min
1	8.14
Number of colonies CFU/m ³		3, 4 13	1, 0	41, 40 385	84, 66
2	8.21
Number of colonies CFU/m ³		0, 2 5	1, 0	89, 64 605	122, 88

Table 6. Cont.

Week	Measuring Date	Inlet		Outlet	
		1 min	2 min	1 min	2 min
3	9.1
Number of colonies CFU/m ³		1, 2 37	3, 17	180, 119 1537	317, 306
4	9.8
Number of colonies CFU/m ³		0, 0 8	3, 2	157, 151 1383	285, 237

Table 7 summarizes fungal contamination measurements of the process air at the inlet and outlet of the DEC when the recirculated water bypassed the UV reactor (Control). The air supplied to the DEC exhibited very low fungal contamination, although the air after passing through the DEC was observed as highly contaminated with bacteria and fungi. A PDA is an agar that is used to extract fungi. However, excessive amounts of bacteria were released from DEC and interfered with fungal growth in the PDA.

Table 7. Number of fungi colonies in the Control case.

Week	Measuring Date	Inlet		Outlet	
		2 min	5 min	2 min	5min
1	7.10
Number of colonies CFU/m ³		9, 5 28	11, 9	24, 31 112	46, TNTC
2	7.17
Number of colonies CFU/m ³		2, 1 24	12, 18	85, 72 259	145, 61

Table 7. Cont.

Week	Measuring Date	Inlet		Outlet	
		2 min	5 min	2 min	5min
3	7.27
Number of colonies CFU/m ³		0, 0	2, 0	Uncountable	Uncountable
		3		Uncountable	
4	8.2
Number of colonies CFU/m ³		0, 0	0, 4	Uncountable	Uncountable
		7		Uncountable	

Table 8 summarizes fungal contamination measurements of the process air at the inlet and outlet of the DEC when the recirculation water was sterilized through a UV reactor (UV-treated). As observed in the Control case, both bacteria and fungi were also collected in the PDA of UV-treated samples. In the Control and UV-treated cases, it was difficult to pinpoint the fungus sample value due to bacterial influences on the PDA, although both bacterial and fungal contamination levels shown in the outlet column of Table 8 indicate a significant decrease compared to those of Table 7. As a result, microbial air quality improved when the recirculated water was treated by a UV reactor.

Table 8. Number of fungi colonies in UV-treated cases.

Week	Measuring Date	Inlet		Outlet	
		1 min	2 min	1 min	2 min
1	8.14
Number of colonies CFU/m ³		1, 1	0, 0	85, 32	70, 65
		3		420	
2	8.21
Number of colonies CFU/m ³		6, 3	11, 6	58, 60	146, 198
		43		770	

Table 8. Cont.

Week	Measuring Date	Inlet		Outlet	
		1 min	2 min	1 min	2 min
3	9.1
Number of colonies CFU/m ³		1, 2	1, 2	19, 170	124, TNTC
		10		783	
4	9.8
Number of colonies CFU/m ³		2, 2	3, 1	41, 45	51, 60
		13		328	

4. Discussion

Puckorius et al. [13] reported that *Legionella* spp. is difficult to cultivate or transfer because of the system temperature and size of water droplets in a direct evaporative cooling system. However, Macher and Girman [15] and Strindehag et al. [16] have confirmed several microbial contaminations of outlet air due to microbial contamination of recirculating water in a direct evaporative cooling system.

4.1. Impact of UV Light

Sung et al. [19] proposed a germicidal system, installing a UV lamp upstream and downstream of the evaporative humidifier (EH) pad and applying a UV water filter to the circulating water. When the proposed germicidal system was used, the bacteria and fungi decreased significantly on the EH pad surface. Microbial contamination of the circulating water was also reduced. In the case of airborne microbes in the air handling unit, it was confirmed that the bacteria decreased significantly, but the fungi maintained a constant degree of contamination. In a study by Sung et al., microbial contamination of outlet air was not measured. However, the proposed germicidal system improved the air quality of the outlet air when contamination of the outlet air was deduced from the pollution degree of the suspended microorganisms measured in the AHU.

4.2. Impact of UV Reactor

The germicidal system proposed by Sung et al. [19] improved the internal air in the EH system. The germicidal system consisted of two components, a UV lamp that disinfected the pad surface and air, and a UV water filter which disinfected recirculating water. Therefore, it is unclear what the cause of air quality improvement of outlet air in the AHU was. In this study, two cases were tested based on the assumption that water pollution affects air quality through analysis of previous research (Control and UV-treated). The results of the study are as follows.

In the absence of a UV reactor in the direct evaporative cooling system (Control), bacterial concentrations in the recirculated water showed high concentrations (820,000–1,570,000 CFU/mL) in the AC film. In the direct evaporative cooling system with ultraviolet disinfection (UV-treated), the recirculated water had a low contamination level (100–700 CFU/mL) immediately after disinfection.

However, after the disinfected water passed through the evaporative cooling pad, it was confirmed that the contamination increased (1000–340,000 CFU/mL). This suggests that bacteria accumulated in the evaporative cooling pad and pipe, increasing the contamination of recirculating water.

In both groups (Control and UV-treated), no correlation was found between the surface contamination of the sampled microorganisms and the duration of direct evaporative cooling. However, it was confirmed that the fungi were more sensitive to the ultraviolet ray reactor than the bacteria. In both cases, the contamination of bacterial and fungal surfaces was more severe in the outlet sides (outlet and upside outlet) of the four positions. It is predicted that the flow of process air will move the microorganisms in the evaporative cooling pad.

The pollution degree of outlet air of the direct evaporative cooling system increased in proportion to the operation time of the system, and both bacteria and fungi decreased more significantly in the UV-treated than in the Control samples. Through this, it was confirmed that the pollution degree of recirculated water influences the air quality in DEC.

Airborne microbes showed better air quality improvement in this study when compared to the results of Sung et al. [19]. Surface-borne microbes also showed a more pronounced improvement when compared to the results of Sung et al. [19].

5. Conclusions

The study empirically evaluated the improvement of microbial air quality on a direct evaporation cooling system. Experiments were performed for four weeks, and each divided into a control group (Control case corresponding to DEC that did not recycle water by bypassing the ultraviolet reactor) and experimental groups (UV-treated cases corresponding to DEC that involved recycled water treatment through an ultraviolet reactor). Water, surface, and air microorganisms were sampled twice a week a total of eight times.

In UV-treated cases, the bacterial concentration in the disinfected recirculating water increased after passing through the direct evaporative cooling pad. This indicates that circulating water is contaminated by surface bacteria contaminants in the evaporative cooling pad.

It was difficult to correlate the degree of bacterial and fungal contamination or type of microorganism on the surface of the direct evaporative cooling pad, given the duration of operation. However, the results confirmed that bacterial and fungal contamination were always higher on the outlet side when compared to that at the inlet side in all experimental periods.

A comparison of the air quality in Control and UV-treated cases indicated that airborne bacteria and fungi decreased when the water treatment was subjected to a UV reactor. The results confirmed that the air quality of the direct evaporative cooling system discharge air improved when the quality of recirculated water improved.

Therefore, the contamination of recirculated water in a direct cooling system affects air pollution. Water treatment techniques, such as ultraviolet water treatment systems, are also necessary for continuous water quality improvement in direct cooling systems.

Acknowledgments: This work was supported by the Korea Agency for Infrastructure Technology Advancement (KAIA) Grant (17CTAP-C116268-02), and the Korea Institute of Energy Technology Evaluation and Planning (KETEP) (No. 20164010200860).

Author Contributions: Wonjun Kim designed the research, conducted the experiment, and finished the writing of the paper; Hye-Won Dong contributed to conducting sampling and modified the manuscript; Junseok Park and Minki Sung gave comments on the experiment methods and results; Jae-Weon Jeong supervised the research design and execution and provided valuable suggestions during manuscript writing.

Conflicts of Interest: The authors declare no conflict of interest.

Appendix A

Table A1. Specifications of the UV reactor.

Reactor Model Number	MIN-3
Maximum water flow rate	3 Gallons/min
Reactor diameter	191 mm
Reactor length	41.28 mm/10.8 mm
Lamp model number	Atlantic UV 05-1366
Lamp nominal length	287 mm
Arc length	225 mm
Quartz diameter	15 mm
UV light wave length	253.7 nm
Power consumption	14 W
UV output	3.7 W

References

- Goetzler, W.; Zogg, R.; Young, J.; Johnson, C. *Energy Savings Potential and RD&D Opportunities for Non-Vapor-Compression HVAC Technologies*; Navigant Consulting Inc., US Department of Energy: Washington, DC, USA, 2014.
- Kim, M.H.; Jeong, J.W. Cooling performance of a 100% outdoor air system integrated with indirect and direct evaporative coolers. *Energy* **2013**, *52*, 245–257. [CrossRef]
- Kim, M.H.; Park, J.Y.; Sung, M.K.; Choi, A.S.; Jeong, J.W. Annual operating energy savings of liquid desiccant and evaporative-cooling-assisted 100% outdoor air system. *Energ. Build.* **2014**, *76*, 538–550. [CrossRef]
- Heidarinejad, G.; Bozorgmehr, M.; Delfani, S.; Esmaeelian, J. Experimental investigation of two-stage indirect/direct evaporative cooling system in various climatic conditions. *Build. Environ.* **2009**, *44*, 2073–2079. [CrossRef]
- Duan, Z.; Zhan, C.; Zhang, X.; Mustafa, M.; Zhao, X.; Alimohammadisagvand, B.; Hasan, A. Indirect evaporative cooling: Past, present and future potentials. *Renew. Sustain. Energ. Rev.* **2012**, *16*, 6823–6850. [CrossRef]
- ASHRAE. Chapter 41. Evaporative air-cooling equipment. In *ASHRAE Handbook—HVAC Systems and Equipment*; American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.: Atlanta, GA, USA, 2016.
- Bentham, R.H.; Broadbent, C.R. A model for autumn outbreaks of Legionnaires' disease associated with cooling towers, linked to system operation and size. *Epidemiol. Infect.* **1993**, *111*, 287–295. [CrossRef] [PubMed]
- Ferré, M.S.; Arias, C.; Oliva, J.M.; Pedrol, A.; Garcia, M.; Pellicer, T.; Dominguez, A. A community outbreak of Legionnaires' disease associated with a cooling tower in Vic and Gurb, Catalonia (Spain) in 2005. *Eur. J. Clin. Microbiol. Infect. Dis.* **2009**, *28*, 153. [CrossRef] [PubMed]
- Greig, J.E.; Carnie, J.A.; Tallis, G.F.; Ryan, N.J.; Tan, A.G.; Gordon, I.R.; Hart, W.G. An outbreak of Legionnaires' disease at the Melbourne Aquarium, April 2000: investigation and case-control studies. *Med. J. Aust.* **2004**, *180*, 566. [PubMed]
- Hung, L.L.; Copperthite, D.C.; Yang, C.S.; Lewis, F.A.; Zampello, F.A. Environmental Legionella assessment in office buildings of continental United States. *Indoor Air* **1993**, *3*, 349–353. [CrossRef]
- Bartram, J.; Chartier, Y.; Lee, J.V.; Pond, K.; Surman-Lee, S. Legionella and the Prevention of Legionellosis. Geneva, Switzerland: World Health Organization Press. 2007. Available online: http://www.who.int/water_sanitation_health/emerging/legionella.pdf (accessed on 9 April 2018).
- ASHRAE. *ANSI/ASHRAE Standard 12-2000, Minimizing the Risk of Legionellosis Associated with Building Water Systems*; American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.: Atlanta, GA, USA, 2000.
- Puckorius, P. Why evaporative coolers have not caused Legionnaires' disease. *Fuel Energy Abstr.* **1995**, *4*, 300.
- Gómez, E.V.; Martínez, F.R.; González, A.T. The phenomenon of evaporative cooling from a humid surface as an alternative method for air-conditioning. *Int. J. Energy Environ.* **2010**, *1*, 69–96.

15. Macher, J.M.; Girman, J.R. Multiplication of microorganisms in an evaporative air cooler and possible indoor air contamination. *Environ. Int.* **1990**, *16*, 203–211. [[CrossRef](#)]
16. Strindehag, O.; Josefsson, I.; Henningson, E. Emission of bacteria from air humidifiers. *Environ. Int.* **1991**, *17*, 235–241. [[CrossRef](#)]
17. Macher, J.M.; Girman, J.R.; Alevantis, L.A. Limited water-to-air bacterial transfer from a residential evaporative air cooler. *Environ. Int.* **1995**, *21*, 761–764. [[CrossRef](#)]
18. Kang, Y.; Kato, S. A study on the effectiveness of microwave heating for disinfection of humidifier elements. *HVAC&R Res.* **2014**, *20*, 113–120. [[CrossRef](#)]
19. Sung, M.; Kato, S.; Yanagi, U.; Kim, M.; Harada, M. Disinfection performance of ultraviolet germicidal irradiation systems for the microbial contamination on an evaporative humidifier. *HVAC&R Res.* **2011**, *17*, 22–30.
20. Bolton, J.R.; Cotton, C.A. *The Ultraviolet Disinfection Handbook*; American Water Works Association: Denver, CO, USA, 2008.
21. Yamamoto, H.; Urakami, I.; Nakano, K.; Ikeda, M.; Yabuuchi, E. Effects of FLONLIZER[®], ultraviolet sterilizer, on *Legionella* species inhabiting cooling tower water. *Microbiol. Immunol.* **1987**, *31*, 745–752. [[CrossRef](#)] [[PubMed](#)]
22. ASHRAE. *ANSI/ASHRAE/IES Standard 133-2008 Method of Testing Direct Evaporative Air Coolers*; American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.: Atlanta, GA, USA, 2008.
23. ASHRAE. *ANSI/ASHRAE/IES Standard 90.1-2013 Energy Standard for Buildings Except Low-Rise Residential Buildings*; American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.: Atlanta, GA, USA, 2016.
24. BUCK BioCulture. *Bio-Contaminants Sampler Model B30120 Technical Brief*; A.P. BUCK Inc.: Orlando, FL, USA, 2006.
25. ISO16000-17. *Indoor Air—Part 17: Detection and Enumeration of Moulds—Culture-Based Method*; International Organization for Standardization (ISO): Geneva, Switzerland, 2011.
26. ISO16000-18. *Indoor Air—Part 18: Detection and Enumeration of Moulds—Sampling by Impaction*; International Organization for Standardization (ISO): Geneva, Switzerland, 2011.

© 2018 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).