

Table S1: CFU/ml for the single taps #1-#12 for flushing Set-Up A, Incubation at 37°C.

CFU/ml Flushing Set-Up A: Flushing once a day, Incubation at 37°C						
Tap /Date	02.11.2020	16.11.2020	30.11.2020	10.02.2021	19.03.2021	21.04.2021
#1	30	200	210	52,5	20	20
#2	150	750	560	22,5	32,5	50
#3	40	140	280	115	17,5	5
#4	320	110	20	92,5	230	195
#5	220	120	70	18,5	25	45
#6	150	80	40	192,5	22,5	5
#7	30	110	50	52,5	30	30
#8	240	90	240	55	32,5	35
#9	120	30	80	32,5	2	15
#10	320	250	430	305	15	50
#11	630	880	540	600	115	395
#12	60	50	20	25	0	0

Table S2: CFU/ml for the single taps #1-#12 for flushing Set-Up A, Incubation at room temperature (RT).

CFU/ml Flushing Set-Up A: Flushing once a day, Incubation at RT				
Tap /Date	02.11.2020	16.11.2020	30.11.2020	21.04.2021
#1	50	130	130	10
#2	190	670	480	20
#3	80	180	250	15
#4	490	120	150	15
#5	500	80	80	150
#6	800	110	120	0
#7	80	100	60	45
#8	330	180	230	10
#9	120	50	160	10
#10	150	150	320	325
#11	400	730	740	365
#12	260	150	70	5

Table S3: CFU/ml for the single taps #1-#12 for flushing Set-Up B, Incubation at 37°C. For #10 the servo didn't work properly, so we couldn't use the data.

CFU/ml Flushing Set-Up B: #1-#6: Flushing once a day, #7-#12: Flushing once a week, Incubation at 37°C					
	23.06.2021	25.08.2021	13.10.2021	10.11.2021	08.12.2021
#1	5	10	217,5	0	352,5
#2	10	20	15	0	80
#3	5	5	27,5	5	32,5
#4	0	7,5	10	0	2,5
#5	10	2,5	35	15	105
#6	0	0	5	0	17,5
#7	0	332,5	152,5	2795	125
#8	100	90	62,5	162,5	52,5
#9	105	22,5	42,5	265	337,5
#10	x	x	x	x	x
#11	635	767,5	1015	2875	745
#12	540	1167,5	797,5	352,5	1467,5

Tabelle S4: CFU/ml for the additional sampling points incubated at 37°C and room temperature (RT).

additional sampling points	37°C			RT		
	Nr. 1	Nr. 2	Nr. 3	Nr. 1	Nr. 2	Nr. 3
CFU/ml						
02.11.2020	0	10	0	0	20	10
16.11.2020	0	0	0	0	10	0
30.11.2020	0	10	0	0	0	0
10.02.2021	0	2,5	0	x	x	x
19.03.2021	0	0	0	x	x	x
21.04.2021	0	0	0	0	5	0
23.06.2021	0	0	0	x	x	x
25.08.2021	0	0	0	0	0	0
13.10.2021	0	0	10	x	x	x
10.11.2021	0	0	0	0	0	0
08.12.2021	0	0	0	x	x	x