

Article

Investigating the Operation of an LNG Carrier as a Floating Power Generating Plant (FPGP)

Anastasios Manos¹, Dimitrios Lyridis², John Prousalidis^{2,*} and Elias Sofras²¹ Hellenic Electricity Distribution Network Operator, 11743 Athens, Greece; anastasios.manos@gmail.com² School of Naval Architecture and Marine Engineering, National Technical University of Athens, 15773 Athens, Greece; dsvlr@mail.ntua.gr (D.L.); elsofras@yahoo.gr (E.S.)

* Correspondence: jprousal@naval.ntua.gr; Tel.: +30-2107722869

Abstract: The paper provides a novel alternative solution for the old generation turbine LNG carriers (LNG/Cs) in order to extend their life cycle, thus avoiding their demolition. Nowadays, the use of liquefied natural gas (LNG) as fuel for the production of electricity is predominant against other fossil fuels. LNG has been widely recognized as the most promising alternative fuel, combining both high efficiency and environmental friendliness. The old generation of steam turbine LNG/Cs with the distinct disadvantage of a low thermal efficiency ratio, leading to higher fuel costs, are coming to a crossroad, which is either to keep the vessel on duty until the end of their life cycle, earning low fares as those are not preferred from the charterers, or to change the use of the vessel, converting them either to a FSRU (floating storage regasification unit) or to a FPGP (floating power generating plant). In this paper, the last alternative is proposed via a holistic examination of the techno-economical (the CBA performed calculates all related metrics) but also in terms of the electric energy market by utilizing power purchase agreements (PPAs) and the contracts for difference (CfDs). This conversion into an FPGO is a novel approach providing a ‘win-win’ solution scheme, on the one hand, to areas with the non-economical bunkering chain of LNG along with non-expensive electricity production, while on the other hand, it provides an extension of the profitable life cycle of the LNG/Cs under study, which would otherwise have been considered of obsolete technology. The proposition is supported by figurative numerical case studies that help extract tangible conclusions regarding the degree of the investment viability.

Keywords: LNG; LNG carrier; FSRU; FPGP; maritime electricity pricing; cold ironing; open electricity market; power purchase agreement (PPA); contract for difference (Cfd)



Citation: Manos, A.; Lyridis, D.; Prousalidis, J.; Sofras, E. Investigating the Operation of an LNG Carrier as a Floating Power Generating Plant (FPGP). *J. Mar. Sci. Eng.* **2023**, *11*, 1749. <https://doi.org/10.3390/jmse11091749>

Academic Editor: Constantine Michailides

Received: 7 August 2023

Revised: 3 September 2023

Accepted: 4 September 2023

Published: 6 September 2023



Copyright: © 2023 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

Liquefied natural gas (LNG) had been widely recognized as an advantageous fossil fuel combining both high efficiency and environmental friendliness. Nowadays, it is considered as an appealing interim fuel toward complete sustainable decarbonization via alternative maritime fuels [1], which is, for many reasons aimed to take place by 2050 [2] with a major milestone being 2030 or even earlier [3]. Within this context, big vessels carrying LNG (LNG carriers or LNG/Cs) have been being built since the beginning of the millennium, enabling the gradual cease of use of fuel oil (heavy fuel oil or diesel) in all sectors of human activity [4]. Moreover, in the sector of electricity generation, thermal power plants have been using LNG as a fuel in modern units (e.g., co-generation ones [5]), while, of course, it is imperative that electricity production is eventually based upon the use of renewable energy sources. In order to facilitate the energy transition, in [4], the authors proposed that LNG/Cs can act as either floating storage units of LNG located near-shore or even be used to produce electricity, acting as floating power plants. A similar proposition was made in [6], according to which, floating power plants (i.e., vessels powered from LNG) that are moored nearby the shore can be used to supply electricity to the shore grid in case the

inland power supply cannot be provided to a sufficient extent due to emergency situations, catastrophes, earthquakes, etc. It was noted though that the solution in [4] or [6] must be designed on purpose to this end from the very beginning and constructed to serve such cases. This was confirmed in [7], where an LNG powered barge was constructed to serve as an alternative to shore power supply (i.e., providing electricity to ships at berth). The electric energy of the barge discussed in [7] due to the LNG was more environmentally friendly than the one produced onboard by diesel generator sets. The barge could supply electric energy to cruise ships or mega yachts of up to 7.5 MW. The technology of this more environmental friendly electricity provision to ships is based on the IEC/ISO/IEEE series of standards, covering high-voltage applications [8], communication systems [9], and low-voltage systems [10], respectively. Still, the common denominator is that building such customized floating power plants of rather small power capacity is fairly expensive. Thus, in [11,12], it was stressed that LNG carrying vessels should always be built in big sizes, as this was proven to be economically beneficial in all cost–benefit analyses. This was also verified in [13], where a special case study was presented, consisting of small LNG carriers making round trips to supply a small number of islands in the archipelagos of Indonesia with LNG where the berthing depth is small. Since the initial building cost is a major issue, a methodology was developed to investigate the optimum capacity of LNG carriers that fit in that particular case.

On the other hand, the evolution in LNG treating and storing technology is being improved so rapidly that the corresponding vessels, the building of which is very costly, need to be replaced by others more efficient in very short time intervals (e.g., less than a decade) [14]. The latter means that that LNG/Cs are not fully exploited as originally planned, their investment is not paid back, and hence, some solutions must be developed so that their depreciation period can somehow be extended [15]. Therefore, alternative solutions of exploiting the LNG/Cs of less modern but still non-obsolete technology have to be investigated [15]. Regarding retrofitting existing vessels in an attempt to increase their performance, the only solution proposed up-to-date has been the installation of a re-liquefaction plant that decreases the leakages due to the boil-off-gas (BOG) [16].

Furthering the concept initially introduced in [15], the authors in [17] proposed that it is worthwhile to retrofit LNG/Cs into floating power plants or more officially named as floating power generating plants (FPGPs). The case studies were similar to those studied in [18], which investigated from technical and economical point of view, the option to have an FPGP installed close to the port of a non-interconnected island. Electricity in non-interconnected islands is produced via thermal power plants operating with pollutant heavy fuel oil (HFO) or diesel fuel oil (DFO). Therefore, considering that the electricity produced onboard a retrofitted LNG/C seems to be less expensive than that of inland production based on HFO or DFO, in [17,18], the LNG/C into FPGP conversion was proven to be an appealing solution both from the environmental but also economical point of view. The technical part of this solution was based on the shore side electrical supply (SSES) as discussed in [19,20], while it contributed to the resilience of the entire grid under consideration in normal but also in emergency operating conditions.

On the other hand, significant efforts have been made in the maritime sector to reach complete decarbonization, once again via alternative fuels including electricity. In particular, the shore to ship electrical supply (SSES) (i.e., the electrical interconnection of any berthed vessel with the shore grid in order to stop operating its auxiliary engines), which stops polluting the wider area of any port with air emissions, seems to be the most readily available decarbonization technology [1]. However, in most cases, the capacity of the grid in the vicinity of the port is not sufficient and must be reinforced so that the estimated total power demands are met, as stated explicitly in [19]. Despite the mid-term measures or the long-term measures required as described in [20], so that the power demands are well-predicted and covered, meeting the power demands of all ships at berth is not always feasible in the short-term within which SSES must be deployed, at least in European Union

ports, as stipulated by the Fit-for-55 package of Directives and Regulations like the Fuel EU Maritime and Alternative Fuel Infrastructure (see indicatively [1,2,21]).

Within this framework, and furthering the concept of having a floating power plant based on LNG, this paper proposes the conversion of a steam turbine LNG carrier into a floating power generating plant (FPGP) in order to produce non-expensive electricity to supply the grid of the port, with the latter acting as an energy hub. The port, in turn, can provide the energy either to berthed vessels or even to inland national grids, as shown in Figure 1.




Figure 1. Operation of an LNG carrier as a FPGP.

Considering the novelties of this paper, they consist of furthering ideas like those presented in [7] for specially designed FPGPs, according to which the proposed electric energy production based on LNG is more environmentally friendly, and hence can be an interim solution until the complete implementation of SSES technology based on the grid capacity to supply 100% green energy. Thus, via the novel approach proposed in the paper, no dedicated special design for a small-scale LNG/C including the risk of the non-viability as in [13] is required. More specifically, the proposition discussed consists in retrofitting an existing LNG/C, which is forced to be considered as obsolete technology, and hence must be withdrawn from faring business. Moreover, the FPGP proposition can be seen as a mutually beneficial (i.e., “win-win” solution) as in the transition period:

- On the one hand, the port is partially relieved by the heavily polluting electricity generation onboard the ships;
- On the other hand, the LNG/Cs acquire a sufficient extension of their exploitation period, attaining their payback.

Furthermore, the proposed solution was validated by studying the feasibility of retrofitting an actual LNG/C into an FPGP. An extra novelty is that the cost–benefit analysis (CBA) was performed not only exploiting by standardized metrics, but also through modern electric market tools. The former comprised indices like the net present value (NPV), the internal rate of return (IRR), the depreciation payback period (DPB), and the present worth cost (PWC). On the other hand, regarding the exploitation of modern electric market rule tools, case studies were also validated by running exemplary calculations of combinations of power purchase agreements (PPAs) and contract for differences (CfDs), which have recently been discussed in [22] and analyzed in depth in [23] regarding the regulatory framework of the maritime electricity transactions, which must comply with the open electricity market rules outlined in [24].

2. Steam Turbine LNG Carriers

An LNG/C with a steam turbine propulsion system usually has two boilers installed on board capable to burn the boil-off gas (BOG) and produce superheated steam (60 bar, $>525^{\circ}\text{C}$). This steam is then fed into two-grade steam turbines, one of high (HP) and another of low pressure (LP), which drive the propeller shaft through a reduction gear, as shown in Figure 2 [18,25]. Another stream of superheated steam is also fed to the steam turbine generators, which produce the power required by the vessel electric loads [5].




Figure 2. Typical steam turbine propulsion arrangement [12].

Up to 2003, the use of steam turbines was the only alternative for the propulsion of modern LNG carriers due to the capability of the boilers to operate in GAS, HFO/MDO, or in DUAL mode (both GAS and HFO). The reliability and low maintenance cost were included in the advantages of such propulsion systems. On the other hand, the extreme low thermal efficiency ratio, which leads to high fuel consumption, and the lack of skilled engine crew specialized in steam arrangements, displaced this system up to a point that only 10% of the orders was steam turbine propelled, as depicted in Figure 3 [11].




Figure 3. Global fleet of LNG carriers by type of propulsion plant [11].

An extension of the lifespan of steam turbine LNG/Cs has been given through the use of the so-called ultra-steam turbine (UST), as shown in Figure 4 [11]. The use of an intermediate pressure turbine between the high and low pressure in cooperation with a separate steam reheater increased the thermal efficiency up to 42%.




Figure 4. Ultra-steam turbine arrangement [11].

Older LNG/Cs may seek alternative options for commercial exploitation, offering unattractive chartering options. The conversion into an FSRU is an established choice in a growing niche market as it provides a quick to build, short-term option for natural gas import. Another alternative concept is the integration of the LNG carrier with a gas-to-power system, either as an FSRU feeding an onshore power plant or as a FPGP (floating power generating plant) [18]. As discussed, the solution of converting a steam turbine LNG carrier to FPGP is analyzed hereinafter from the point of view of the profitability of the investment and the energy market.

3. Techno-Economic Scenarios

In this section, a techno-economic scenario based on an existing steam turbine LNG carrier is presented. The investment that was evaluated consisted in the conversion of this ship into an FPGP using assumptions similar to those met in [5,15,18,26], and the LNG prices were taken from [27].

- The total investment cost was assumed to be the cost for the retrofit of one or two more turbo generators with the relevant cabling, switchboards, converters, etc., depending on the power of the plant, which includes the acquisition cost as well as the steel, piping, and electrical works onboard. This cost was divided into two categories. The first category was the cost, which was covered with own funds and assumed to be EUR 5,000,000 for scenarios 1 and 2, while scenario 3 regarded the respective amount of EUR 1,500,000. The second category was the rest amount of the total investment cost, which will be covered exclusively by a loan of 10 years duration.
- The initial annual incomes were derived from the produced electricity assuming 300 days of trading per year. The remaining (65) days of the year were considered to be dedicated to the service and repair works of the vessel.
- The years of trading of the vessel as a floating power generating plant (FPGP) were assumed to be equal with the loan duration (i.e., 10 years).
- The operating cost was assumed to be the cost of the gas consumed for the production of electricity, C_{FUEL} , plus the cost of the steam plant maintenance and provisions, C_{MAIN} , plus the crew pay roll, C_{CREW} . Therefore, the initial annual net income (f_t) is the initial annual income (A_{in}) subtracting the initial annual costs as described above.

Hence:

$$f_t = (A_{in}) - (C_{crew} + C_{fuel} + C_{MAIN}).$$

For any other year of the period of the techno-economic analysis, the annual income at year t , ($A_{in,t}$) is calculated from the initial annual income, (N_{in}), considering a net price inflation rate ($NPIR$) that is equal to 0.04:

$$(A_{in,t}) = (N_{in}) \cdot (1 + NPIR)^{t-1}$$

and deducting the annual costs, also considering the relative inflation rates.

More specifically, the annual fuel cost at year t , ($A_{FuelCost,t}$) is calculated considering the initial fuel cost ($N_{FuelCost}$) and the corresponding fuel cost inflation rate ($FCIR$):

$$(A_{FuelCost,t}) = (N_{FuelCost}) \cdot (1 + FCIR)^{t-1}$$

Similarly, the annual maintenance cost at year t , ($A_{MaintCost,t}$) is calculated considering the initial maintenance cost ($N_{MaintCost}$) and the corresponding maintenance cost inflation rate ($MCIR$):

$$(A_{MaintCost,t}) = (N_{MaintCost}) \cdot (1 + MCIR)^{t-1}$$

Moreover, the annual crew cost at year t , ($A_{CrewCost,t}$) is calculated considering the initial crew cost ($N_{CrewCost}$) and the corresponding crew cost inflation rate ($CCIR$):

$$(A_{CrewCost,t}) = (N_{CrewCost}) \cdot (1 + CCIR)^{t-1}$$

- The annual accounting relief (A_t) considering linear deduction is obtained by the investment cost, (IC), divided by the tax deduction period, (TDP):

$$A_t = \frac{(IC)}{(TDP)}$$

- The annual debit relief considered with equal annuity through the years A_{Lt} is:

$$A_{Lt} = L \cdot CRF(N_L, i_L)$$

Whereas the CRF is:

$$CRF = \frac{i_L \cdot (1 + i_L)^{N_L}}{(1 + i_L)^{N_L} - 1}$$

where i_L is the loan interest rate and N_L is the loan payback period

- The loan interest through the year t is:

$$I_{Lt} = r_L \cdot L_t$$

- The loan balance at the beginning of the year t (L_t) is:

$$L_{t+1} = L_t - A_{Lt} + I_{Lt}$$

- The reduction in the loan at year t is:

$$\Delta L_t = A_{Lt} - I_{Lt}$$

- The net cash flow at year t is:

$$F_t = f_t - A_{Lt}$$

On the other hand, the initial net cash flow F_0 is:

$$F_0 = -(\text{Investment cost covered with own funds}) \cdot (1 + i_M)^{\text{period of construction}}$$

where i_M is the market loan rate.

4. Available Electric Energy of the Vessel for Commercial Use

The examined scenarios from the point of view of the available electric energy that can be sold are as follows:

Scenario 1: Available electric energy to be sold is 19.4 MW, which can be achieved by adding one (1) turbo generator of 15 MW on board the vessel.

Scenario 2: Available electric energy to be sold is 34.4 MW, which can be achieved by adding two (2) turbo generators of 15 MW each on board the vessel.

Scenario 3: Available electric energy to be sold is 4.4 MW, which can be achieved by utilizing the spare electric energy produced from the existing turbo generators.

In all aforementioned scenarios, the vessel will be alongside during power supply to the shore so there is no need for special mooring arrangements to be fitted, and hence no subsequent related cost.

All of the above are summarized in Table 1.

Table 1. Power data for the vessel under study.

GENERAL DATA			
STEAM TURBINE LNGC (Existing Vessel)	SCENARIO 1	SCENARIO 2	SCENARIO 3
No. of existing turbo generators	2	2	2
Electric power per generator (kVA)	4313	4313	4313
Electric power per generator (kW)	3450	3450	3450
Total electric power from existing turbo generators (kW)	6900	6900	6900
Voltage (V)	6600	6600	6600
Frequency (Hz)	60	60	60
Ship's electric load demand (hotel and auxiliary) (kW)	2500	2500	2500
Total exist. available power for propulsion and electric demands (MW)	36.36	36.36	36.36
Total power for propulsion (MW)	29.46	29.46	29.46
Total available existing electric power for commercial use (MW)	4.40	4.40	4.40
STEAM TURBINE LNGC (retrofit for conversion to LNG FPGP)			
No. of turbo generators to be added	1	2	0
Power of added turbo generators (MW)	15	15	0
Total power of added turbo generators (MW)	15	30	0
Voltage (V)	6600	6600	6600
Frequency (Hz)	50	50	50
Total available electrical power for commercial use (MW)	19.4	34.4	4.4

5. Operating, Maintenance and Crew Costs Analysis—Assumptions

In this section, all of the cost parameters considered in the analysis as well as the assumptions made are presented and discussed.

The operating cost of the LNG carrier was assumed to be the cost of the LNG fuel burnt for the steam production needed for the electricity for commercial use. The cost of the LNG fuel that is needed for the steam production to meet all the load demands of the vessel is considered quite low as the vessel is berthed, and hence there are no high load demands.

The specific consumption in kg/h of the LNG for the steam production was derived with linear interpolation from the pairs of values shown in Table 2 [11]. The assumptions made and the related calculations of all of costs, namely fuel cost, maintenance costs and crew costs are summarized in Tables 3–5.

Table 2. Specific fuel gas consumption.

Plant Power (MW)	11.5	22.7	25.5	28.9	30.5
Fuel Gas consumption (kg/h)	4800	6200	6800	7400	7980

Table 3. Annual fuel LNG cost for all three scenarios considered.

ANNUAL FUEL LNG COST OF SCENARIO 1									
GAS CONSUMPTION FOR STEAM PRODUCTION (19.4 MW)	SPECIFIC CONSUMPTION (kg/h)	ANNUAL CONSUMPTION (tons)	ANNUAL CONSUMPTION (ft³)	ANNUAL CONSUMPTION (m³)	ANNUAL CONSUMPTION (mmBTU)	VESSEL'S RELOADS PER YEAR	LNG cost per mmBTU (USD)	LNG cost per mmBTU (€)	ANNUAL LNG COST (€)
	5788	41,674	2,029,504,320	57,475,562	2,033,548	0.7	9.90	9.01	18,321,495
	TOTAL								18,321,495
ANNUAL FUEL LNG COST OF SCENARIO 2									
GAS CONSUMPTION FOR STEAM PRODUCTION (34.4 MW)	SPECIFIC CONSUMPTION (kg/h)	ANNUAL CONSUMPTION (tons)	ANNUAL CONSUMPTION (ft³)	ANNUAL CONSUMPTION (m³)	ANNUAL CONSUMPTION (mmBTU)	VESSEL'S RELOADS PER YEAR	LNG cost per mmBTU (USD)	LNG cost per mmBTU (€)	ANNUAL LNG COST (€)
	9394	67,637	3,293,912,160	93,283,592	3,300,476	1.1	9.90	9.01	29,736,027
	TOTAL								29,736,027
ANNUAL FUEL LNG COST OF SCENARIO 3									
GAS CONSUMPTION FOR STEAM PRODUCTION (4.4 MW)	SPECIFIC CONSUMPTION (kg/h)	ANNUAL CONSUMPTION (tons)	ANNUAL CONSUMPTION (ft³)	ANNUAL CONSUMPTION (m³)	ANNUAL CONSUMPTION (mmBTU)	VESSEL'S RELOADS PER YEAR	LNG cost per mmBTU (USD)	LNG cost per mmBTU (€)	ANNUAL LNG COST (€)
	3913	28,174	1,372,054,320	38,856,578	1,374,788	0.5	9.90	9.01	12,386,318
	TOTAL								12,386,318

Table 4. Annual maintenance costs for all scenarios.

ANNUAL MAINTENANCE COST OF SCENARIO 1			
ITEM	ENERGY (MWh)	MAINTENANCE COST per MWh	MAINTENANCE COST (€)
STEAM PLANT MAINTENANCE	139,680	2.50 €/MWh	349,200
TOTAL			349,200
ANNUAL MAINTENANCE COST OF SCENARIO 2			
ITEM	ENERGY (MWh)	MAINTENANCE COST per MWh	MAINTENANCE COST (€)
STEAM PLANT MAINTENANCE	24,7680	2.50 €/MWh	619,200
TOTAL			619,200
ANNUAL MAINTENANCE COST OF SCENARIO 3			
ITEM	ENERGY (MWh)	MAINTENANCE COST Per MWh	MAINTENANCE COST (€)
STEAM PLANT MAINTENANCE	31,680	2.50 €/MWh	79,200
TOTAL			79,200

Table 5. Monthly crew payroll.

CREW ON BOARD			
Rank	No. Off	Monthly Salary (EUR)	Total (EUR)
Master	1	10,000	10,000
Chief officer	1	6000	6000
Third officer	2	3000	6000
Chief engineer	1	8000	8000
Second engineer	1	5000	5000
Third engineer	2	3000	6000
Wipers	2	1500	3000
Boatswain	1	2000	2000
Sailor	4	1500	6000
Total monthly crew payroll			52,000

It is worth mentioning that among the three scenarios, only in the case of scenario 2 (i.e., where the plant power is 34.4 MW) did the vessel need to be reloaded once per year as the capacity of the LNG in the tanks was not sufficient for 300 days of operation in a year at full power mode.

Regarding the maintenance cost, a constant specific cost of 2.5 €/MWh [6] was assumed, showing one of the distinct advantages of steam turbine vessels (i.e., the low maintenance cost) [9,10]. As shown in Table 4, the maintenance cost for the three scenarios considered was equal to EUR 349,000 (with one turbo generator producing 19.4 MW), EUR 619,200 (with two turbo generator producing 34.4 MW), and EUR 79,200 (production of 4.4 MW with no additional generator), respectively.

In order to analyze the crew payroll, a typical crew synthesis of such vessels was assumed (see Table 5 [15,17]). Taking into account that the ship would be berthed on an almost constant basis, a rather more limited number of crew compared with that during sailing was considered. In all scenarios, the same crew was considered, hence, the initial monthly pay roll was summed up to EUR 52,000 in all cases (see Table 5). Moreover, as explained in Section 7, in the following years, an increment due to the inflation rate was taken into account. Furthermore, a constant additional cost for the crew provisions was also considered.

6. Acquisition Cost—Assumptions

In this section, the acquisition cost for the retrofitting under consideration is discussed, accompanied by the assumptions made.

More specifically, in Tables 6–8, the cost of the retrofit for the conversion of the LNG carrier into FPGP is analyzed with the basic electro-mechanical equipment that must be

installed being included. The prices are indicative but quite close to the reality during this research. It is stressed that in scenario 3, the cost was fairly low compared to other two cases, as in this case no turbo generator was to be added.

Table 6. Acquisition cost for scenario 1.

ACQUISITION COST FOR SCENARIO 1			
ITEM	QUANTITY	COST PER UNIT	€
15 MW TURBO GENERATOR	1	1,500,000€	1,500,000€
STEAM TURBINES FOR THE TURBO GENERATORS	1	5,000,000€	5,000,000€
HV SWITCHBOARD	1	1,000,000€	1,000,000€
SHORE CONNECTION SWITCHBOARD	1	500,000€	500,000€
FREQUENCY CONVERTERS 60/50 Hz	1	300,000€	300,000€
NEW POWER MANAGEMENT SYSTEM	1	300,000€	300,000€
HV CABLES (m)	300 m	200 €/m	60,000€
STEEL RETROFIT (materials and labor)	1	200,000€	200,000€
PIPING RETROFIT (materials and labor)	1	250,000€	250,000€
ELECTRICAL RETROFIT (materials and labor)	1	150,000€	150,000€
VARIOUS			1,500,000€
TOTAL			10,760,000€

Table 7. Acquisition cost for scenario 2.

ACQUISITION COST OF SCENARIO 2			
ITEM	QUANTITY	COST PER UNIT	€
15 MW TURBO GENERATOR	2	1,500,000€	3,000,000€
STEAM TURBINES FOR THE TURBO GENERATORS	2	5,000,000€	10,000,000€
HV SWITCHBOARD	2	1,000,000€	2,000,000€
SHORE CONNECTION SWITCHBOARD	1	500,000€	500,000€
FREQUENCY CONVERTERS 60/50 Hz	1	300,000€	300,000€
NEW POWER MANAGEMENT SYSTEM	1	300,000€	300,000€
HV CABLES (m)	500 m	200 €/m	100,000€
STEEL RETROFIT (materials and labor)	2	200,000€	400,000€
PIPING RETROFIT (materials and labor)	2	250,000€	500,000€
ELECTRICAL RETROFIT (materials and labor)	2	150,000€	300,000€
VARIOUS			500,000€
TOTAL			17,900,000€

Table 8. Acquisition cost for scenario 3.

ACQUISITION COST FOR SCENARIO 3			
ITEM	QUANTITY	COST PER UNIT	€
15 MW TURBO GENERATOR	0	1,500,000€	-€
STEAM TURBINES FOR THE TURBO GENERATORS	0	5,000,000€	-€
HV SWITCHBOARD	0	1,000,000€	-€
SHORE CONNECTION SWITCHBOARD	1	500,000€	500,000€
FREQUENCY CONVERTERS 60/50 Hz	1	300,000€	300,000€
NEW POWER MANAGEMENT SYSTEM	0.5	300,000€	150,000€
HV CABLES (m)	150 m	200 €/m	30,000€
STEEL RETROFIT (materials and labor)	0	200,000€	-€
PIPING RETROFIT (materials and labor)	0	250,000€	-€
ELECTRICAL RETROFIT (materials and labor)	0.5	150,000€	75,000€
VARIOUS			500,000€
TOTAL			1,555,000€

It is worth mentioning that the under-study vessel will be alongside during its shore connection for power supply. If the vessel is afloat when interconnected with the shore, then

special mooring equipment needs to be installed, which has a very high cost (indicative cost MUSD 15), and the investment will be negative for the short-term period of 10 years under study.

7. Economic Calculations of the Scenarios under Study

In order to evaluate the investment, the financial metrics discussed below were calculated:

- (1) Net present value (NPV), showing if the investment will be profitable in the long run; NPV must pass from negative values to positive values.
- (2) Internal rate of return (IRR), estimating the profitability of the investment.
- (3) Discounted payback period (DPB), evaluating whether the critical time instant that the profitability and feasibility of the given investment will be attained.
- (4) Present worth cost (PWC), which transforms all future costs and revenues to equivalent monetary units at present.

To assess all of the above financial metrics, the economic data of Table 9 were calculated by making certain additional assumptions, namely:

- The investment period was considered equal to 10 years, which is a very plausible assumption for the life span extension of an LNG/C as well as the corresponding loan payback period.
- The inflation rate, increasing annually in all costs in all scenarios (LNG fuel, lub-oil, personnel and maintenance), was considered equal to 4%, a plausible assumption used in all cost–benefit analyses.
- As already mentioned, the selling period was 300 days per annum, with the remaining 65 days dedicated to the maintenance of the ship and its machinery.

Table 9. Economic data of the vessel under study.

ECONOMIC DATA	SCENARIO 1	SCENARIO 2	SCENARIO 3
INFLATION RATES			
MAINTENANCE INFLATION RATE	0.04	0.04	0.04
FUEL INFLATION RATE	0.04	0.04	0.04
LUB OIL INFLATION RATE	0.04	0.04	0.04
CREW INFLATION RATE	0.04	0.04	0.04
INCOMES			
TOTAL AVAILABLE ELECTRICAL POWER FOR COMERCIAL USE (MW)	19.4	34.4	4.4
PRICING OF ELECTRICITY (€/kWh)	0.1508	0.1381	0.4496
ANNUAL DAYS OF OPERATION	300	300	300
ANNUAL OPERATING HOURS (h)	7200	7200	7200
ANNUAL AVAILABLE ENERGY (kWh)	139,680,000	247,680,000	31,680,000
ANNUAL INCOMES (M€)	21.07	34.20	14.24
NET PRICE INFLATION RATE	0.04	0.04	0.04
INVESTMENT DATA			
MARKET RATE	0.12	0.12	0.12
TOTAL COST OF INVESTMENT (EUR)	10,760,000	17,900,000	1,555,000
COST COVERED BY OWN FUNDS (EUR)	5,000,000	5,000,000	1,500,000
COST COVERED BY LOAN (EUR)	5,760,000	12,900,000	55,000
LOAN DATA			
LOAN PAYBACK PERIOD (N_L)	10	10	10
YEARS OF CONVERSION (LNGC → LNG FPGP)	1	1	1
CAPITAL RECOVERY FACTOR, CRF (N_L, r_L)	0.1424	0.1424	0.1424
LOAN INTEREST (r_L)	0.07	0.07	0.07
INITIAL NET CASH FLOW F_0 (EUR)	−5,600,000	−5,600,000	−1,680,000

Table 11. PWC results for scenario 1.

FINANCIAL METRICS OF SCENARIO 1 (Part 2)							
t	C _{CREW} (€)	C _{MAIN.} (€)	C _{FUEL} (€)	A _{It} (€)	C _t (€)	C _t /(1 + i) ^t (€)	Σ(C _t /(1 + i) ^t) (€)
0					−5,600,000	−5,600,000	−5,600,000
1	714,000	349,200	18,321,495	820,094	20,204,789	18,039,991	12,439,991
2	742,560	363,168	19,054,355	820,094	20,980,177	16,725,269	29,165,259
3	772,262	377,695	19,816,529	820,094	21,786,580	15,507,258	44,672,517
4	803,153	392,803	20,609,190	820,094	22,625,240	14,378,749	59,051,266
5	835,279	408,515	21,433,558	820,094	23,497,446	13,333,082	72,384,348
6	868,690	424,855	22,290,900	820,094	24,404,540	12,364,099	84,748,447
7	903,438	441,849	23,182,536	820,094	25,347,918	11,466,111	96,214,558
8	939,575	459,523	24,109,837	820,094	26,329,031	10,633,854	106,848,412
9	977,158	477,904	25,074,231	820,094	27,349,388	9,862,463	116,710,875
10	1,016,245	497,020	26,077,200	820,094	28,410,560	9,147,440	125,858,315
11	1,056,894	516,901	27,120,288	820,094	29,514,178	8,484,621	134,342,936
PRESENT WORTH COST						PWC	134,342,936

Table 12. NPV, IRR, and DPB results for scenario 2.

FINANCIAL METRICS OF SCENARIO 2 (Part 1)												
	Crew Cost (€)	Maintenance Cost (€)	LNG Cost (€)	Operating Profit of Year t (€)	Annual Accounting Relief (€)	Loan Balance at the Beginning of Year t (€)	Annual Debit Relief (€)	Loan Interest through Year t (€)	Reduction of Loan at Year t (€)	Net Cash Flow through Year t (€)	$F_t/(1 + i)^t$	$\Sigma(F_t/(1 + i)^t)$
t	C _{CREW}	C _{MAINTENANCE}	C _{FUEL GAS}	f _t	A _t	L _t	A _{Lt}	I _{Lt}	Δ _{Lt}	F _t	(€)	(€)
0										−5,600,00	−5,600,000	−5,600,000
1	714,000	619,200	29,736,027	3,127,204	1,790,000	12,900,000	1,836,670	903,000	933,670	1,290,534	1,152,263	−4,447,737
2	742,560	643,968	30,925,468	3,252,292	1,790,000	11,966,330	1,836,670	837,643	999,027	1,415,622	1,128,526	−3,319,212
3	772,262	669,727	32,162,487	3,382,384	1,790,000	10,967,304	1,836,670	767,711	1,068,959	1,545,714	1,100,209	−2,219,003
4	803,153	696,516	33,448,986	3,517,679	1,790,000	9,898,345	1,836,670	692,884	1,143,786	1,681,009	1,068,312	−1,150,691
5	835,279	724,376	34,786,946	3,658,386	1,790,000	8,754,559	1,836,670	612,819	1,223,851	1,821,717	1,033,691	−117,000
6	868,690	753,351	36,178,423	3,804,722	1,790,000	7,530,709	1,836,670	527,150	1,309,520	1,968,052	997,076	880,076
7	903,438	783,486	37,625,560	3,956,911	1,790,000	6,221,189	1,836,670	435,483	1,401,187	2,120,241	959,089	1,839,166
8	939,575	814,825	39,130,583	4,115,187	1,790,000	4,820,002	1,836,670	337,400	1,499,270	2,278,517	920,255	2,759,421
9	977,158	847,418	40,695,806	4,279,795	1,790,000	3,320,732	1,836,670	232,451	1,604,219	2,443,125	881,015	3,640,436
10	1,016,245	881,315	42,323,638	4,450,986	1,790,000	1,716,514	1,836,670	120,156	1,716,514	2,614,317	841,740	4,482,176
11	1,056,894	916,567	44,016,584	4,629,026	1,790,000	0	1,836,670	0	1,836,670	2,792,356	802,736	5,284,912
NET PRESENT VALUE											NPV	5,284,912
INTERNAL RATE OF RETURN											IRR	0.2788
DISCOUNTED PAYBACK PERIOD											DPB	5.082

Table 13. PWC results for scenario 2.

FINANCIAL METRICS OF SCENARIO 2 (Part 2)							
t	C _{CREW} (€)	C _{MAIN.} (€)	C _{FUEL} (€)	A _{Lt} (€)	C _t (€)	C _t /(1 + i) ^t (€)	Σ(C _t /(1 + i) ^t) (€)
0					−5,600,000	−5,600,000	−5,600,000
1	714,000	619,200	29,736,027	1,836,670	32,905,897	29,380,265	23,780,265
2	742,560	643,968	30,925,468	1,836,670	34,148,666	27,223,107	51,003,372
3	772,262	669,727	32,162,487	1,836,670	35,441,146	25,226,307	76,229,680
4	803,153	696,516	33,448,986	1,836,670	36,785,325	23,377,739	99,607,418
5	835,279	724,376	34,786,946	1,836,670	38,183,271	21,666,213	121,273,632
6	868,690	753,351	36,178,423	1,836,670	39,637,135	20,081,406	141,355,038
7	903,438	783,486	37,625,560	1,836,670	41,149,153	18,613,787	159,968,825
8	939,575	814,825	39,130,583	1,836,670	42,721,653	17,254,559	177,223,384
9	977,158	847,418	40,695,806	1,836,670	44,357,052	15,995,598	193,218,982
10	1,016,245	881,315	42,323,638	1,836,670	46,057,867	14,829,401	208,048,382
PRESENT WORTH COST						PWC	208,048,382

Table 14. NPV, IRR, and DPB results for scenario 3.

FINANCIAL METRICS OF SCENARIO 3 (Part 1)												
	Crew Cost (€)	Maintenance Cost (€)	LNG Cost (€)	Operating Profit of Year t (€)	Annual Accounting Relief (€)	Loan Balance at the Beginning of Year t (€)	Annual Debit Relief (€)	Loan Interest through Year t (€)	Reduction of Loan at Year t (€)	Net cash Flow through Year t (€)	$F_t/(1+i)^t$	$\Sigma(F_t/(1+i)^t)$
t	C _{CREW}	C _{MAINTENANCE}	C _{FUEL GAS}	f _t	A _t	L _t	A _{Lt}	I _{Lt}	Δ _{Lt}	F _t	(€)	(€)
0										−1,680,000	−1,680,000	−1,680,000
1	714,000	79,200	12,386,318	1,064,748	155,500	55,000	7831	3850	3981	1,056,917	943,676	−736,324
2	742,560	82,368	12,881,771	1,107,338	155,500	51,019	7831	3571	4259	1,099,507	876,520	140,196
3	772,262	85,663	13,397,042	1,151,631	155,500	46,760	7831	3273	4558	1,143,800	814,135	954,331
4	803,153	89,089	13,932,923	1,197,696	155,500	42,202	7831	2954	4877	1,189,866	756,181	1,710,512
5	835,279	92,653	14,490,240	1,245,604	155,500	37,326	7831	2613	5218	1,237,773	702,346	2,412,858
6	868,690	96,359	15,069,850	1,295,428	155,500	32,108	7831	2248	5583	1,287,598	652,337	3,065,195
7	903,438	100,213	15,672,644	1,347,246	155,500	26,524	7831	1857	5974	1,339,415	605,883	3,671,078
8	939,575	104,222	16,299,550	1,401,135	155,500	20,550	7831	1439	6392	1,393,305	562,732	4,233,810
9	977,158	108,391	16,951,532	1,457,181	155,500	14,158	7831	991	6840	1,449,350	522,650	4,756,460
10	1,016,245	112,726	17,629,593	1,515,468	155,500	7318	7831	512	7318	1,507,637	485,419	5,241,879
11	1,056,894	117,235	18,334,777	1,576,087	155,500	0	7831	0	7831	1,568,256	450,836	5,692,715
NET PRESENT VALUE											NPV	5,692,715
INTERNAL RATE OF RETURN											IRR	0.6659
DISCOUNTED PAYBACK PERIOD											DPB	1.828

Table 15. PWC results for scenario 3.

FINANCIAL METRICS OF SCENARIO 3 (Part 2)							
t	C _{CREW} (€)	C _{MAIN.} (€)	C _{FUEL} (€)	A _{Lt} (€)	C _t (€)	$C_t/(1+i)^t$ (€)	$\Sigma(C_t/(1+i)^t)$ (€)
0					−1,680,000	−1,680,000	−1,680,000
1	714,000	79,200	12,386,318	7831	13,187,349	11,774,419	10,094,419
2	742,560	82,368	12,881,771	7831	13,714,530	10,933,139	21,027,558
3	772,262	85,663	13,397,042	7831	14,262,798	10,151,978	31,179,535
4	803,153	89,089	13,932,923	7831	14,832,996	9,426,637	40,606,173
5	835,279	92,653	14,490,240	7831	15,426,003	8,753,128	49,359,301
6	868,690	96,359	15,069,850	7831	16,042,730	8,127,746	57,487,047
7	903,438	100,213	15,672,644	7831	16,684,126	7,547,051	65,034,099
8	939,575	104,222	16,299,550	7831	17,351,178	7,007,850	72,041,948
9	977,158	108,391	16,951,532	7831	18,044,911	6,507,176	78,549,124
10	1,016,245	112,726	17,629,593	7831	18,766,395	6,042,277	84,591,401
11	1,056,894	117,235	18,334,777	7831	19,516,737	5,610,596	90,201,997
PRESENT WORTH COST						PWC	90,201,997

By inspecting Tables 10–15 and Figures 5–8, the following conclusive remarks can be made:

- The net present value (NPV) in scenario 1 turned from negative to positive between the eighth to the ninth year of investment. This was confirmed by the DPB, which was equal to 8.44 (see Table 10), which was the maximum of the three scenarios (see Figure 7). Thus, although its PWC was between the other two scenarios, scenario 1 became profitable rather marginally from the loan payback period point of view compared to the other two (see Table 11 and Figure 8). This was also verified by the fact that among the three scenarios, scenario 1 had the minimum value of IRR (equal to 0.1638 vs. 0.2788 of scenario 2 and 0.6659 of scenario 3 (see Table 10, Table 12, Table 14 and Figure 6).
- On the other hand, scenario 2 had the maximum PWC (see Figure 8), as it engaged the biggest procurement (that of two turbo generators vs. one generator in scenario 1 and no generator in scenario 3). However, its NPV turned into positive values faster than scenario 1, namely between the fifth and sixth (see Table 10 and Figure 5). Actually, the exact DPB value was calculated to be equal to 5.082 (see Table 12 and Figure 6). The better performance of this investment (always in contrast to scenario 1 which had, however, a lower initial equipment procurement cost) was reflected by the IRR, which was equal to 0.2788 (see Table 12 and Figure 7). The reason as to why the second scenario was proven to be better than the first was attributed to the income due to the electricity sold. The considerably bigger amounts of energy sold (i.e., 34.4 MW for

300 days per year, which sums up to 247,680 MWh) counter-compensate for the initial high acquisition cost fairly quickly.

- Finally, the third scenario is a very conservative but well-guaranteed investment. Its NPV turned positive between the first and second year, with its calculated DPB being 1.828 years. This can be easily explained as the investment was the lowest possible with no additional generator to be acquired, and hence the lowest PWC value. Moreover, the IRR was the highest, equal to 0.6659 (i.e., about 2.4 times that of scenario 2 and four times that of scenario 1).
- In conclusion, the worst investment from all points of view seems to be scenario 1. On the other hand, the scenario with the minimum investment, payback period, but also total profit was scenario 3. Scenario 2 provides an optimum combination of big investment accompanied with high profit in short time periods. Between scenarios 2 and 3, the main difference is whether the initial capital cost is available (through loans or own-income) or not. Still, considering that the income obtained from selling electricity plays a predominant role on how beneficial each alternative scenario can be proven, a further analysis follows next.




Figure 5. Comparative graph of the NPV.




Figure 6. Comparative graph of the IRR.




Figure 7. Comparative graph of the DPB.




Figure 8. Comparative graph of the PWC.

9. Contractual Agreements for Selling Electricity

In the previous section, the cost–benefit analysis highlighted the importance of the income from selling electricity either to other ships (as an alternative to the “shore-to-ship electricity (SSE)” or the inland main grid. The conditions and contractual terms of this selling procedure are investigated in this section, taking into account that the product sold is very close to the concept of “maritime electricity” developed only recently in [22,23].

Within this context, following the global trends of huge amounts of electricity transactions, two types of agreements [15,16] were applied in order to evaluate the benefit or the loss of the investor of a FPGP as an electric energy provider:

- Power purchase agreements—PPAs are bilateral agreements to purchase electricity between an energy seller (who may or may not be a producer) and an energy buyer, which can be a business, an organization or even a group of businesses, and, under conditions, a set of households.

- Contracts for difference—CfDs enable traders to foresee and speculate on the future market movements of an underlying asset (e.g., foreign exchange rate, share prices, stock market index levels, commodities etc.) without actually owning or even taking part in any physical delivery of this underlying asset. CfDs enable the traders to speculate on the short-term movements. The gain or loss depends on the price of the underlying asset when the contract starts and ends.

All ships are, in general, subject to the cost of generating electricity onboard by their own generators. This cost comprises the procurement cost of conventional fuel plus the cost of the lubricants, the penalty to be paid once the ship generates electricity by conventional generator sets using pollutant fuel, and the annual maintenance cost of the generators.

In the case study considered, the cost of generating electricity on board a vessel as an active customer was assumed to be equal to 269 €/MWh [22], which included the cost of the marine diesel oil (MDO) consumed from the generation of electricity as well as the environmental fee for the CO₂ emissions. The additional cost of NO_x, SO_x, PMs, maintenance costs, etc. can be added in the case a more accurate analysis is needed. Evidently, the cost of conventional fuel can fluctuate on an hourly or daily basis, however, we considered it constant for the simplicity of the calculations. This cost was used as the reference value and compared with the cost of the electricity produced by the LNG carrier operating as a FPGP.

The supplier's selling price (*SSP*) in euro per MWh is equal to the pricing of electricity (*PoE*) as above-mentioned, thus is calculated considering the annual LNG cost ($A_{LNG\ cost}$) in euro, the electric energy that is available to be sold (*EE*) in MWh, and the days of trading (*DoT*):

$$SSP = PoE = \frac{A_{LNG\ cost}}{EE \cdot DoT \cdot 24}$$

To calculate the port distribution usage fee, the following formulae were utilized, which comprise a fixed price and a fee proportional to the energy consumed [16]:

- Port distribution usage fee = 0.5 €/MWh + 1.5% of the monthly production cost if the supplier's selling price is greater than 269 €/MWh.
- Port distribution usage fee = 1.725 €/MWh + 5% of the monthly production cost if the supplier's selling price is less than 269 €/MWh.

Hence, the total supply cost of the electricity, named *P* in €/MWh, is the sum of the supplier's selling price plus the distribution usage fee of the distribution network, which in most cases is that of the port where the ship is berthed. The supplier is the FPGP.

On the other hand, the total resultant cost for the ship partner of the PPA, summing all partial, fixed, and variant costs, will be named *C* in €/MWh. Based on the PPA, *C* will be the PPA agreed price of the shore side electricity, and referring to the aforementioned numerical example, *C* must be equal to 269 €/MWh. Following a procedure similar to the one described in [23]:

If $P < C$, then the power supplier has a benefit in excess of the PPA. A portion of the supplier's earnings (i.e., $a\%(C-P)$), feeds the CfD.

If $P > C$, then the power supplier has a loss. In this case, the amount $(P-C)$ reflecting the loss of the trader is to be compensated at least partially by the CfD.

The calculated results obtained from implementing the aforementioned analysis in all three scenarios considered in this paper are presented in Tables 16–18, respectively. The analysis was conducted for a 10-month period that corresponded to the 300-day net operating period of the FPGP above-mentioned. At the end of this period, if the energy supplier (i.e., the FPGP) has a benefit, a portion of it supplies the CfD, whereas in the case of a resultant loss, this loss is compensated by the CfD. The calculated results referring to CfDs are figuratively summarized in Figure 9.

Table 16. Calculated results of scenario 1.

	Supplier' Selling Price (LNG/C as Supplier)	Port Distribution Usage Fee	Total Supply	Production Cost by Ship's D/G Agreed Price	Difference	Loss of Supplier	Benefit of Supplier
Month	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]
1	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
2	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
3	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
4	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
5	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
6	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
7	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
8	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
9	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
10	150.84	15.18	166.02	269.00	−102.98	0.00	102.98
					−1.02982	0.00	1.02982
					PPA	CfD	

Table 17. Calculated results of scenario 2.

	Supplier' Selling Price (LNG/C as Supplier)	Port Distribution Usage Fee	Total Supply	Production Cost by Ship's D/G Agreed Price	Difference	Loss of Supplier	Benefit of Supplier
Month	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]
1	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
2	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
3	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
4	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
5	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
6	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
7	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
8	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
9	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
10	138.07	15.18	153.24	269.00	−115.76	0.00	115.76
					−1.15758	0.00	1.15758
					PPA	CfD	

Table 18. Calculated results of scenario 3.

	Supplier' Selling Price (LNG/C as Supplier)	Port Distribution Usage Fee	Total Supply	Production Cost by Ship's D/G Agreed Price	Difference	Loss of Supplier	Benefit of Supplier
Month	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]	[€/MWh]
1	449.63	4.54	454.16	269.00	185.16	185.16	0.00
2	449.63	4.54	454.16	269.00	185.16	185.16	0.00
3	449.63	4.54	454.16	269.00	185.16	185.16	0.00
4	449.63	4.54	454.16	269.00	185.16	185.16	0.00
5	449.63	4.54	454.16	269.00	185.16	185.16	0.00
6	449.63	4.54	454.16	269.00	185.16	185.16	0.00
7	449.63	4.54	454.16	269.00	185.16	185.16	0.00
8	449.63	4.54	454.16	269.00	185.16	185.16	0.00
9	449.63	4.54	454.16	269.00	185.16	185.16	0.00
10	449.63	4.54	454.16	269.00	185.16	185.16	0.00
					1.85165	1.85165	0.00
					PPA	CfD	




Figure 9. Benefit or loss of FPGP as a supplier.

By inspecting the calculated results, the following remarks can be made:

- The second column in Tables 16–18 corresponds to the selling price of the supplier (i.e., the FPGP). The lowest selling price corresponds to scenario 2 where the amount of energy provided is the largest (34.4 MW for the period of 10 months considered). The price of the first scenario came second as it corresponded to a 19.4 MW capacity of the production unit. Finally, the third scenario ranked third as it only provided 4.4 MW for the production of electricity.
- Regarding the question of whether the PPA results are for the benefit of the supplier (i.e., the FPGP) or not, and hence how the CfD will be used, it can be seen that in the first two scenarios, there was a benefit on behalf of the supplier. Thus, a portion of the resultant total amount in the 10-month yearly period can be used to supply the CfD as its input. In contrast, in the third scenario, the selling price was fairly high as the installed electric power capacity was fairly low (on the order of 4.4 MW). Thus, in this last case (i.e., the third scenario), there were losses on the side of the supplier (see also Figure 9). The latter can be compensated for by the CfD, which in this case, was used to support the supplier.
- In conclusion, as can be easily seen in Figure 9, from this trade-wise approach, the third scenario is the least appealing for the 10-month yearly period considered as it is not beneficial without the supporting tool of CfD. In contrast, the second scenario was the most favorable, resulting in the greatest profit on the side of the supplier, while the first scenario was slightly less favorable.

10. Discussion of the Results

The work presented in this paper aimed to demonstrate a holistic examination of the investment for converting a steam turbine LNG carrier (LNG/C) into a floating power generating plant (FPGP). The examination included both the techno-economical and electricity market points of view.

In order to evaluate the investment from the more conventional CBA point of view, the financial metrics NPV, IRR, DPB, and PWC were used. As discussed, all three examined scenarios had positive financial metrics in the 10-year investment period considered, which proves their profitability in the long-term.

More specifically, the third scenario presented higher NPV and IRR than the other two scenarios and a lower DPB and PWC, which was because the total initial investment

cost was lower as no turbo generators need to be added. In contrast, in scenarios 1 and 2, one or two generators need to be added, respectively.

Still, among the three scenarios, it was shown that scenario 2 (with two generators added) tended to have the optimum values of all four metrics calculated, providing fairly quick payback considering the initial investment cost. This is mainly due to the bigger amounts of energy sold and the corresponding income obtained from this.

On the other hand, from the energy market point of view, the last scenario seems to result in losses on the side of the supplier, and hence, the loss of the trader is to be compensated, at least partially, by the CfD. The other two scenarios presented extremely high benefits for the supplier during every year of trading, which was because the FPGP combines a low energy production cost and a high amount of produced energy.

It is worth noting that in order for the FPGP to be more competitive against other energy producers, the 15% surcharge, as described in Section 7, can be reduced to 10% or even down to 5%; the FPGP will continue to be beneficial for the investor. This portion is the input to the CfDs. The latter can be regarded as a guarantee that ascertains the viability of these types of investments. Taking into account the assumptions made for such studies regardless of how plausible and reasonable they are, there is always the latent uncertainty due to the numerous parameters affecting the final results. As it has been shown, CfDs can finally compensate and correct any contingencies that have occurred.

The conclusions drawn can be fairly appealing in the case where the grid supplied by the FPGP is that of a non-interconnected island, as originally hinted at in [15]. It is noted that in most of these islands, electricity is produced via thermal power plants based on costly but also pollutant oil, either heavy fuel oil or diesel oil [15]. Hence, the investment of retrofitting an LNG/C into an FPGP is not only economically profitable but also more environmentally friendly than that of conventional electricity production methods based on fossil fuels.

11. Conclusions

This paper provides an appealing alternative to extend, in a fairly profitable manner, the lifespan of old generation turbine LNG carriers (LNG/Cs). The solution consists of retrofitting the vessel into a floating power generating plant (FPGP) (i.e., a floating electric power plant providing electricity to shore grids or to other ships at berth). Considering that LNG is an interim but more environmentally friendly fuel than other fossil fuels, this scheme can also be applied to grids where electricity production is based on heavy fuel oil or diesel oil (e.g., in non-interconnecting islands). The paper presents a holistic investigation using both a techno-economical life cycle analysis of the retrofit investment but also by using modern tools of the transactions of the electric energy market, namely power purchase agreements (PPAs) and the contracts for difference (CfDs). The analyses of certain case study scenarios show that a careful investigation of all metrics included in a cost–benefit analysis (CBA), namely the NPV, IRR, DPB, and PWC can be used as a measure of how profitable this investment to retrofit can be in the limited time intervals that are of special interest. This profitability of the investment can be further evaluated based on the optimum combination of PPAs and CfDs that must be used for the electrical transactions engaged. The general conclusion is that this type of retrofit has been proven to be a mutually beneficial solution for all parties involved. Moreover, it has been shown that the scenario consisting of purchasing the biggest possible piece of machinery, which results in the biggest possible electricity production, is the most beneficial. On the other hand, if other less appealing solutions are selected, during implementation, the CfDs provide a guarantee for a finally beneficial result of the investment.

Author Contributions: Conceptualization, A.M.; Methodology, A.M. and J.P.; Validation, D.L. and J.P.; Formal analysis E.S. and A.M.; Investigation, A.M. and E.S.; Data curation, J.P.; Writing—original draft preparation, A.M.; Writing—review and editing, D.L. and J.P.; Visualization, A.M.; Supervision, D.L. and J.P. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: Not applicable.

Conflicts of Interest: The authors declare no conflict of interest.

References

1. Available online: <https://www.consilium.europa.eu/en/press/press-releases/2023/07/25/fueleu-maritime-initiative-council-adopts-new-law-to-decarbonise-the-maritime-sector/> (accessed on 1 August 2023).
2. Available online: https://ec.europa.eu/info/law/better-regulation/have-your-say/initiatives/12438-Sustainable-and-Smart-Mobility-Strategy_en (accessed on 1 August 2023).
3. Available online: https://commission.europa.eu/strategy-and-policy/priorities-2019-2024/european-green-deal/repowereu-affordable-secure-and-sustainable-energy-europe_en (accessed on 1 August 2023).
4. Hutchinson, K.W.; Dobson, D.C. Near-shore floating liquefied gas storage and processing. In *RINA, Design, and Construction & Operation of LNG/LPG Ships, Proceedings of the H.I.M.T-RINA Conference on Design, and Construction & Operation of LNG/LPG Ships, Athens, Greece, 5 December 2018*; Royal Institution of Naval Architects (RINA): London, UK, 2018; pp. 77–83.
5. Frangopoulos, C. *Cogeneration: Technologies, optimization and implementation*; IET Publications: London, UK, 2017; p. 360, ISBN 978-1-78561-055-4.
6. Available online: <https://www.siemens-energy.com/global/en/offerings/power-generation/power-plants/seafloat.html> (accessed on 27 August 2023).
7. Available online: <https://www.becker-marine-systems.com/products/product-detail/becker-lng-hybrid-barge.html> (accessed on 27 August 2023).
8. IEC/ISO/IEEE 80005-1:2019+A1:2022; Utility Connections in Port—Part 1: High Voltage Shore Connection (HVSC) Systems—General Requirements. IEC/ISO/IEEE: Geneva, Switzerland, 2019; pp. 1–76.
9. IEC/ISO/IEEE 80005-1:2012; Utility Connections in Port—Part 2: High and Low Voltage Shore Connection Systems. Data Communication for Monitoring and Control. IEC/ISO/IEEE: Geneva, Switzerland, 2018; pp. 1–56.
10. IEC/ISO/IEEE/PAS 80005-3:2014; Utility Connections in Port—Part 3: Low Voltage Shore Connection (LVSC) Systems—General Requirements. IEC/PAS: Geneva, Switzerland, 2014; pp. 1–56.
11. Available online: https://www.wartsila.com/docs/default-source/oil-gas-documents/gastech/e4_6.pdf?sfvrsn=2 (accessed on 27 August 2023).
12. Available online: <https://www.wartsila.com/docs/default-source/oil-gas-documents/white-paper-o-ogi-2013-lng-power-production.pdf> (accessed on 27 August 2023).
13. Budiyanto, M.A.; Riadi, A.; Sumanta Buana, I.G.N.; Kurnia, G. Study on the LNG distribution to mobile power plants utilizing small-scale LNG carriers. *Heliyon* **2020**, *6*, e04358. [CrossRef] [PubMed]
14. Available online: <https://cdn.wartsila.com/docs/default-source/oil-gas-documents/brochure-lng-shipping-solutions.pdf> (accessed on 27 August 2023).
15. Lyridis, D.V.; Papaleonidas, C.; Prousalidis, J.; Sofras, E. A general methodology for examining the feasibility of LNG supply chains to insular regions for power generation purposes. In *RINA, Design, and Construction & Operation of LNG/LPG Ships, Proceedings of the H.I.M.T-RINA Conference on Design, and Construction & Operation of LNG/LPG Ships, Athens, Greece, 5 December 2018*; Royal Institution of Naval Architects (RINA): London, UK, 2018.
16. Nilsson, D. Regasification Vessels with Power Generation Requirements and Recommendations for Gas Power Generation Vessels. Master's Dissertation, Chalmers University of Technology, Gothenburg, Sweden, 2012.
17. Lyridis, D.; Papaleonidas, C.; Stobkan, G.; Prousalidis, J.; Sofras, E.; Anaxagorou, P. Novel technical perspectives for alternative commercial use of old LNG carriers. In *Proceedings of the MOSES 2019 Conference, 2nd International Conference on Modelling and Optimisation of Ship Energy Systems*, Glasgow, UK, 8–10 May 2019.
18. Stopkan, G. *Investigating Alternative Utilisation Possibilities for LNG Carriers Producing Electricity*; National Technical University of Athens: Athens, Greece, 2018. (In Greek)
19. D'Agostino, F.; Kaza, D.; Schiapparelli, G.P.; Silvestro, F.; Bossi, C.L.; Colzi, F. Assessment of the Potential Shore to Ship Load Demand: The Italian Scenario. In *Proceedings of the 2021 IEEE Power & Energy Society General Meeting (PESGM)*, Washington, DC, USA, 26–29 July 2021. [CrossRef]
20. *Shore-Side Electricity Guidance to Port Authorities and Administrations*; European Maritime Safety Agency (EMSA): Lisbon, Portugal, 2022.
21. ESPO. *Position of the European Sea Ports Organisation on the Fuel EU Maritime Initiative*; ESPO: Leicester, UK, 2020.
22. Manos, A.; Lyridis, D.; Prousalidis, J. The Maritime Sector in the electric Energy Markets. In *Proceedings of the ESARS-IEC 2023*, Venice, Italy, 28–31 March 2023. [CrossRef]
23. Manos, A.; Lyridis, D.; Prousalidis, J. Establishing a Framework of the Open Maritime Electric Energy Market. *Energies* **2023**, *16*, 5276. [CrossRef]

24. Directive (EU) 2019/944 of the European Parliament and of the Council of 5 June 2019 on Common Rules for the Internal Market for Electricity and Amending Directive 2012/27/EU. Available online: <https://eur-lex.europa.eu/legal-content/EN/TXT/PDF/?uri=CELEX:32019L0944> (accessed on 1 August 2023).
25. Fernández, I.A.; Gómez, M.R.; Gómez, J.R.; Insua, Á.B. Review of propulsion systems on LNG carriers. *Renew. Sustain. Energy Rev.* **2017**, *67*, 1395–1411. [[CrossRef](#)]
26. Frangopoulos, C.; von Spakovsky, M.; Sciubba, E. A Brief Review of Methods for the Design and Synthesis Optimization of Energy Systems. *Int. J. Appl. Thermodyn.* **2002**, *5*, 151–160. [[CrossRef](#)]
27. Historical Records of LNG Prices 1990–2022. Available online: <https://tradingeconomics.com/commodity/natural-gas> (accessed on 1 August 2023).

Disclaimer/Publisher’s Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.