



Article Modern Optimal Controllers for Hybrid Active Power Filter to Minimize Harmonic Distortion

Feras Alasali ^{1,*}^(D), Khaled Nusair ²^(D), Husam Foudeh ³^(D), William Holderbaum ⁴, Arangarajan Vinayagam ⁵^(D) and Asma Aziz ⁶^(D)

- ¹ Department of Electrical Engineering, Faculty of Engineering, The Hashemite University, P.O. Box 330127, Zarqa 13133, Jordan
- ² Protection and Metering Department, National Electric Power Company, Amman 11181, Jordan; khalednusair2016@yahoo.com
- ³ Department of Electrical Engineering, Faculty of Engineering, Mutah University, Mutah, AlKarak 61710, Jordan; husamfoudeh@yahoo.com
- ⁴ School of Science, Engineering & Environment, University of Salford, Salford M5 4WT, UK; w.holderbaum@salford.ac.uk
- ⁵ Department of Electrical and Electronics Engineering, New Horizon College of Engineering, Bangaluru 560087, India; arajanin@gmail.com
- ⁶ School of Engineering, Edith Cowan University, Joondalup, WA 6027, Australia; asma.aziz@ecu.edu.au
- Correspondence: ferasasali@hu.edu.jo; Tel.: +962-(5)-3903333

Abstract: Nowadays, AC distributed power networks are facing many challenges in guaranteeing and improving the required level of power quality indices in power networks with increasing nonlinear, time-variable and unbalanced loads. Power networks can benefit from avoiding and minimizing different AC problems, such as frequency fluctuation and Total Harmonic Distortions (THDs), by using power filters, such as Hybrid Active Power Filters (HAPFs). Therefore, attention towards responsible power quality indices, such as Total Harmonic Distortion (THD), Power Factor (P.F) and Harmonic Pollution (HP) has increased. THD and HP are important indices to show the level of power quality at the network. In this paper, modern optimization techniques have been employed to optimize HAPF parameters, and minimize HP, by using a nature-inspired optimization algorithm, namely, Whale Optimization Algorithm (WOA). The WOA algorithm is compared to the most competitive powerful metaheuristic optimization algorithms: Manta Ray Foraging Optimization (MRFO), Artificial Ecosystem-based Optimization (AEO) and Golden Ratio Optimization Method (GROM). In addition, the WOA, and the proposed modern optimization algorithms, are compared to the most competitive metaheuristic optimization algorithm for HAPF from the literature, called L-SHADE. The comparison results show that the WOA algorithm outperformed all other optimization algorithms, in terms of minimizing harmonic pollution, through optimizing parameters of HAPF; therefore, this paper aims to present the WOA as a powerful control model for HAPF.

Keywords: hybrid active power filter; metaheuristic optimization algorithms; total harmonic distortion; power quality; harmonic pollution

1. Introduction

1.1. Background

Recently, electrical energy consumption has increased worldwide, due to the increase in population and the electrification of industrial processes, such as vehicles, and new customers' behavior in observing rapid technological progress. Therefore, attention towards responsible energy utilization and high-power quality indices has increased [1,2]. Power networks benefit from avoiding and minimizing different AC problems, such as frequency fluctuation and THD [2]. However, AC distributed power networks have faced many challenges in guaranteeing and improving the required level of power quality indices, with



Citation: Alasali, F.; Nusair, K.; Foudeh, H.; Holderbaum, W.; Vinayagam, A.; Aziz, A. Modern Optimal Controllers for Hybrid Active Power Filter to Minimize Harmonic Distortion. *Electronics* 2022, 11, 1453. https://doi.org/ 10.3390/electronics11091453

Academic Editor: Nicu Bizon

Received: 30 March 2022 Accepted: 29 April 2022 Published: 30 April 2022

Publisher's Note: MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Copyright: © 2022 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (https:// creativecommons.org/licenses/by/ 4.0/). increasing nonlinear loads [3,4]. In the last few years, there has been an increase in interest in improving the efficiency of power filters to improve devices and network performance. This process is described in [5,6] as a complex and challenging optimization problem. In this work, the proposed new optimization algorithms have been tested and employed to achieve optimal performance in terms of power quality.

1.2. Literature Review

In general, nonlinear load is caused by two main types of harmonic distortions: current and voltage harmonic sources [5–7]. In addition, non-linear loads lead to lower power factors, higher power transmission-line losses and higher Total Harmonic Distortions (THDs). In power systems, minimizing the THD is an important and main task in improving the power quality of the electrical system. In the last few years, power filters have been studied and used to minimize the THD from the power grid. In general, there are three main types of power filters: Passive Power Filter (PPF), Active Power Filter (APF) and Hybrid Active Power Filter (HAPF) [5]. However, the disadvantage of using PPFs in the power network is limited ability to follow the dynamic behavior of nonlinear loads. To overcome this problem, APF has three-phase Pulse Width Modulated (PWM) included and uses voltage source inverters, which have more efficiency, less cost and less size compared to PPFs [8]. Therefore, HAPFs have been introduced as a solution that have the benefits of APF and PPF due to combining them [5,8].

In the literature, many studies have concentrated on controlling PPF by using different optimization algorithms, such as Particle Swarm Optimization (PSO) and direction hybrid [9,10]. However, the literature [8–10] focused on using a common control method (PWM) [8], and developing optimal control for power filters based on a common optimization algorithm (PSO) [9,10]. The results in [9,10] did not consider the significance of using modern optimization algorithms. Therefore, developing and employing new and powerful metaheuristic optimization algorithms, such as WOA, can be beneficial for improving the power quality performance in the network. There is a limited number of studies on designing HAPF-based metaheuristic optimization algorithms, due to the complexity of the model. For example, the authors in [8] have used the L-SHADE optimization algorithm to improve HPAF. However, the L-SHADE optimization algorithm has only been compared to a common algorithm, such as the Differential Evolution (DE) algorithm. In addition, to the best of the authors' knowledge, there is no work on HAPF that has been addressed by using these modern optimization algorithms and which include a comprehensive comparative case study for the optimization algorithms. In this paper, modern optimization techniques have been employed on HAPF to minimize the THD and improve the power quality at power networks. The modern optimization techniques in this work are: Whale Optimization Algorithm (WOA) [11], Manta ray foraging optimization (MRFO) [1,12], Artificial Ecosystem-based Optimization (AEO) [13] and Golden Ratio Optimization Method (GROM) [14,15]. These modern optimization algorithms have been compared to the following powerful, and most competitive, metaheuristic optimization algorithms: Autonomous Groups Particles Swarm Optimization (AGPSO), Modified Particle Swarm Optimization (MPSO), Improved Particle Swarm Optimization (IPSO) [16], Equilibrium Optimizer (EO) [17,18] and L-SHADE optimization algorithm [8]. Among modern optimization techniques, the WOA has a great deal of experience in solving complex engineering optimization problems [11,19]. The obvious advantages, such as simplicity, flexibility, fast convergence speed, and stochastic nature, have attracted considerable interest from the current research community in a variety of fields, including electrical and power systems, data mining and machine learning, and wireless sensor networks [19,20]. Therefore, this paper aims to present the WOA as a powerful control model for HAPF parameter optimization.

1.3. Contributions

In this work, the proposed optimization algorithm, WOA, has been evaluated on two configurations of HAPF. The first configuration included the APF and the shunt passive filter in series with non-linear load and source. In the second configuration, the APF and the shunt passive filter were combined and connected with non-linear load and source. In both configurations, the THD problem in HAPF was formulated as a single objective function [5,8]. The proposed optimization algorithms were applied in this work to minimize voltage and current THD at the same time. In general, a limited number of researchers [8] have focused on applying common optimization algorithms to solve the THD problem in HAPF. Achieving the minimum THD for HAPF is a complex and challenging task. Therefore, it is important to employ more flexible and modern optimization algorithms. The main contributions of this paper can be summarized as follows: firstly, a new optimization algorithm, WOA, is applied and employed to improve the performance of HAPF; secondly, a comprehensive comparative case study is conducted for the proposed modern optimization algorithms (MRFO, AEO, GROM) and the common powerful optimization methods from literature (AGPSO, MPSO, IPSO, EO, L-SHADE). To the best of the author's knowledge, there is no work on HAPF that has addressed using these modern optimization algorithms.

1.4. Outline of Paper

The remainder of this article is organized as follows: the circuit system of HAPF and the optimization problem are introduced in Section 2; the optimization process and WOA algorithm are presented in Section 3; case studies and results of the proposed optimization models are discussed in Sections 4 and 5; and, finally, the conclusions and summary of this work are presented in Section 6.

2. Methodology

In this article, HAPFs are used to improve the power quality of power circuits. In power systems, minimizing HP and THD are significant factors in improving power quality of the electrical system. However, to achieve higher power quality, it is necessary to optimally control the HAPF. In this work, different modern optimization algorithms are evaluated on two configurations of HAPF. The outline scheme of the HAPF optimal controlling process is:

- Firstly, the topology of HAPF and the problem statement are described. In Section 2.1, the description of the HAPF, based on two configurations, is presented. Based on the topology of HAPF, the power quality problem has been described as an optimization problem under a number of constraints.
- Secondly, the HAPF optimization problem has been solved by using different optimization algorithms. Section 3 presents the methodology of the optimization algorithms to solve the HAPF optimization problem.

2.1. System Description and Problem Statement: Hybrid Active Power Filters

The basic topology of HAPF for the system is shown in Figure 1. This system consists of a power supply (voltage source), HPAF and a nonlinear load. As previously discussed, HAPF is mainly the combination of PPF and APF [8,19].

In this work, two configurations of HAPF are commonly used in power systems. Figure 2a presents the first configuration of HAPF, where the APF and the shunt passive filter are in a series with a nonlinear load and source. In this configuration, the APF injects a harmonic compensation current to cancel the load harmonic and improve the performance of PPF. In addition, the dropped voltage over the PPF will also reduce the voltage rating of the APF [5]. In the second configuration, as shown in Figure 2b, the APF and the shunt passive filter are combined. This configuration allows a lower rating of current in the APF, due to high impedance at the series APF. In Figure 2, the point of common coupling (PCC) represents the point where the load is connected to the system. The PPF is represented by

inductive, Z_L , and reactance, Z_C , as tuned filter, as shown in Figure 2. The voltage and current source, transmission line resistance and reactance and load current at the harmonic, H, are presented by V_{SH} , I_{SH} , R_{SH} , L_{SH} and I_{LH} , respectively. To minimize the voltage THD, APF works as a controlled voltage source. The APF injects a voltage harmonic waveform to cancel the voltage THD in the system. The voltage harmonic waveform is equal to the proportional factor, F, of the harmonic current. In this work, the proposed optimization method aimed to find the optimal values of F, Z_L , and Z_C under both configurations so as to achieve the minimum impact of THD [5,8].



Figure 1. The basic configuration of HAPF.



(a) Configuration 1 of HAPF

Figure 2. Cont.



(**b**) Configuration 2 of HAPF

Figure 2. The main circuit of configurations 1 and 2 of HAPF.

In general, HAPF combines both APF and PPF to reduce the size and cost of the filter compared to APF. HAPF, under the main two topologies, shown in Figure 2, is normally used for compensation in industrial power systems. This compensation is worked without indicating the interface transformer at the power system [5–8]. In the power system, the PCC is the closest point to the load and is identified as the point where the load is connected to the power system. This common power system structure will help controllers achieve synchronization with the grid voltage, as presented in [2,5,8]. In addition, common control strategy and power transformation, to compensate for currents, voltages and power, are based on the synchronous reference frame detection method as described in [2] and used in [2,5,8].

In this work, the impact of THD on the power system is represented by Harmonic Pollution (HP) as per [21]. In power networks, the higher the level of HP, the greater the potential risk, installation and power quality problems at the power network. The HP is described by Equation (1)

$$HP = \sqrt{VTHD^2 + ITHD^2}$$
(1)

where the VTHD and ITHD are the voltage and current THD, respectively. The F, Z_L , and Z_C as decision variables are then used to minimize HP by minimizing VTHD and ITHD. The description of the common and known VTHD and ITHD equations is prescribed by IEEE 519-2014 [22]. Equation (2) describes the optimization problem in this work.

$$\underset{F, Z_L, Z_C}{\operatorname{arg min} HP} \tag{2}$$

Subject to the following:

• HAPF parameters [8,22].

$$0 \le F \le 20 \tag{3}$$

$$0 \le Z_L \le 10 \tag{4}$$

$$0 \le Z_C \le 10 \tag{5}$$

The VTHD and ITHD limitation (VTHD_{lim}, ITHD_{lim}) based on IEEE 519-2014 [22].

$$VTHD \le VTHD_{lim} \tag{6}$$

$$ITHD \le ITHD_{lim} \tag{7}$$

• Power factor limitation [8,22].

$$PF = PF_{target} + \varepsilon \tag{8}$$

where the power factor in the network, PF, needs to be equal to the target power factor with a small error, ε , less than 10^{-2} .

3. Description of the Modern Optimization Algorithms

The optimal operation of HAPF requires minimization of HP by selecting optimal decision variables F, Z_L , and Z_C to reduce VTHD and ITHD. The objective function, as described in Equation (2), is designed to minimize HP by considering the optimal values of F, Z_L , and Z_C under several constraints, Equations (3) to (8). In this study, the proposed WOA is considered to optimize the parameters of HAPF, and the results of the proposed WOA are compared with other modern optimization algorithms, such as MRFO, AEO, and GROM.

Modern optimization algorithms are employed and applied in this work to find and achieve the minimum HP: Whale Optimization Algorithm (WOA) [11], Manta ray foraging optimization (MRFO) [1,12], Artificial Ecosystem-based Optimization (AEO) [13] and Golden Ratio Optimization Method (GROM) [14,15]. These modern optimization algorithms were used to solve complex and stochastic optimization problems in the simplest way within a low computational. In addition, the results of the proposed WAO optimization algorithm were compared to powerful, and most competitive, metaheuristic optimization algorithms, namely: Autonomous Groups Particles Swarm Optimization (AGPSO), Modified Particle Swarm Optimization (MPSO), Improved Particle Swarm Optimization algorithm [8]. From the results of the analysis, it is shown that the WOA algorithm outperformed all other optimization algorithms in terms of minimizing HP. Therefore, this paper aims to present the WOA as a powerful control model for HAPF. The WOA optimization algorithm is explained in detail below:

Whale Optimization Algorithm

The Whale Optimization Algorithm (WOA) is a metaheuristic optimization algorithm proposed by Mirjalili and Lewis [11]. The WOA is nature-inspired, based on the natural movement behavior of humpback whales. The WOA algorithm utilizes the hunting strategy for whales as inspiration to find an optimal solution. The WOA algorithm is tested with 35 common optimization and engineering problems, and compared to benchmarked methods, such as the Particle Swarm Optimization (PSO) method [16]. The results showed that the WOA outperformed the common methods and presented a competitive algorithm for solving complex problems, such as power quality problems in the power system. In WOA, the search area is randomly generated and updated every iteration, based on the best solution location. The solution-represented particle, which connects to the position, acts as a search agent. This process can be presented by the following equations

$$\vec{\mathbf{d}} = \left| \vec{\mathbf{c}} \cdot \vec{\mathbf{x}_p}(\mathbf{n}) - \vec{\mathbf{x}}(\mathbf{n}) \right| \tag{9}$$

$$\vec{x}(n+1) = \vec{x_p}(n) - \vec{a}.\vec{d}$$
(10)

where n is the current iteration, \vec{x} is the position vector, d is a vector to compare the best solution $(\vec{x_p}(n))$ to the current solution $\vec{x}(n)$, $\vec{x_p}$ is the best solution that has been found so far (the $\vec{x_p}$ will be updated at each iteration in case a better solution is found), \vec{a} and \vec{c} are coefficient vectors.

A fitness function (optimization problem) is used to evaluate the solutions and then move towards the optimal solution, based on the inspiration of whale behaviors [8]. The main steps for solving the HAPF optimization problem, Equation (2), by using the WOA algorithm, are summarized in Figure 3. The objective function (optimization problem), the cost function, Equation (2), is selected as the problem we aim to solve and the fitness function in WOA. Then, the WOA starts with generating a random population (exploration phase) within the domain by using the following equations

$$\vec{d} = \left| \vec{c} \cdot \vec{x}_{ra} - \vec{x} \right|$$
(11)

$$\vec{x}(n+1) = \vec{x_{ra}} - \vec{a}.\vec{d}$$
(12)

where x_{ra} is the random position vector (exploration phase), which is chosen from the available population.



Figure 3. A flow chart of Whale Optimization Algorithm (WOA) for the HAPF problem.

In the step, the size of the population and the number of iterations for solving the problem need to be selected. The searching process is started by evaluating each new search agent (solution) by using the fitness function, Equation (2), under the constraints described by Equations (3)–(8). The WOA algorithm is worked, based on an iteration process. At each iteration, the position of the search agent (solution) is updated, based on the best solution obtained in Step 3, and a new random solution generated to avoid the local optimal solution. In general, after the best solution within three phases, based on the movement of the whale. Firstly, the encircling prey phase aims to let the search agents update their positions in the neighborhood of the current best solution. Secondly, the bubble-net attacking method (exploitation phase) includes a new random position for a

search agent between the current position of the solution and the current position of the best solution. Thirdly, the search for prey (exploration phase) aims at avoiding the local optimal solution by updating the position of the search agent, based on a new random agent from the domain, instead of the best solution agent. This process is repeated from 2 to 4 until the maximum number of iterations is achieved as a termination criterion.

4. Case Studies

As described in Figure 2, two configurations of HAPF are used in the paper to evaluate the performance of the proposed modern optimization algorithms. To check the stability, and robustness, and to evaluate these algorithms, the two configurations of HAPF are simulated with different model parameters under three case studies, as presented in Tables 1 and 2. In these case studies, the industrial plant is connected to a total three-phase apparent load equal to 5.1 + j4.965 MVA at a line-to-line voltage equal to 4.16 kV. In addition, the rated short circuit capacity is 80 MVA and the target power factor, PF_{target} , is 95%. The limitations of the VTHD and ITHD, VTHD $_{lim}$ and ITHD $_{lim}$, are determined to be 5%. The level of load can slightly impact the levels of the harmonics; for example, increasing the nonlinear loads will increase the current magnitude and harmonics but without impacting on the optimization algorithms' performance. In this work, the numerical data of these case studies were used as common data for an industrial plant [8,22]. In addition, this paper aims to employ three different case studies (different levels of source harmonics) to evaluate the proposed optimization algorithms. In Tables 1 and 2, the voltage and current source, transmission line resistance and reactance, and load current at harmonic, H, are presented by V_{SH} , I_{SH} , R_{SH} , L_{SH} and I_{LH} , respectively. In addition, the current load, voltage load, load resistance at harmonic, H, are presented by I_{LH} , V_{LH} , R_{LH} and Z_{LH} , respectively.

Parameters	Case 1	Case 2	Case 3
$R_{S1}(\Omega)$	0.02163	0.02163	0.02163
I _{S1} (A)	0.2163	0.2163	0.2163
$R_{L1}(\Omega)$	1.7421	1.7421	1.7421
$Z_{L1}(\Omega)$	1.696	1.696	1.696
V _{S1} (KV)	2.4	2.4	2.4
V _{S5} (%V _{S1})	0	2	4
V _{S7} (%V _{S1})	0	1.5	3
V_{S11} (% V_{S1})	0	1	2
V _{S13} (%V _{S1})	0	0.5	1
I_{L5} (% I_{L})	40	40	40
I _{L7} (%I _L)	6	6	6
I _{L11} (%I _L)	2	2	3
I _{L13} (%I _L)	1	1	2

Table 1. The parameters of case studies for configuration 1 of HAPF.

The three case studies for each configuration, as presented in Tables 1 and 2, aim to evaluate the performance of the optimization algorithms with different levels of voltage and current harmonic distortions.

The main aim of using the proposed modern optimization method is to minimize the HP under the different operation cases. In this work, the performance of the proposed modern optimization method was compared to powerful metaheuristic optimization algorithms from the literature. In this work, the parameters of optimization algorithms are determined as the optimal value over a testing range, as presented in Table 3.

Parameters	Case 1	Case 2	Case 3
$R_{S1}(\Omega)$	0.02163	0.02163	0.02163
I _{S1} (A)	0.2163	0.2163	0.2163
$R_{L1}(\Omega)$	1.7421	1.7421	1.7421
$Z_{L1}(\Omega)$	1.696	1.696	1.696
V _{S1} (KV)	2.4	2.4	2.4
V _{S5} (%V _{S1})	0	2	4
V _{S7} (%V _{S1})	0	1.5	3
V _{S11} (%V _{S1})	0	1	2
V _{S13} (%V _{S1})	0	0.5	1
I _{L5} (%I _L)	40	40	40
I _{L7} (%I _L)	6	6	6
I_{L11} (% I_{L})	2	2	2
I_{L13} (% I_{L})	1	1	1

Table 2. The parameters of case studies for configuration 2 of HAPF.

Table 3. The main parameters of the optimization algorithms.

Algorithm	Parameters	Values
	Size of population	100
MRFO	Maximum iteration number	500
	Shape constant	1
	Constant values for controlling exploration (a1)	2
	Constant values for controlling exploitation (a2)	1
EO	Number of search particles	100
	Maximum number of iterations	500
	Generation probability	0.5
	Coefficient of inertia	Decreasing from 0.9 to 0.4 (linearly)
IDCO	Search agent number	100
1150	Maximum iteration number	500
	Coefficient of acceleration	1 and 2
	Coefficient of inertia	Decreasing from 0.9 to 0.4 (linearly)
AGPSO	Number of search agents	100
	Maximum iteration number	500
	Inertia coefficient	1 and 2
AEO	Size of population	100
	Maximum number of iterations	500
	Golden ratio	1.618
GROM	Number of search agents	100
	Maximum number of iterations	500
	Coefficient of inertia	Decreasing from 0.9 to 0.4 (linearly)
	Search agent number	100
MPSO	Maximum iteration number	500
	Coefficient of acceleration	1 and 2
MOA	Number of search agents	100
WOA	Maximum number of iterations	500

5. Results and Discussion

The optimized results obtained from the proposed WOA, modern and other optimization algorithms, for the two configuration models of HAPF are presented in the following subsections. Firstly, the proposed optimization methods are evaluated in terms of HP, VTHD and ITHD, in all cases. Then, the harmonics of compensated system results for all algorithms under different cases are presented. Finally, a comparison section is presented to show and compare the performance of all algorithms under different scenarios. In general, the proposed optimization algorithm, WOA, outperformed all other optimization algorithms, by achieving the minimum HP in all simulations. In addition, the proposed WOA algorithm provided a higher power quality level, compared to the other algorithms, in terms of minimum VTHD and ITHD.

5.1. Harmonics Analysis under all Case STUDY Conditions

This section presents the performance of the optimization methods in this paper under different operation scenarios. Tables 4 and 5 present the results of the proposed optimization algorithms for configurations 1 and 2 of HAPF over three different cases, as discussed in Section 4. The results in Tables 4 and 5 show that the WOA outperformed all algorithms in terms of the HP for all cases. In addition, the proposed optimization method achieved a lower HP compared to L-SHADE [8] from the literature for all cases. In general, the results in Tables 4 and 5 show that the increasing trend of voltage leads to an increase in the VTHD, ITHD and HP.

Table 4. The results of optimization algorithms for configuration 1 of the HAPF system over the three different cases.

Optimization	Z _C (Ω)	$Z_L(\Omega)$	F (Ω)	I _S (A)	V _{LH} (V)	Transmission Efficiency (%)	Transmission Loss (W)	ITHD (%)	VTHD (%)	HP (%)
Algorithm						Case 1				
WOA	2.709668	0.103934	19.9999	753.8507	2430.08	99.29864169	12,292.13	0.199743	0.125255	0.235766692
AEO	2.709428	0.103694	20	753.8507	2430.08	99.29864169	12,292.13	0.199949	0.12501	0.235811789
AGPSO	2.709443	0.103709	20	753.8507	2430.08	99.29864169	12,292.13	0.199935	0.125025	0.235807572
GROM	2.709394	0.10366	20	753.8507	2430.08	99.29864169	12,292.13	0.199982	0.124976	0.23582184
MPSO	2.709576	0.103842	20	753.8507	2430.08	99.29864169	12,292.13	0.199816	0.12516	0.235778556
IPSO	2.709523	0.103789	20	753.8507	2430.08	99.29864169	12,292.13	0.199862	0.125106	0.23578841
EO	2.709515	0.10378	20	753.8507	2430.08	99.29864169	12,292.13	0.199869	0.125097	0.235790216
MRFO	2.709479	0.103745	19.9999	753.8507	2430.08	99.29864169	12,292.13	0.199902	0.125061	0.235798895
L-SHADE [8]	2.7094	0.10365	20	752.9	2431.59	99.29	12,290	0.2	0.125	0.236
						Case 2				
WOA	2.608059	0	19.9999	753.612	2430.56	99.29899871	12,284.35	1.438586	2.329165	2.737615864
AEO	2.699685	0.091682	20	753.5515	2430.79	99.29912149	12,282.37	0.511079	2.703904	2.7517811
AGPSO	2.699563	0.09156	19.9999	753.5516	2430.79	99.29912131	12,282.38	0.511591	2.703398	2.751378991
GROM	2.674307	0.066684	19.6643	753.6114	2430.75	99.29902512	12,284.33	0.699179	2.598871	2.751278888
MPSO	2.699501	0.091499	20	753.5516	2430.79	99.29912122	12,282.38	0.511848	2.703144	2.751177609
IPSO	2.699511	0.091509	20	753.5516	2430.79	99.29912124	12,282.38	0.511804	2.703187	2.751211422
EO	2.69933	0.091329	19.9966	753.5518	2430.79	99.29912097	12,282.38	0.512653	2.702439	2.75063412
MRFO	2.699031	0.09103	19.9848	753.5519	2430.79	99.29912066	12,282.39	0.514242	2.701195	2.749708921
L-SHADE [8]	2.6998	0.09176	20	753.55	2430.8	99.3	12,280	0.511	2.704	2.752
						Case 3				
WOA	2.615877	0	9.75041	752.8964	2431.86	99.30003131	12,261.03	3.307698	4.594555	5.661343106
AEO	2.615877	$4.85 imes 10^{-17}$	9.75103	752.8964	2431.86	99.30003134	12,261.03	3.307491	4.594606	5.661263412
AGPSO	2.615877	0	9.75103	752.8964	2431.86	99.30003134	12,261.03	3.307491	4.594606	5.661263412
GROM	2.615877	0	9.75103	752.8964	2431.86	99.30003134	12,261.03	3.307491	4.594606	5.661263412
MPSO	2.615877	0	9.75103	752.8964	2431.86	99.30003134	12,261.03	3.307491	4.594606	5.661263412
IPSO	2.615877	0	9.75103	752.8964	2431.86	99.30003134	12,261.03	3.307491	4.594606	5.661263412
EO	2.615877	0	9.75103	752.8964	2431.86	99.30003134	12,261.03	3.307491	4.594606	5.661263412
MRFO	2.615877	$1.25~ imes~10^{-7}$	9.75101	752.8964	2431.86	99.30003133	12,261.03	3.307493	4.594606	5.66126432
L-SHADE [8]	2.6159	$1.36~ imes~10^{-8}$	9.75	752.9	2431.87	99.3	12,260	3.306	4.609	5.672

Table 5. The results of optimization algorithms for configuration 2 of HAPF system over the three different cases.

Optimization	Z _C (Ω)	$Z_L(\Omega)$	F (Ω)	I _S (A)	V _{LH} (V)	Transmission Efficiency (%)	Transmission Loss (W)	ITHD (%)	VTHD (%)	HP (%)
Algorithm						Case 1				
WOA	2.710505	0.10477230	20	753.8507	2430.08	99.29864162	12,292.13298	0.192439	0.12102636	0.22730
AEO	2.710115	0.10438244	20	753.8507	2430.08	99.29864162	12,292.1331	0.192657	0.12064263	0.22731
AGPSO1	2.710018	0.10428551	20	753.8507	2430.08	99.29864162	12,292.13313	0.192731	0.12055103	0.22732
GROM	2.709904	0.10417129	19.9999	753.8507	2430.08	99.29864161	12,292.13315	0.192829	0.12044509	0.22735
MPSO	2.709984	0.10425194	20	753.8507	2430.08	99.29864162	12,292.13313	0.192759	0.12051967	0.22733
IPSO	2.709942	0.10420972	20	753.8507	2430.08	99.29864161	12,292.13314	0.192795	0.12048048	0.22734
EO	2.709979	0.10424678	20	753.8507	2430.08	99.29864162	12,292.13313	0.192763	0.12051486	0.22733
MRFO	2.710062	0.10432978	19.9999	753.8507	2430.08	99.29864159	12,292.13366	0.192696	0.12059295	0.22732
L-SHADE [8]	2.7099	0.10416	20	753.85	2430.09	99.29	12,290	0.193	0.12	0.2274
						Case 2				
WOA	2.690802	0.08284364	20	753.5593	2430.77	99.29910792	12,282.63264	0.559311	2.66508995	2.72314
AEO	2.700516	0.09251425	19.9999	753.5513	2430.79	99.29912184	12,282.37063	0.503653	2.70512008	2.75160
AGPSO	2.700648	0.09264524	20	753.5511	2430.79	99.29912208	12,282.36593	0.503084	2.70566005	2.75203
GROM	2.701244	0.09323842	20	753.5506	2430.79	99.29912297	12,282.34878	0.500571	2.70810475	2.75397
MPSO	2.701180	0.09317464	20	753.5507	2430.79	99.29912285	12,282.35121	0.500836	2.70784197	2.75376
IPSO	2.701108	0.09310331	20	753.5507	2430.79	99.29912274	12,282.3532	0.501134	2.70754803	2.75353

Optimization	Z _C (Ω)	Z _L (Ω)	F (Ω)	I _S (A)	V _{LH} (V)	Transmission Efficiency (%)	Transmission Loss (W)	ITHD (%)	VTHD (%)	HP (%)
Algorithm						Case 2				
EO MRFO L-SHADE [8]	2.699022 2.700827 2.7013	0.09102766 0.09279294 0.09331	19.9998 19.9993 20	753.5525 753.5468 753.55	2430.79 2430.79 2430.8	99.29911973 99.29912871 99.3	12,282.4107 12,282.22403 12,2800	0.510492 0.502473 0.5	2.69898720 2.70626688 2.708	2.74684 2.75251 2.754
						Case 3				
WOA	2.616002	5.096×10^{-5}	10.3001	752.8877	2431.87	99.30004442	12,260.74687	3.312369	4.61549677	5.680073
AEO	2.615950	2.19×10^{-16}	10.3055	752.8877	2431.87	99.30004442	12,260.74776	3.311876	4.61549756	5.680787
GROM	2.615950	2.16×10^{-16}	10.3055	752.8877	2431.87 2431.87	99.30004442 99.30004442	12,260.74776	3.311876	4.61549756	5.680787
MPSO	2.615950	0	10.3055	752.8877	2431.87	99.30004442	12,260.74776	3.311876	4.61549756	5.680787
EO	2.615950	0	10.3055	752.8877	2431.87 2431.87	99.30004442 99.30004442	12,260.74776	3.311876	4.61549756	5.680787
MRFO L-SHADE [8]	2.615950 2.6188	1.119×10^{-7} 1.81×10^{-4}	10.3055 8.84	752.8877 752.68	2431.87 2431.88	99.30004441 99.3	12,260.74811 12.26	3.311877 3.312	4.61549756 4.615	5.680787 5.6814

Table 5. Cont.

5.2. Results of Harmonics with Compensated System

Figures 4 and 5 present the individual voltage and current harmonics (V_{LH}) and (I_{LH}), respectively, for various cases under HAPF configuration 1. The results presented in Figures 4 and 5 show evidence that all optimization algorithms satisfied the achievement of limitation of harmonics required in standard IEEE 519, (V_{LH} \leq 3), I_{LH}(H = 5,7) < 4, and I_{LH}(H = 11, 13) < 2 [8,20]. In Figure 4, the WOA outperformed the other proposed optimization algorithms by reducing the voltage harmonic (V_{LH}). For example, the WOA reduced the voltage harmonic (V_{L5}) at case 2 by 23% compared to other algorithms. The voltage and current harmonics. The WOA outperformed all algorithms and slightly improved the performance, except for the I_{L5} in case 2, where the WOA recorded the highest value with 1.35%. However, the WOA for the I_{L5} at case 2 satisfied the limitation (I_{LH}(H = 5,7) < 4).

The individual voltage and current harmonics, (V_{LH}) and (I_{LH}), for configuration 2 of HAPF are shown in Figures 6 and 7, respectively. The results show that all optimization algorithms satisfied the limitation of harmonics. In addition, the results in this section showed that the increasing trend of voltage from cases 1 to 3 led to an increase in the harmonic level. In Figures 6 and 7, the WOA outperformed the other proposed optimization algorithms by reducing the current harmonics (I_{LH}). For example, the WOA in Figure 6 reduced the current harmonics (I_{L5}) at cases 1 and 2 by 75%, and 5% compared to other algorithms. Similar to configuration 1, the voltage and current harmonics (V_{LH}) and (I_{LH}) increased over the three cases with increasing voltage source harmonics. The WOA outperformed all algorithms and slightly improved performance, except for the I_{L5} in case 2, where the WOA recorded the highest value with 0.45%. However, the WOA for the I_{L5} in case 2 satisfied the limitation (I_{LH}(H = 5,7) < 4). The results of all algorithms at configuration 2 showed better results compared to configuration 1.











Figure 4. The individual voltage harmonics for configuration 1 of HAPF under the proposed three cases.



Figure 5. The individual current harmonics for configuration 1 of HAPF under the proposed three cases.



Figure 6. The individual voltage harmonics for configuration 2 of HAPF under the proposed three cases.



Figure 7. The individual current harmonics for configuration 2 of HAPF under the proposed three cases.

Overall, the HAPF optimization problem is a complex and challenging task, which requires a balance between exploration and exploitation to avoid local optimal points and to achieve a global one. The results showed that the WOA algorithm is a very competitive algorithm, and was the best algorithm in almost all the cases, achieving a good balance between the exploration and exploitation phases. The WOA's ability to derive the adaptive strategy and update the information helped in avoiding the extra number of iterations and achieved the optimal solution.

5.3. Comparative Performance and Statistical Analysis

To evaluate the convergence for the proposed optimization algorithms, convergence curves for all cases were generated over 500 iterations. The convergence curves show the relationship between the number of iterations and the HP value. The convergence curves introduce the speed of the optimization algorithm in achieving the final (optimal) solution. For example, Figure 8 shows the convergence results for all optimization algorithms for configurations 1 and 2 of the HAPF system within case 3 parameters. The results presented smooth convergence curves for all optimization algorithms. However, the WOA algorithm achieved the optimal solution with a smaller number of iterations compared to other algorithms. In addition, the GROM, AEO and EO algorithms showed similar convergence behavior to WOA. All algorithms achieved the optimal solution with less than 300 iterations for all cases, compared to the L-SHADE algorithm [8], which required more than 1500 iterations to achieve the optimal solution. The results in Figure 7 show

that the proposed optimization algorithms in this paper are more efficient and powerful compared to L-SHADE [8], in terms of computational cost and higher efficiency in CPU utilization. In addition, the results of all algorithms at configuration 2 showed better results, in terms of the fitness value, by 10%, and in computational cost by 32%, compared to configuration 1. This is mainly due to the convergence curve of the WOA leaning towards being accelerated as iteration increases. The WOA convergence curve has been accelerated regarding the WOA searching for promising regions in the initial steps and can derive an adaptive strategy and update information to help to avoid an extra number of iterations.



(**b**)

Figure 8. The Convergence comparison results for all optimization algorithms for case study 3 (a) Configuration 1 of HAPF (b) Configuration 2 of HAPF.

In Section 1, the proposed optimization algorithms results were presented for all cases. This section provides further analysis of the performance of the optimization algorithms over 20 runs of simulations. The statistical analysis for all algorithms is presented in Table 6 considering the minimum, maximum, mean and standard deviation values of the HP value as a cost function. The WOA showed the most effective performance compared to other algorithms, achieving the lower value of the minimum values for all cases.

Case Study of HAPF	Optimization Algorithm	Minimum	Maximum	Mean	Standard Deviation
	WOA	0.235766692	0.469826	0.237665	0.052876309
	AEO	0.235811789	0.235826	0.235824	3.04936×10^{-6}
	AGPSO	0.235807572	0.235916	0.235825	2.51373×10^{-5}
Configuration	GROM	0.23582184	0.492987	0.235825	0.057503316
1/Case1	MPSO	0.235778556	0.492987	0.23583	0.1055344
	IPSO	0.23578841	0.492979	0.235821	0.05750202
	EO	0.235790216	0.236637	0.235824	0.000185485
	MRFO	0.235798895	0.235867	0.235827	$1.46314 \ imes \ 10^{-5}$
	WOA	2.737615864	2.81752	2.756903	0.018962596
	AEO	2.7517811	2.952527	2.752029	0.084461027
	AGPSO	2.751378991	2.752278	2.751971	0.000253608
Configuration	GROM	2.751278888	2.952426	2.752029	0.047503307
1/Case2	MPSO	2.751177609	2.75286	2.751955	0.000359295
,	IPSO	2.751211422	2.753154	2.75205	0.000505761
	EO	2.75063412	2.753359	2.75202	0.000497049
	MRFO	2.749708921	2.952446	2.752314	0.082200423
	WOA	5.601029678	6.075889	5.668014	0.141450192
	AEO	5.661263412	5.874927	5.661263	0.087682408
	AGPSO	5.661263412	5.874927	5.661263	0.103770037
Configuration	GROM	5.661263412	5.661264	5.661263	4.46357×10^{-8}
1/Case3	MPSO	5.661263412	5.87493	5.874927	0.104558563
	IPSO	5.661263412	5.874927	5.874927	0.107392539
	EO	5.661263412	5.874927	5.661264	0.065595524
	MRFO	5.66126432	5.874928	5.661381	0.077773785
	WOA	0.227333375	0.374346	0.228852	0.032383272
	AEO	0.227313411	0.4588	0.227358	0.071226658
	AGPSO	0.227327958	0.227406	0.227359	$1.71045 imes 10^{-5}$
Configuration	GROM	0.22735514	0.4588	0.227358	0.051752048
2/Case1	MPSO	0.227334808	0.22739	0.227359	1.3785×10^{-5}
	IPSO	0.227344748	0.458807	0.227368	0.113256767
	EO	0.227335944	0.227737	0.227358	0.000113333
	MRFO	0.227320864	0.227378	0.227362	$1.38645 \ imes \ 10^{-5}$
	WOA	2.723147738	2.780197	2.7549	0.015270307
	AEO	2.751607155	2.949088	2.754218	0.04358177
	AGPSO	2.75203382	2.754539	2.75416	0.000518827
Configuration	GROM	2.753979531	2.754341	2.754198	7.40857×10^{-5}
2/Čase 2	MPSO	2.753769282	2.75494	2.754148	0.000265005
	IPSO	2.753534424	2.949048	2.754154	0.043576249
	EO	2.746840797	2.757001	2.75419	0.002199937
	MRFO	2.752518836	2.949141	2.75431	0.059895568
	WOA	5.680073815	6.081872	5.687081	0.095893203
	AEO	5.680787098	5.68209	5.680787	0.000291242
	AGPSO	5.680787098	5.906081	5.906081	0.114994201
Configuration	GROM	5.680787098	5.849521	5.680787	0.037730048
2/Čase 3	MPSO	5.680787098	5.906081	5.906081	0.092458845
	IPSO	5.680787098	5.906081	5.906081	0.110250146
	EO	5.680787098	5.691575	5.680789	0.003574488
	MRFO	5.680787674	5.68109	5.680795	8.22709×10^{-5}

 Table 6. The statistical analysis results of all optimization algorithms for the different HAPF systems.

6. Conclusions

This work presented modern metaheuristic optimization algorithms for hybrid active power filters (HAPF). The proposed algorithms were employed to achieve the minimum HP by finding the optimal parameter design of HAPF under the limitations of harmonic distortion levels, as presented in the common standard IEEE 519. In addition, the robustness of the proposed algorithms was evaluated through two configurations of HAPF and in different case studies. The proposed optimization algorithm, WOA, was employed to improve the performance of HAPF compared to modern optimization algorithms (MRFO, AEO, GROM), and the common powerful optimization methods from literature (AGPSO, MPSO, IPSO, EO, L-SHADE). The WOA outperformed the other metaheuristic optimization algorithms and L-SHADE from the literature. The WOA outperformed the other proposed optimization algorithms, by reducing the current and voltage harmonics (V_{LH}, I_{LH}). For example, the WOA reduced the voltage harmonic (V_{L5}) at case 2 by 23% and the I_{L5} by 75% at case 1 (configuration 1), compared to other algorithms. The voltage and current harmonics (V_{LH}) and (I_{LH}) increased over the three cases with increasing voltage source harmonics. The results showed that the proposed modern optimization algorithms can improve power quality by successfully minimizing the VTHD, ITHD and HP to a lower level, compared to the literature. Hence, the investigation of the performance of the proposed modern metaheuristic optimization algorithms under various ranges of constraints, by using new techniques to handle the constraints, will be part of our future work.

Author Contributions: Conceptualization, F.A. and K.N.; methodology, K.N., F.A. and H.F.; software, K.N. and F.A.; validation, K.N. and F.A.; formal analysis, A.V., A.A., W.H. and F.A.; investigation, K.N. and F.A.; resources, all authors; data curation, all authors; writing—original draft preparation, F.A. and K.N.; writing—review and editing, all authors; visualization, all authors; supervision, all authors; project administration, F.A. and K.N. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Acknowledgments: We would like to thank the Renewable Energy Center at The Hashemite University for their support.

Conflicts of Interest: The authors declare no conflict of interest.

Nomenclature

THD	Total Harmonic Distortions
HAPF	Hybrid Active Power Filters
PF	Power Factor
HP	Harmonic Pollution
WOA	Whale Optimization Algorithm
MRFO	Manta ray foraging optimization
AEO	Artificial Ecosystem-based Optimization
GROM	Golden Ratio Optimization Method
PPF	Passive Power Filter
APF	Active Power Filter
PWM	Pulse Width Modulated
PSO	Particle Swarm Optimization
DE	Differential Evolution
AGPSO	Autonomous Groups Particles Swarm Optimization
MPSO	Modified Particle Swarm Optimization
IPSO	Improved Particle Swarm Optimization
EO	Equilibrium Optimizer
PCC	Point of common coupling
ZL	inductive
Z _C	reactance
Н	At harmonic H
V _{SH}	Voltage source
I _{SH}	current source
R _{SH}	transmission line resistance
L _{SH}	transmission line reactance
I _{LH}	load current

VTHD	voltage THD
ITHD	voltage THD
VTHD _{lim}	VTHD limitation
ITHD _{lim}	ITHD limitation
PF _{target}	target power factor

References

- 1. Alasali, F.; Nusair, K.; Obeidat, A.M.; Foudeh, H.; Holderbaum, W. An analysis of optimal power flow strategies for a power network incorporating stochastic renewable energy resources. *Int. Trans. Electr. Energy Syst.* **2021**, *31*, e13060. [CrossRef]
- Alloui, N.; Fetha, C. Optimal Design for Hybrid Active Power Filter Using Particle Swarm Optimization. *Trans. Electr. Electron. Mater.* 2017, 18, 129–135.
- 3. Nusair, K.; Alasali, F.; Hayajneh, A.; Holderbaum, W. Optimal placement of FACTS devices and power-flow solutions for a power network system integrated with stochastic renewable energy resources using new metaheuristic optimization techniques. *Int. J. Energy Res.* **2021**, *45*, 18786–18809. [CrossRef]
- 4. Alasali, F.; El-Naily, N.; Zarour, E.; Saad, S.M. Highly sensitive and fast microgrid protection using optimal coordination scheme and nonstandard tripping characteristics. *Int. J. Electr. Power Energy Syst.* **2021**, *128*, 106756. [CrossRef]
- 5. Alghamdi, T.A.H.; Anayi, F.; Packianather, M. Optimal Design of Passive Power Filters Using the MRFO Algorithm and a Practical Harmonic Analysis Approach including Uncertainties in Distribution Networks. *Energies* **2022**, *15*, 2566. [CrossRef]
- 6. Pantoli, L.; Leuzzi, G.; Deborgies, F.; Jankovic, P.; Vitulli, F. A Survey of MMIC Active Filters. *Electronics* 2021, 10, 1680. [CrossRef]
- He, Q.; Liu, L.; Qiu, M.; Luo, Q. A Step-by-Step Design for Low-Pass Input Filter of the Single-Stage Converter. *Energies* 2021, 14, 7901. [CrossRef]
- 8. Biswas, P.P.; Suganthan, P.; Amaratunga, G.A. Minimizing harmonic distortion in power system with optimal design of hybrid active power filter using differential evolution. *Appl. Soft Comput.* **2017**, *61*, 486–496. [CrossRef]
- 9. Zeineldin, H.; Zobaa, F. Particle Swarm Optimization of Passive Filters for Industrial Plants in Distribution Networks. *Electr. Power Compon. Syst.* **2011**, *39*, 1795–1808. [CrossRef]
- Chang, Y.; Chinyao, L. An ant direction hybrid differential evolution heuristic for the large-scale passive harmonic filters planning problem. *Expert Syst. Appl.* 2008, 35, 894–904. [CrossRef]
- 11. Mirjalili, S.; Lewis, A. The Whale Optimization Algorithm. Adv. Eng. Softw. 2016, 95, 51–67. [CrossRef]
- 12. Zhao, W.; Zhang, Z.; Wang, L. Manta ray foraging optimization: An effective bio-inspired optimizer for engineering applications. *Eng. Appl. Artif. Intell.* **2020**, *87*, 103300. [CrossRef]
- 13. Zhao, W.; Wang, L.; Zhang, Z. Artificial ecosystem-based optimization: A novel nature-inspired meta-heuristic algorithm. *Neural Comput. Appl.* **2020**, *32*, 9383–9425. [CrossRef]
- 14. Nusair, K.; Alasali, F. Optimal Power Flow Management System for a Power Network with Stochastic Renewable Energy Resources using Golden Ratio Optimization Method. *Energies* **2020**, *13*, 3671. [CrossRef]
- 15. Nematollahi, A.F.; Rahiminejad, A.; Vahidi, B. A novel meta-heuristic optimization method based on golden ratio in nature. *Soft Comput.* **2019**, *24*, 1117–1151. [CrossRef]
- 16. Mirjalili, S.; Lewis, A.; Sadiq, A.S. Autonomous Particles Groups for Particle Swarm Optimization. *Arab. J. Sci. Eng.* **2014**, *39*, 4683–4697. [CrossRef]
- 17. Biswas, P.P.; Suganthan, P.; Mallipeddi, R.; Amaratunga, G.A. Optimal power flow solutions using differential evolution algorithm integrated with effective constraint handling techniques. *Eng. Appl. Artif. Intell.* **2018**, *68*, 81–100. [CrossRef]
- 18. Taher, M.A.; Kamel, S.; Jurado, F.; Ebeed, M. Optimal power flow solution incorporating a simplified UPFC model using lightning attachment procedure optimization. *Int. Trans. Electr. Energy Syst.* **2019**, *30*, e12170. [CrossRef]
- Ling, Y.; Zhou, Y.; Luo, Q. Lévy Flight Trajectory-Based Whale Optimization Algorithm for Global Optimization. *IEEE Access* 2017, 5, 6168–6186. [CrossRef]
- Dao, T.-K.; Pan, T.-S.; Pan, J.-S. A multi-objective optimal mobile robot path planning based on whale optimization algorithm. In Proceedings of the 2016 IEEE 13th International Conference on Signal Processing (ICSP), Chengdu, China, 6–10 November 2016; pp. 337–342.
- 21. Peng, F.; Hirofumi, A.; Akira, N. A new approach to harmonic compensation in power systems-a combined system of shunt passive and series active filters. *IEEE Trans. Ind. Appl.* **1990**, *26*, 983–990. [CrossRef]
- IEEE Std. 519-2014; IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems. IEEE Std.: Piscataway, NJ, USA, 2014.