




Article

On the Efficiency in Electrical Networks with AC and DC Operation Technologies: A Comparative Study at the Distribution Stage

Oscar Danilo Montoya ^{1,2,*} , Federico Martin Serra ³  and Cristian Hernan De Angelo ⁴ 

¹ Facultad de Ingeniería, Universidad Distrital Francisco José de Caldas, Carrera 7 No. 40B-53, Bogotá D.C. 11021, Colombia

² Laboratorio Inteligente de Energía, Universidad Tecnológica de Bolívar, km 1 vía Turbaco, Cartagena 131001, Colombia

³ Laboratorio de Control Automático (LCA), Facultad de Ingeniería y Ciencias Agropecuarias, Universidad Nacional de San Luis, Villa Mercedes, San Luis 5730, Argentina; fmserra@unsl.edu.ar

⁴ Grupo de Electrónica Aplicada (GEA), Instituto de Investigaciones en Tecnologías Energéticas y Materiales (IITEMA)—CONICET, Facultad de Ingeniería, Universidad Nacional de Río Cuarto, Río Cuarto, Córdoba 5800, Argentina; cdeangelo@ieee.org

* Correspondence: odmontoyag@udistrital.edu.co

Received: 23 July 2020; Accepted: 18 August 2020; Published: 20 August 2020



Abstract: This research deals with the efficiency comparison between AC and DC distribution networks that can provide electricity to rural and urban areas from the point of view of grid energy losses and greenhouse gas emissions impact. Configurations for medium- and low-voltage networks are analyzed via optimal power flow analysis by adding voltage regulation and devices capabilities sources in the mathematical formulation. Renewable energy resources such as wind and photovoltaic are considered using typical daily generation curves. Batteries are formulated with a linear representation taking into account operative bounds suggested by manufacturers. Numerical results in two electrical networks with 0.24 kV and 12.66 kV (with radial and meshed configurations) are performed with constant power loads at all the nodes. These simulations confirm that power distribution with DC technology is more efficient regarding energy losses, voltage profiles and greenhouse emissions than its AC counterpart. All the numerical results are tested in the General Algebraic Modeling System widely known as GAMS.

Keywords: alternating current networks; direct current networks; optimal power flow; non-linear optimization; control of power electronic converters

1. Introduction

1.1. General Context

Presently electrical distribution networks are essential systems in economic development around the world [1,2]; these grids are also responsible for distributing energy from large-scale power systems to all end users at medium and low voltage levels [3], which implies that in terms of size, the distribution networks are the lengthiest infrastructure inside of the power system [4,5]. This is important since higher losses can be presented at distribution networks in comparison to power systems (transmission and sub-transmission networks), e.g., in the Colombian context, energy losses at distribution networks can be between 6% and 18% while losses at transmission networks can be between 1% and 2% [6]. Recent advancements in power electronics, renewable energy, and energy storage technologies have made distribution networks be focused on the current modernization of power systems. In this

sense, three main tendencies can be identified as follows: (i) expanding the existing distribution networks using conventional AC technologies considering AC–DC inverters to interface the distributed energy resources [7]; (ii) Use of DC feeders to expand distribution networks taking the advantages of renewables and batteries that can work directly under the DC paradigm [8]; (iii) design hybrid distribution networks using AC and DC feeders taking the advantages of these technologies regarding reliability and security in the network operation, particularly in the new microgrids environment [3]. To analyze these possible distribution network configurations, power flow and optimal power flow models (steady-state analysis) appear to be essential tools in the literature [9]. These methods (convex and heuristics) determine the state variable (voltage magnitudes and angles) for a particular load condition being applicable to AC and DC networks with minimal changes [3].

1.2. Motivation

The analysis of electrical distribution networks from the point of view of power flow and optimal power flow is a fundamental step to validate the efficiency of these grids regarding energy losses, voltage profiles and conductor chargeability. In this sense, this research is motivated in the analysis of electrical distribution networks using AC or DC technologies in order to identify their performance regarding efficiency in terms of energy losses and greenhouse gas emissions, when it is selected one of both technologies for distributed electricity at medium-voltage level [2].

1.3. Brief Literature Survey

Electrical distribution networks had been designed under the AC paradigm for decades [10,11]; however, presently multiple reports can be found where distribution networks are analyzed under the DC paradigm, some of them are recompiled below.

The authors of [3] have presented an optimal power flow model for multi-terminal DC networks in medium-voltage levels where the energy losses in power converters have been added with quadratic constraints. These constraints allow the obtaining of an equivalent convex optimization model easily solved with semidefinite programming. In Reference [12] an optimization model for optimal phase-balancing in DC low-voltage distribution circuits with a bipolar configuration, which is represented through a Mixed-Integer Non-Linear Programming (MINLP) multi-objective model, has been presented. Numerical results demonstrated that phase-balancing reduces energy losses significantly when compared to the benchmark case. The authors of [13] have proposed the optimal location of photovoltaic sources in DC networks to minimize the total greenhouse gas emissions of CO₂ in rural networks. The proposed optimization model has an MINLP structure and it was solved through the General Algebraic Modeling System (GAMS) optimization software. In Reference [8,14] three approaches for optimal operation of battery energy storage systems in DC networks using day-ahead economic formulations, have been presented. The main idea of those works is the minimization of the daily energy purchasing costs in slack nodes by using metaheuristic and convex optimization methods with excellent results when these are compared to the benchmark cases. In Reference [15] a convex optimization model added to a branch and bound approach to solve the problem of optimal reconfiguration of DC networks, has been proposed. The main advantage of this approach is that the global optimal solution is guaranteed via second-order cone optimization, applied to a study case using real-time simulations. The authors in [16] have proposed a MINLP model for optimal location and reallocation of battery energy storage systems in DC grids to reduce the daily energy losses and the total energy purchasing costs in the conventional sources. Numerical results demonstrated that the location of the batteries is dependent on the performance index used as the objective function, i.e., energy losses or energy purchasing costs; in this sense, authors have demonstrated a multi-objective compromise between both objectives. All the simulations were carried-out in the GAMS optimization package.

Regarding AC distribution networks multiple works related with power system planning and operation have been proposed in scientific literature. Some of these works are: optimal reconfiguration of distribution networks [17–19], optimal location of shunt capacitor banks and

distributed generators [20–22], optimal selection of wire gauges in radial distribution networks [23–25], optimal location and coordination of protective devices [26–28], optimal location and operation of battery energy storage systems [7,14,29], and optimal planning of AC distribution networks including new substations [5,30].

It is important to mention that for all aforementioned approaches regardless the operation technology, i.e., AC or DC paradigms, the concepts of power flow and optimal power flow analyses are essential to determine their operative conditions [31]. This clearly implies that these concepts can be used to address both technologies and compare them regarding greenhouse gas emissions, energy purchasing costs and grid energy losses as will be addressed in this contribution.

1.4. Contribution and Scope

The main contributions of this research can be summarized as follows:

- ✓ The comparison from the point of view of power flow and optimal power flow analyses of AC and DC technologies energy distribution at medium-voltage levels, considering renewable energies and battery energy storage systems under an economic dispatch environment.
- ✓ The derivation of the multiperiod power flow model for DC distribution networks from the classical and well-known AC model by presenting the necessary simplifications, which are also presented in a tutorial style for solution purposes through the general algebraic modeling system (i.e., GAMS) optimization package.
- ✓ The use of power electronic converters to interface the DC power distribution system with AC loads to provide the reactive power demanded by the load. This is made by using control strategies that guarantees asymptotic stability during closed-loop operation taking advantage on the passivity-based control design and the Hamiltonian model often found in power converters.

Additionally, the main considerations taken into account in the development of this work are: (i) to make distribution AC and DC technologies it is supposed that all the loads in the AC grid operate with unity power factor (only applicable for AC loads), (ii) in the case of loads connected in the DC grid that require reactive power support (e.g., motors), these are interfaced via power inverters that can provide this support without affecting the operative condition of the DC grid, and (iii) a low-voltage grid operating with 240 V and 60 kW of load is considered to present the effect of the AC or DC distribution network in residential applications, while a medium-voltage grid (12.66 kV) allows to compare AC and DC technologies when considerable reactive power appear in loads.

Observe that this research is focused on the efficiency comparison between AC and DC grids from the point of view of the distribution stage, i.e., when AC or DC technologies are used to transfer power from conventional and renewable generators to loads and batteries; for this reason, we assume that power losses in all the conversion stage are similar when these devices are interfaced in AC and DC grids, which allows us to consider them as equals in both scenarios for comparison purposes in the distribution layer.

Please note that we include ahead in this paper a section dedicated to the analysis of voltage source converters since these devices are essential in the DC distribution paradigm [3]. We introduced these devices with a classical passivity-based controller that operates these devices in the inversion mode, i.e., these are used to provide AC power to three-phase loads assuming a constant voltage source in the DC side [32]. However, these devices can also be used as the main sources when AC conventional networks interface with DC distribution feeders [33].

1.5. Organization of the Document

The remainder of this document is rearranged as follows: Section 2 presents the complete mathematical formulation of the multiperiod optimal power flow problem for AC grids as well as the necessary simplifications to derive the equivalent DC model. Section 3 presents the main characteristics of the GAMS software to solve non-linear non-convex optimization problems with a

small test feeder composed by six nodes and five lines that operates with 240 V to meet a total load about 60 kW. Section 4 presents the integration of three-phase loads in DC networks using voltage source converter interface. In addition, a general control design to guarantee sinusoidal voltage profile in the AC load regardless the active and reactive power consumption via passivity-based control methods is presented. Section 5 presents all the numerical information regarding the medium-voltage distribution network analyzed, which is composed by 33 nodes, 32 lines and operates with a nominal voltage of 12.66 kV. This system has four renewable generators (two photovoltaic-based generators and two wind turbines), and three battery energy storage systems (note that these renewable sources and battery energy storage systems are indeed composed by DC sub-networks interfaced with power electronic converters to manage the power transferred (absorbed) to (from) the DC or AC distribution networks). Section 6 presents all the numerical simulations on the 33-nodes test feeder considering multiple simulation cases. Section 7 shows the main conclusions derived from this work as well as some possible future works.

2. Mathematical Formulation

To compare electrical AC and DC distribution to provide electrical service in rural areas we assume that all the power consumptions have unity power factor and the voltage profile for both technologies is the same. The main characteristic of the proposed formulation is that the distribution network lacks of a voltage controlled node, since the operation is governed by the best coordination between renewable, batteries, and fossil fuels that guarantees the power supply to all the loads during a daily operative scenario. Regarding possible objective function in rural isolated areas two operative scenarios are considered: (i) minimization of the total grid energy losses, and (ii) minimization of the greenhouse emissions by diesel generators. Both objective functions are formulated under an optimal power flow environment.

In the case of the mathematical model of the battery energy storage systems we assume a linear representation to facilitate the implementation in GAMS environment based on the simplified model proposed in [34] which considers that in the conversion stage all the energy losses are neglected, i.e., 100% of efficiency in all the power electronic interface [7,14]; nevertheless, if more accurate battery models are required, then, references [35,36] can be consulted.

2.1. Optimal Power Flow Model in AC Grids

The Optimal power flow (OPF) problem in AC networks is a classical non-linear non-convex optimization problem due to the presence of the active and reactive power balance equations. Here, we consider OPF formulation presented in [7] to analyze distribution networks without constant voltage suppliers. The complete formulation of the OPF problem for AC grids is presented below:

Objective Functions

$$\min z_{ge}^{ac} = \sum_{t \in \mathcal{T}} \sum_{i \in \mathcal{N}} T_i^{ge} p_{i,t}^{dg} \Delta t, \quad (1a)$$

$$\min z_{loss}^{ac} = \sum_{t \in \mathcal{T}} \sum_{i \in \mathcal{N}} \sum_{ij \in \mathcal{N}} Y_{ij} v_{i,t} v_{j,t} \cos(\delta_{j,t} - \delta_{i,t} + \theta_{ij}) \Delta t, \quad (1b)$$

where z_{ge}^{ac} and z_{loss}^{ac} are the objective function values related to the amount of greenhouse emissions and energy losses per day, respectively. T_i^{ge} represents the quantity of CO₂ emitted to the atmosphere in $\frac{kg}{kWh}$ by a diesel generator connected at node i , $p_{i,t}^{dg}$ is the active power delivered by the diesel generator connected at node i in the period of time t ; Δt is the length of the period of time considered (typically 1 h). Y_{ij} is the value of the admittance that relates nodes i and j , which have voltages $v_{i,t}$ and $v_{j,t}$ at each period of time t . $\delta_{i,t}$ ($\delta_{j,t}$) is the angle of the voltage at node i (j) in the interval of time t ,

and θ_{ij} is the angle of the admittance between nodes i and j . Please note that \mathcal{N} and \mathcal{T} are the sets that contains all the nodes in the grid and the total of periods of time of the operation horizon.

Set of Constraints

The power balance equations in the AC power flow are related to the amount of active and reactive power injected at each node i in each period of time t . These take the following form:

$$p_{i,t}^{dg} + p_{i,t}^{rs} + p_{i,t}^b - p_{i,t}^d = v_{i,t} \sum_{j \in \mathcal{N}} Y_{ij} v_{j,t} \cos(\delta_{i,t} - \delta_{j,t} - \theta_{ij}), \quad (2a)$$

$$q_{i,t}^{dg} + q_{i,t}^{rs} + q_{i,t}^b - q_{i,t}^d = v_{i,t} \sum_{j \in \mathcal{N}} Y_{ij} v_{j,t} \sin(\delta_{i,t} - \delta_{j,t} - \theta_{ij}), \quad (2b)$$

where $p_{i,t}^{rs}$ and $q_{i,t}^{rs}$ are the active and reactive power generation by renewable sources connected at node i in the period of time t ; $p_{i,t}^b$ and $q_{i,t}^b$ are the active and reactive power capabilities in batteries and $p_{i,t}^d$ and $q_{i,t}^d$ represent the active and reactive power demands, respectively. Please note that in the literature it is recommended that batteries can operate with unity power factor which implies that $q_{i,t}^b = 0$ [14,37].

Constraints related with batteries are listed below:

$$SoC_{i,t+1}^b = SoC_{i,t}^b - \varphi_i^b p_{i,t}^b \Delta t, \quad (3a)$$

$$SoC_i^{b,\min} \leq SoC_{i,t}^b \leq SoC_i^{b,\max}, \quad (3b)$$

$$p_i^{b,\min} \leq p_{i,t}^b \leq p_i^{b,\max}, \quad (3c)$$

$$SoC_{i,t_0}^b = SoC_i^{b,\text{initial}}, \quad (3d)$$

$$SoC_{i,t_f}^b = SoC_i^{b,\text{final}}, \quad (3e)$$

where $SoC_{i,t}^b$ is the state-of-charge of the battery b connected at node i in the period of time t , which is bounded by $SoC_i^{b,\min}$ and $SoC_i^{b,\max}$; note that the state-of-charge can be interpreted as the quantity of energy stored in the battery in percentage. φ_i^b is the charging/discharging coefficient of the battery b . $p_i^{b,\min}$ and $p_i^{b,\max}$ represent the minimum and maximum power allowable draws/injections at node i for secure operation of the battery at each period of time. $SoC_i^{b,\text{initial}}$ and $SoC_i^{b,\text{final}}$ represent the initial and final state-of-charges defined by the utility to operate the battery, i.e., the initial condition of the economic dispatch problem at t_0 and the final operative consign at the end of the operation period t_f .

The complete interpretation of the mathematical models (1)–(3) is as follows: Expression (1a) determines the value of the objective function regarding greenhouse gas emissions to the atmosphere by diesel generation. Equation (1b) defines the total energy losses in all the conductors of the network during the operation horizon (i.e., typically 24 h). Expressions (2a) and (2b) define the power balance constraints regarding active and reactive components of the power at each node. Equation (3a) calculates future the state-of-charge in the battery for each period of time as function of the current charge and the power injection/absorption to/from the grid. Expressions (3b) and (3c) determine the maximum and minimum values allowed to the state-of-charge (energy stored) in the battery as well as its maximum power injection (discharging state) or absorption (charging state), respectively. Finally, Equations (3d) and (3e) determine the initial state-of-charge of the battery and the final operative consign defined by the utility. These are defined as function of the operational requirements of the network. Nevertheless, in specialized literature it is recommended for Ion-Lithium batteries to start and end the day with 50% of state of charge. [14].

Remark 1. The mathematical model for the optimal operation of AC networks with renewables and batteries defined from (1) to (3) is non-linear and non-convex due to the power balance constraints which makes difficult to reach the global optimum [8]. For this reason, here we recurred to the GAMS optimization software to solve this problem to make our results comparable to those obtained from the mathematical model regarding DC grids reported in next subsection.

Remark 2. The studied optimization model (1)–(3) corresponds to a single-phase representation of AC distribution network that can be used if: (i) the AC network is indeed a single-phase network which is the most typical scenario in low-voltage distribution environments, or (ii) it is a three-phase balanced distribution network that can be represented through a single-phase equivalent model [7].

2.2. Optimal Power Flow Model in DC Grids

The mathematical formulation of the optimal power flow problem for DC networks can be obtained directly from the AC formulation by simplifying the objective function regarding energy losses minimization. Also, power balance constraints can be simplified as follows:

- ✓ The angle of the voltage do not exist ($\delta_{i,t} = \delta_{j,t} = 0$) in DC networks since no frequency concept is present in these networks.
- ✓ The reactive power constraint disappears in the DC paradigm, since it is a concept regarding inductors and capacitors in AC grids, and in DC grids they behave as short- and open-circuits, respectively.
- ✓ The admittance matrix in DC grids is only defined by real numbers ($\theta_{ij} = 0$) regarding only with resistive effects in branches and loads, i.e., $Y_{ij} = G_{ij}$.

With these assumptions, the objective function of the DC optimal power flow and the power balance constraint takes the following forms:

Objective function regarding energy losses

$$\min z_{\text{loss}}^{\text{dc}} = \sum_{t \in \mathcal{T}} \sum_{i \in \mathcal{N}} \sum_{j \in \mathcal{N}} G_{ij} v_{i,t} v_{j,t} \Delta t, \quad (4)$$

where $z_{\text{loss}}^{\text{dc}}$ is the amount of energy losses in all the branches of the DC network.

Power balance constraint

$$p_{i,t}^{\text{dg}} + p_{i,t}^{\text{rs}} + p_{i,t}^{\text{b}} - p_{i,t}^{\text{d}} = v_{i,t} \sum_{j \in \mathcal{N}} G_{ij} v_{j,t}, \quad (5)$$

Remark 3. The complete mathematical model of the optimal power flow problem in DC grids is composed by the greenhouse gas emission objective function (1a), the objective function regarding energy losses minimization defined by (4), the power balance constraint (5) and the remainder of constraints defined in (3).

It is worthy to mention that the model of the optimal power flow in DC grids is also non-linear and non-convex due to the product between voltage variables in the power balance constraint, which makes necessary to use specialized software (i.e., GAMS) to solve it efficiently [16].

3. Solution Methodology

To solve the optimal power flow problems in AC and DC grids in this paper it is selected the GAMS software to implement their mathematical structures with a non-linear programming (NLP) solver that typically works with interior point methods to reach the optimal solution [36,38].

GAMS software has been largely used in specialized literature to address non-linear non-convex optimization problems in many areas of engineering, some of these works are: optimal planning and

operation of power systems with batteries in AC and DC networks [36,37,39,40]; optimal location of distributed generators [13,22,41,42]; optimal design of osmotic power plants [43]; optimal design of water distribution networks [44]; stability analysis in DC networks [45]; optimal design of thermoacoustic engines [46]; optimal location of protective devices [47], and optimal planning of distribution networks [30], among others.

In general terms, GAMS software is a powerful optimization package that solves complex optimization problems focused on the mathematical formulation of the problem rather than the solution methodology [38]. This represents an ideal situation to introduce students and researchers with mathematical optimization [36]. The main characteristics of the GAMS software can be summarized as follows:

- ✓ It works with a compact model, i.e., by using the symbolic representation of the problem such as reported in model (1)–(3).
- ✓ The parametric information of the mathematical model is introduced via constants, vectors and matrices, which are named in GAMS as scalars, parameters and tables.
- ✓ Multiple optimization models can be selected depending on the nature of the problem under study. These models can be linear programming, non-linear programming, or mixed-integer combinations.

A numerical example is presented to understand the use of GAMS software to solve optimization problems with non-linear and non-convex structure. To do so, below it is presented the solution of the power flow problem for a small test feeder that can be operated with AC or DC technology. In the case of the AC technology, it is important to mention that this grid corresponds to a low-voltage distribution network with a single-phase structure, which is the most typical operation case in low-voltage applications [48]. The configuration of this test feeder is presented in Figure 1. This test feeder is composed by six nodes and five distribution lines (radial topology). The information of the branches and loads is reported in Table 1. Please note that to make both configurations comparable, we assume unity power factor in all the loads. In addition, this system operates with 240 V typically found in Colombian AC grids.




Figure 1. Electrical configuration for the 6-nodes test system used in the GAMS example.

Table 1. Branches and load information.

Node i	Node j	R_{ij} (Ω)	X_{ij} (Ω)	P_j (kW)
1	2	0.01233	0.01827	16
2	3	0.02467	0.03051	11
3	4	0.01469	0.02545	15
3	5	0.02984	0.03084	10
5	6	0.01325	0.01922	8

Please note that this example is a typical low-voltage distribution network where distribution transformers have nominal power of 75 kVA. The implementation of the optimal power flow problem for this test system considers:

- ✓ A unique hour of analysis.
- ✓ Operation with unity power factor in all the loads.
- ✓ No presence of distributed generators or batteries.

The simplified mathematical model for the optimal power flow in AC grids is presented below:

$$\min p_{\text{loss}} = \sum_{i \in \mathcal{N}} v_i \sum_{j \in \mathcal{N}} Y_{ij} v_j \cos(\delta_i - \delta_j - \theta_{ij}), \quad (6a)$$

$$p_i^{dg} - p_i^d = v_i \sum_{j \in \mathcal{N}} Y_{ij} v_j \cos(\delta_i - \delta_j - \theta_{ij}), \quad (6b)$$

$$q_i^{dg} - q_i^d = v_i \sum_{j \in \mathcal{N}} Y_{ij} v_j \sin(\delta_i - \delta_j - \theta_{ij}). \quad (6c)$$

The implementation of the simplified mathematical model (6) for the optimal power flow analysis in AC grids is presented in Listing 1.

In the case of the DC model the set of equations reported in (6) can be simplified as presented in Equation (7)

$$\min p_{\text{loss}} = \sum_{i \in \mathcal{N}} v_i \sum_{j \in \mathcal{N}} G_{ij} v_j, \quad (7a)$$

$$p_i^{dg} - p_i^d = v_i \sum_{j \in \mathcal{N}} G_{ij} v_j, \quad (7b)$$

The implementation of this simplified mathematical model (6) for the optimal power flow analysis in DC grids is presented in Listing 2.

Once both models (i.e., Equations (6) and (7)) are solved using the CONOPT solver in GAMS by using algorithms presented in Listings 1 and 2, we reach the solution of the voltage profiles reported in Table 2. Please note that for both cases the lowest voltage occurs at node 6 being 207.86 V for the AC grid and 208.24 V for the DC network. These results imply a difference of about 0.38 V between both networks.

Table 2. Voltage profile for the AC and DC grids.

Node i	AC Voltage (pu)	DC Voltage (pu)
1	1	1
2	0.983164996232027	0.984105190366298
3	0.958943129797591	0.960589773608504
4	0.954139851448628	0.955826686308744
5	0.947125787365783	0.948881700223591
6	0.944803809697248	0.946567991473344

Additionally, power losses in the AC grid are 2.40 kW, and 2.39 kW in the DC case (i.e., a difference about 10 W). These results demonstrate that even considering unity power factor at all the loads, the distribution using DC technology is more efficient than the AC counterpart. The voltage drop in lines is lower due to the irrelevance of inductive reactance of the lines.

An important fact when comparing AC and DC configurations is the amount of reactive power required by the AC grid to operate adequately. In this sense, in this small example the grid needs to generate about 3.21 kVAr, which corresponds to reactive power losses through all the lines. This obviously does not occur in the DC paradigm since reactive effect is not presented as previously mentioned. An additional simulation case in this small test feeder is made in the case of the AC distribution network by considering that all the loads are operated with a lagging power factor of 0.95. In these conditions, the total grid losses exhibit by this network are about 2.77 kW and the minimum voltage profile is about 221.04 V at node 6. These results imply that in comparison to the unity power factor operation case, the reactive power consumption at all the loads makes that the power losses to

be increased about 0.37 kW, requiring at the substation node 23.40 kVAr to supply the reactive power requirements at all the loads; and that the voltage at the node has worsened about 5.76 V. Please note that when reactive power is considered for loads in the AC grid, its behavior affects and worsens the results of the comparison with respect to the unity Please note that these results are particularly important when voltage increase to medium level, since these differences become in tens of volts and hundreds of watts. In Section 6 these impacts will be widely discussed under an economic dispatch environment in the 33-node test feeder taking into account higher penetration of renewables and battery energy storage systems.

Listing 1. Algorithm implemented in GAMS for OPF model (6).

```

1 SETS
2 i set of nodes /N1*N6/
3 g set of generators /G1/
4 map(g,i) Associates node with gen /G1.N1/;
5 alias(i,j);
6 SCALARS
7 vmax Maximum voltage bound /1.10/
8 vmin Minimum voltage bound /0.90/
9 v0 Slack voltage /1.00/
10 d0 Slack angle /0.00/;
11 PARAMETER Pd(i)
12 /N1 0,N2 0.16,N3 0.11,N4 0.15,N5 0.10,N6 0.08/;
13 TABLE Ybus(i,j,*)
14      Yij      Thij
15 N1.N1 21.9587119756815 -0.977131269610956
16 N2.N1 21.9587119756815 2.164461383978837
17 N1.N2 21.9587119756815 2.164461383978837
18 N2.N2 34.2649004085076 -0.946099794913962
19 N3.N2 12.3355889037129 2.250751567181446
20 N2.N3 12.3355889037129 2.250751567181446
21 N3.N3 39.8699085005043 -0.930090535155209
22 N4.N3 16.4707942748332 2.094290056213377
23 N5.N3 11.2786162705081 2.339716087328560
24 N3.N4 16.4707942748332 2.094290056213377
25 N4.N4 16.4707942748332 -1.047302597376417
26 N3.N5 11.2786162705081 2.339716087328560
27 N5.N5 31.9116612264763 -0.909021422256346
28 N6.N5 20.7328356619391 2.174363262762511
29 N5.N6 20.7328356619391 2.174363262762511
30 N6.N6 20.7328356619391 -0.967229390827282;
31 VARIABLES
32 ploss Power losses variable
33 v(i) Magnitude of the voltage at node i.
34 d(i) Angle of the voltage at node i.
35 p(g) Active power generation at node i.
36 q(g) Reactive power generation at node i.;
37 v.lo(i) = vmin; v.up(i) = vmax;
38 d.fx('N1') = d0;
39 v.fx('N1') = v0;
40 EQUATIONS
41 ObjFun Objective function
42 PowerA(i) Active power balance per node.
43 PowerR(i) Reactive power balance per node.;
44 * Mathematical structure
45 ObjFun.. ploss =E= SUM(i,v(i)*SUM(j,v(j)*Ybus(i,j,'Yij')*
46      cos(d(i)-d(j)-Ybus(i,j,'Thij'))));
47 PowerA(i).. sum(g$map(g,i),p(g)) - Pd(i)=E= v(i)*SUM(j,v(j)*
48      Ybus(i,j,'Yij')*cos(d(i)-d(j)-Ybus(i,j,'Thij')));
49 PowerR(i).. sum(g$map(g,i),q(g)) =E= v(i)*SUM(j,v(j)*
50      Ybus(i,j,'Yij')*sin(d(i)-d(j)-Ybus(i,j,'Thij')));
51 MODEL OPF /ALL/;
52 OPTIONS decimals = 4;
53 SOLVE OPF us NLP min ploss;
54 DISPLAY ploss.l, v.l, p.l;

```

Listing 2. Algorithm implemented in GAMS for the OPF model (7).

```

1  SETS
2  i set of nodes /N1*N6/
3  g set of generators /G1/
4  map(g,i) Associates node with gen /G1.N1/;
5  alias(i,j);
6  SCALARS
7  vmax Maximum voltage bound /1.10/
8  vmin Minimum voltage bound /0.90/
9  v0 Slack voltage /1.00/;
10 PARAMETER Pd(i)
11 /N1 0, N2 0.16, N3 0.11, N4 0.15, N5 0.10, N6 0.08/;
12 TABLE Ybus(i,j,*)
13      Gij
14 N1.N1 39.2538523925385
15 N2.N1 -39.2538523925385
16 N1.N2 -39.2538523925385
17 N2.N2 58.8728228019427
18 N3.N2 -19.6189704094041
19 N2.N3 -19.6189704094041
20 N3.N3 68.7863929415566
21 N4.N3 -32.9475833900613
22 N5.N3 -16.2198391420912
23 N3.N4 -32.9475833900613
24 N4.N4 32.9475833900613
25 N3.N5 -16.2198391420912
26 N5.N5 52.7481410288836
27 N6.N5 -36.5283018867925
28 N5.N6 -36.5283018867925
29 N6.N6 36.5283018867925
30 VARIABLES
31 ploss Power losses variable
32 v(i) Magnitude of the voltage at node i.
33 p(g) Active power generation at node i.;
34 v.lo(i) = vmin; v.up(i) = vmax;
35 v.fx('N1') = v0;
36 EQUATIONS
37 ObjFun Objective function
38 PowerA(i) Active power balance per node.;
39 * Mathematical structure
40 ObjFun.. ploss =E= SUM(i,v(i)*SUM(j,v(j)*Ybus(i,j,'Gij')));
41 PowerA(i).. sum(g$map(g,i),p(g)) - Pd(i) =E= v(i)*SUM(j,v(j)*Ybus(i,j,'Gij'));
42 MODEL OPF /ALL/;
43 OPTIONS decimals = 4;
44 SOLVE OPF us NLP min ploss;
45 DISPLAY ploss.l, v.l, p.l;

```

It is worth mentioning that as described in Section 5, the comparisons made in this research regarding the efficiency comparison between AC and DC paradigms are focused on the distribution stage, which implies that we will not consider power losses in the power electronic interfaces used for interfacing renewable sources and battery energy storage systems. Nevertheless, these will be able to be explored in future research regarding energy distribution technologies and power electronic interfaces for batteries and renewables.

Remark 4. Regarding optimal implementation in GAMS environment of the OPF problem for AC and DC grids depicted in Listings 1 and 2, we can observe that the DC model is pretty simple with less variables (no angles), which makes this easiest to be solved since its nonlinearities are soft when compared to the AC model that contains trigonometric functions.

4. Generation Reactive Power in DC Grids with Voltage Source Converter Interfaces

To provide apparent power to three-phase loads in medium- and low-voltage levels using DC distribution feeders, it is required a power electronic interface, i.e., voltage source converter (VSC) (A voltage source converter interface corresponds to a power electronic converter that is fed by a DC source that provides the required active power in the AC side, which is managed by controlling the switches (on or off) states via pulse-width modulation techniques to provide a sinusoidal voltage signal to AC loads [3,32]) that manages the active power interchange between the DC grid and the load at the same time that the reactive power is correctly provided to this load by the converter. In Figure 2 it is depicted the interconnection of a three-phase load to a DC distribution network with a voltage source converter and RLC filter.




Figure 2. Interconnection of three-phase loads to DC distribution networks via VSCs.

Remark 5. The VSC interface is a power electronic device that can provide active and reactive power to AC loads when at the DC side it is interconnected a constant voltage source (inversion mode of operation), as the case of the DC distribution paradigm [32]; however, the same device can also be employed to transform AC energy into DC energy when is operated in the conversion mode, as the case of high-voltage direct power transmission systems [33], i.e., the case of DC distribution is used to interface the conventional AC grid to the DC working as the main transformer [49,50].

To demonstrate that it is possible to manage the active and reactive power consumption in the three-phase load we consider the following facts:

- ✓ The voltage provided by the DC distribution networks is constant, i.e., the dynamics of the capacitor in the DC side can be neglected, which implies that the dynamical model of the interface presented in Figure 2 can be considered linear.
- ✓ The current absorbed by the three-phase load (i.e., j_{abc}) is measurable and controllable to guaranteeing constant power absorption.
- ✓ All the state variables (i.e., i_{abc} and v_{abc}) in Figure 2 are measurable and all the parameters of the RLC filter are perfectly known.

Please note that the control objective in the power electronic interface presented in Figure 2 is to maintain the voltage across the capacitor C_f with purely sinusoidal form as presented below:

$$\begin{aligned} v_a^* &= \sqrt{2}V_{\text{rms}} \sin(\omega t), \\ v_b^* &= \sqrt{2}V_{\text{rms}} \sin\left(\omega t - 2\frac{\pi}{3}\right), \\ v_c^* &= \sqrt{2}V_{\text{rms}} \sin\left(\omega t + 2\frac{\pi}{3}\right). \end{aligned} \quad (8)$$

where V_{rms} is the root-mean-square value of the voltage in the point of load connection, ω is the angular frequency of the three-phase voltage which is defined as $2\pi f$, being f the electrical frequency in hertz.

Since the desired voltages are three sinusoidal signals defined with positive sequence, then, the control design for the VSC presented in Figure 2 can be designed using the Park's reference frame

as demonstrated in [32]. The complete dynamical model of the three-phase VSC to support active and reactive power to a three-phase load as presented in Figure 2 takes the following form in the dq -reference frame:

$$L_f \frac{d}{dt} i_d = m_d v_{dc} - R_f i_d + \omega L_f i_q - v_d, \quad (9a)$$

$$L_f \frac{d}{dt} i_q = m_q v_{dc} - R_f i_q - \omega L_f i_d - v_q, \quad (9b)$$

$$C_f \frac{d}{dt} v_d = i_d - \omega C_f v_q - j_d, \quad (9c)$$

$$C_f \frac{d}{dt} v_q = i_q + \omega C_f v_d - j_q, \quad (9d)$$

where m_d and m_q are the modulation indexes in the dq -reference frame; i_{dq} and j_{dq} are the current that flow in the inductor of the filter and the current absorbed by the three-phase load, v_{dq} are the dq components of the voltage across the capacitor C_f .

The main characteristic of the dynamical model (9) is that it corresponds to a Hamiltonian system which can be easily controllable via passivity-based control theory as presented in [32]. The Hamiltonian model of (9) takes the following form:

$$\mathcal{D}\dot{x} = [\mathcal{J} - \mathcal{R}]x + gu + \zeta, \quad (10)$$

where \mathcal{D} is known as the inertia matrix based on its similarities with mechanical systems, \mathcal{J} corresponds to the interconnection matrix which is skew-symmetric, \mathcal{R} is the damping matrix which is positive semidefinite, g is the control input matrix, and z is a vector that contains external inputs. Please note that x is the vector of state variables and u is a vector with control inputs, respectively. Each of the aforementioned parameters and variables can be easily defined by comparing (9) and (10).

Remark 6. The dynamical system (10) can be asymptotically stabilized by using an incremental representation as presented in [32] with a proportional-integral strategy over the passive output \tilde{y} as follows:

$$\tilde{u} = -K_p \tilde{y} - K_i \int_0^{t_f} \tilde{y} dt, \quad (11)$$

where K_p and K_i are defined as diagonal positive definite matrices and \tilde{y} is $g^T \tilde{x}$. In addition, the complete control is defined from the incremental model as $u = \tilde{u} + u^*$, where u^* is obtained by evaluating the equilibrium point x^* in (10).

To show that the power electronic interface presented in Figure 2 is able to control active and reactive power in a three-phase load, let us consider the following parameters: $f = 50$ Hz, $L_f = 1.25$ mH, $R_f = 0.20$ Ω , $C_f = 45$ μ F, $V_{rms} = 100$ V and $v_{dc} = 311$ V. The three-phase load is modeled as a combination between a resistance of 2 Ω and an inductance of 7.958 mH connected in parallel. During the period of time between 0 s and 150 ms only the resistive load is connected, then, when time simulation is greater than 150 ms, the inductive load is also connected. It is important to mention that these parameters imply an equivalent active power consumption of about 5 kW added with 4 kVar at each phase.

In Figure 3 the voltage and current profile provided to the a -phase by the VSC interface to the three-phase load are presented.

Please note that the behavior of the a -phase current depicted in Figure 3 demonstrates that if the voltage profile is supported at the load terminals via passivity-based control as defined in (11), then, the active and reactive power required by the load is guaranteed. This implies that the power electronic interface presented in Figure 2 can be used to interface three-phase loads to DC distribution networks with local reactive power support (i.e., unity power factor operation). The main advantage

of this interface is that the reactive power is provided locally to the load and no power losses are observed by the DC grid caused by reactive currents, which clearly shows that DC grids are more efficient than AC grids when loads have power factors lower than unity, as it will be presented in section of Results.




Figure 3. Behavior of the voltage and current in the a -phase of the three-phase load.

5. Test System

The comparison of the AC and DC technologies for energy distribution in medium-voltage levels is made by using the 33-nodes test feeder reported in [7]. This test feeder is designed to be operated at 12.66 kV with the connections depicted in Figure 4. The information regarding branches and loads for this test feeder are reported in Table 3. Please note that this test feeder corresponds to a three-phase distribution network typically used to study the problem of the optimal location of distributed generators in power distribution networks as reported in [51].

To evaluate the effect of the renewable generation in the daily operation of this test feeder, we consider four renewable generators previously located in this test system with the information reported in Table 4.

The connection of the generators for each test system is described as follows: at the node 13 it is connected the photovoltaic generator PV_1 and the wind turbine WT_1 with nominal rates of 450 kW and 825 kW, respectively. At the node 25, it is connected a second PV_2 with a nominal power rate of 1500 kW while at the node 30 it is connected the second wind generator WT_2 with the nominal capability of 1200 kW. The information regarding battery energy storage systems considered in this test feeder is reported in Table 5. We assume that the utility has located three batteries, which are distributed as follows: at node 6, a C-type battery is located; at node 14 an A-type battery is used, and at the node 31, a B-type battery is considered.




Figure 4. Electrical configuration for the 33-nodes test system.

Table 3. Parameters of the 33-nodes test feeder.

Node <i>i</i>	Node <i>j</i>	R_{ij} (Ω)	X_{ij} (Ω)	P_j (kW)	Q_j (kW)	Node <i>i</i>	Node <i>j</i>	R_{ij} (Ω)	X_{ij} (Ω)	P_j (kW)	Q_j (kW)
1	2	0.0922	0.0477	100	60	17	18	0.7320	0.5740	90	40
2	3	0.4930	0.2511	90	40	2	19	0.1640	0.1565	90	40
3	4	0.3660	0.1864	120	80	19	20	1.5042	1.3554	90	40
4	5	0.3811	0.1941	60	30	20	21	0.4095	0.4784	90	40
5	6	0.8190	0.7070	60	20	21	22	0.7089	0.9373	90	40
6	7	0.1872	0.6188	200	100	3	23	0.4512	0.3083	90	50
7	8	1.7114	1.2351	200	100	23	24	0.8980	0.7091	420	200
8	9	1.0300	0.7400	60	20	24	25	0.8960	0.7011	420	200
9	10	1.0400	0.7400	60	20	6	26	0.2030	0.1034	60	25
10	11	0.1966	0.0650	45	30	26	27	0.2842	0.1447	60	25
11	12	0.3744	0.1238	60	35	27	28	1.0590	0.9337	60	20
12	13	1.4680	1.1550	60	35	28	29	0.8042	0.7006	120	70
13	14	0.5416	0.7129	120	80	29	30	0.5075	0.2585	200	600
14	15	0.5910	0.5260	60	10	30	31	0.9744	0.9630	150	70
15	16	0.7463	0.5450	60	20	31	32	0.3105	0.3619	210	100
16	17	1.2890	1.7210	60	20	32	33	0.3410	0.5302	60	40

Table 4. Renewable energy behavior during a typical sunny day.

Time (s)	PV ₁ (p.u)	PV ₂ (p.u)	WT ₁ (p.u)	WT ₂ (p.u)	Time (s)	PV ₁ (p.u)	PV ₂ (p.u)	WT ₁ (p.u)	WT ₂ (p.u)
0.0	0	0	0.633118295	0.489955551	12.0	0.924486326	0.975683083	0.972218577	0.942224932
0.5	0	0	0.629764678	0.467954207	12.5	1	1	0.980049847	0.949956724
1.0	0	0	0.607259323	0.449443905	13.0	0.982041153	0.978264398	0.981135531	0.963773634
1.5	0	0	0.609254545	0.435019277	13.5	0.913674689	0.790055240	0.988644844	0.974977461
2.0	0	0	0.605557422	0.437220792	14.0	0.829407079	0.882557147	0.991393173	0.986750539
2.5	0	0	0.630055346	0.437621534	14.5	0.691912077	0.603658738	0.998815517	0.995058133
3.0	0	0	0.684246423	0.450949300	15.0	0.733063295	0.606324907	1	1
3.5	0	0	0.758357805	0.453259348	15.5	0.598435064	0.357393267	0.996070963	0.998107341
4.0	0	0	0.783719339	0.469610539	16.0	0.501133849	0.328035635	0.987258076	0.997690423
4.5	0	0	0.815243582	0.480546213	16.5	0.299821403	0.142423488	0.976519817	0.993076899
5.0	0	0	0.790557706	0.501783479	17.0	0.177117518	0.142023463	0.929542167	0.982629597
5.5	0	0	0.738679217	0.527600299	17.5	0.062736095	0.072956701	0.876413965	0.972084487
6.0	0	0	0.744958950	0.586555316	18.0	0	0.019081590	0.791155379	0.930225756
6.5	0	0	0.718989730	0.652552760	18.5	0	0.008339287	0.691292162	0.891253999
7.0	0.039123365	0.026135642	0.769603567	0.697699990	19.0	0.000333920	0	0.708839248	0.781950905
7.5	0.045414292	0.051715061	0.822376817	0.774442755	19.5	0	0	0.724074349	0.660094138
8.0	0.065587179	0.110148398	0.826492212	0.820205405	20.0	0	0	0.712881960	0.682715246
8.5	0.132615282	0.263094042	0.848620129	0.871057775	20.5	0	0	0.733954043	0.686617947
9.0	0.236870796	0.431175761	0.876523598	0.876973635	21.0	0	0	0.719897641	0.681865563
9.5	0.410356256	0.594273035	0.904128455	0.877065236	21.5	0	0	0.705502389	0.717315757
10.0	0.455017818	0.730402039	0.931213527	0.897955131	22.0	0	0	0.703007456	0.718080346
10.5	0.542364455	0.830347309	0.955557477	0.903245007	22.5	0	0	0.686551618	0.726890145
11.0	0.726440265	0.875407050	0.965504834	0.916903429	23.0	0	0	0.687238555	0.734452193
11.5	0.885104984	0.898815348	0.971037333	0.924757605	23.5	0	0	0.682569771	0.739699146

It is worth mentioning that each one of the renewable source or battery energy storage system corresponds to a DC sub-network interfaced with a power electronic converter that manages the power transferred(absorbed)/to(from) the distribution network regardless whether this is operated under AC or DC paradigm [3].

Table 5. Battery types.

Type	Nominal Energy (kWh)	Charge/Dis. Time (h)	Nominal Power (kW)
A	1000	4	250
B	1500	4	375
C	2000	5	400

To evaluate the daily variation of the active and reactive power consumption and emulating the hourly price behavior, we consider the load and cost curves reported in Figure 5. Furthermore, as the peak of the electricity, we assume the information reported by CODENSA utility from Colombia in May 2019, which is COP\$/kWh 479.3389.




Figure 5. Typical behavior of load consumption and electricity spot market cost.

The numerical information about the demand and cost curves presented in Figure 5 can be consulted in [7].

6. Numerical Results and Discussion

In this section, all the numerical results reached by GAMS after implementing the OPF models for AC and DC networks are described. To make a fair comparison between both distribution technologies the following simulation scenarios are proposed:

- ✓ S1: It is considered that the 33-nodes test feeder operates with unity power factor, i.e., all the reactive power consumptions reported in Table 3 are considered zero in this scenario.
- ✓ S2: The complete information of the 33-nodes test feeder is considered to evaluate the effect of the reactive power demand in the operation of classical AC networks.

It is important to mention that as recommended in [14] all the batteries start and end the day with 50% of state-of-charge and during the day (for Ion-Lithium batteries) this variable can be moved from 10% to 90%.

6.1. Operation of the AC Network

In the operation of this grid, we consider three objective functions as follows: Case 1: minimization of the energy losses during the operation horizon, Case 2: the minimization of the energy purchase costs in the conventional generator (node 1) considering the cost curve reported in Figure 5, and Case 3: the minimization of the total CO₂ gas emissions in the slack source considering that the 33-nodes test feeder is a rural grid fed by a diesel generator. Here, we consider as reported in [13] that CO₂ emission coefficient is 1300 lb/MWh.

Table 6 presents all the numerical results regarding the three objective functions for the S1.

Table 6. Simulation results in the 33-nodes test feeder operated with unity power factor.

Obj. Fun.	Case 1 (kWh/day)	Case 2 (MCOP\$)	Case 3 (lb/day)
Case 1	186.918	9.627	30,042.760
Case 2	449.949	4.152	13,731.976
Case 3	366.155	4.345	13,618.771

The results in the S1 reported in Table 6 allows to observe that:

- ✓ The minimization of the energy losses during the day (186.918 kWh/day) implies high costs regarding energy purchase at the slack node (MCOP\$9.627). This is a logical result since in this case, the main idea is to define the optimal power injection in renewables (and batteries) and conventional sources to minimize the magnitude of the current flowing through the lines. The energy losses is a function of the square values of the current. Since the objective function is associated with lines the optimization model does not take into account the origin of the energy, which implies that the algorithm chooses whether to purchase energy in the spot market to optimize the objective function regarding energy losses without taking into account its acquisition costs.
- ✓ The second case shows that the minimization of the energy purchase costs in the slack node (MCOP\$4.152) is directly related to the minimization of the total gas emissions of CO₂ (13731.976 lb/day) since both are involved with the amount of power injected at this node. Nevertheless, this situation produces the highest energy losses during the operation horizon (449.949 kWh/day). This is explained by the objective function selected since in this case, the goal is to minimize the energy production on the slack node regardless the final magnitude of the current flow through the lines, that accordingly increases the energy losses in the whole system.
- ✓ The third case shows that effectively the energy costs and the amount of CO₂ emissions are correlated objective functions, since minimum values of one of them produces minimum values in the other one with minimal variations; however, this objective function allows reaching a better performance regarding energy losses with 366.155 kWh/day, being an attractive solution since allows to reduce polluting emission gases with low energy purchase costs (MCOP\$4.345) and acceptable daily energy losses.

In Table 7 the numerical results for the S2, i.e., the operation of the 33-nodes test feeder considering active and reactive power consumptions are presented. In general, numerical results presents the same behavior reported in the analysis of the S1. Nevertheless, we can notice that energy losses are drastically affected by the presence of the reactive power consumptions inside of the network. Note that in the first case, energy losses have been incremented at least 5 times in comparison to the unity power factor case. In addition, regarding the minimization of the energy purchase costs in the spot market and the greenhouse gas emissions, the increments are about 1.04 times for both cases, which allows concluding that reactive power practically does not produce effects in those objectives when compared to the operation with unitary power factor.

Table 7. Simulation results in the 33-nodes test feeder operated with active and reactive power loads.

Obj. Fun.	Case 1 (kWh/day)	Case 2 (MCOP\$)	Case 3 (lb/day)
Case 1	948.979	9.774	30,501.450
Case 2	1219.420	4.347	14,329.381
Case 3	1134.773	4.535	14,215.115

6.2. Operation of the DC Network

To evaluate the performance of the 33-nodes test feeder, it was considered that the system can be represented by a DC equivalent as defined in the S1. In this sense, the reactive power loads and reactance of this model are removed. The implementation of optimal power flow for this DC medium-voltage distribution network is reported in Table 8.

Table 8. Simulation results in the 33-nodes test feeder operated with DC technology.

Obj. Fun.	Case 1 (kWh/day)	Case 2 (MCOP\$)	Case 3 (lb/day)
Case 1	186.898	9.627	30,041.788
Case 2	449.365	4.152	13,731.910
Case 3	365.504	4.345	13,618.717

From the results reported in Table 8 we can note that:

- ✓ The behavior of the DC equivalent of the 33-node test feeder (see Table 8) is identical to the behavior of this system when unity power factor is assigned at all the loads as can be seen in Table 6. These results imply that when the AC grid is used to support only active power consumption (residential applications), its electrical efficiency is 100% comparable to the emerging DC distribution networks.
- ✓ The only difference between AC and DC distribution considering purely active power consumptions correspond to the need of generating small reactive power quantities in the slack source to support the reactive power losses throughout all the lines. In this context, when the 33-nodes test feeder is operated with unity power factor and considering the minimization of the total energy purchasing costs, the amount of reactive energy generated during the day is about 332.022 kVAr/day, which needs to be provided by the slack source; while in the DC distribution case this reactive power is inexistent; which can be considered an advantage of the DC technology when compared with the AC counterpart.

6.3. Efficiency Comparison for Different Power Factors

To demonstrate that the DC distribution network is an attractive alternative to provide electrical service to industrial users connected at medium-voltage levels, let us compare the efficiency of this technology with conventional AC grids for different percentages of reactive power consumptions.

Remark 7. Recall that DC distribution networks are able to provide active and reactive power support to AC loads by using a voltage source converter (VSC) that interfaces the DC grid to the AC load as can be demonstrated in [32], where an isolated (i.e., rural) AC grid receives voltage and power support by interconnecting linear and non-linear loads to DC distribution grids via a VSC.

In Figure 6 it is presented the amount of energy losses (objective function minimize) in the AC grid when the reactive power load changes from 0 to 120% of the peak value reported in Table 3; in addition, the total energy losses are also presented in the DC equivalent network, assuming that the energy losses at all the VSCs are about 10% of the total energy losses of the network. Please note that in the case of the DC grid the reactive power is provided directly at the load side, which implies that this power is provided by the power electronic interface as explained in Section 4. For this reason, the active

power losses for DC grids remains constant for different percentage of reactive power demands at the load side, since no currents are associated with this power flow in DC distribution lines.




Figure 6. Amount of daily energy losses for different penetrations of reactive power consumptions at the load side.

The information regarding daily energy losses in the AC and DC equivalent networks make evident that the efficiency of the AC grid is deteriorated rapidly as a function of the amount of reactive power consumption at all the loads due to the exponential increment of the total energy losses. Nevertheless, in the case of the DC network the efficiency is always constant regardless the reactive power consumption. This is explained by the fact that the VSCs that interface the AC loads are able to locally generate reactive power, which implies that the DC distribution makes the node can sense their effects in its lines. Please note that when the loads in the 33-nodes test feeders are 100% reactive power consumption, the AC grid has 948.979 kWh/day of energy losses, while in the case of the DC equivalent these losses are about 205.588 kWh/day. These results imply that the AC grid has at least 4.6 times more energy losses than the DC equivalent, which confirms that the DC technology is a promissory alternative to provide the electricity service at medium- and low-voltage distribution levels with higher efficiency levels regarding energy losses, compared at the distribution stage, i.e., involving energy losses in conductors used in the electricity distribution. It is important to mention that this high relation (i.e., 4.6 times for the 33-nodes test feeder) is largely influenced by the relation between active and reactive power demand in the distribution network under study. This implies that this data can be considered to be an indicator, but more studies regarding energy efficiency at all the electronic interfaces (renewable generators, energy storage devices and controllable loads) are needed to determine the overall energy efficiency at distribution levels.

6.4. Effect of Renewable Energy Variations in the Economic Dispatch

In this subsection it is explored the possible operation scenario where renewable energy has important variations regarding weather conditions such as cloudy and rainy days, including very low-speed winds. In this case, we consider as objective function the total energy losses minimization during daily operation, i.e., the Case 1. To consider all the possible operation scenarios in a real network, we consider that the amount of renewable energy varies from 0% to 100% in steps of 20%. In addition, we consider that all the loads in the 33-nodes test feeder operate under normal conditions, i.e., 100% of active and reactive power consumption.

Table 9 presents the behavior of the AC and DC distribution networks when there are higher variations in renewable energy production.

Table 9. Daily energy losses as a function of the renewable energy variations.

Penetration (%)	AC Network (kWh/day)	DC Network (kWh/day)	Diff. (kWh/day)	Relation AC/DC
0	2355.704	1639.291	716.4130	1.4370
20	1705.694	969.892	735.8020	1.7586
40	1271.238	524.844	746.3940	2.4221
60	1039.554	291.767	747.7870	3.5630
80	963.319	218.631	744.6880	4.4061
100	948.979	205.588	743.3910	4.6159

From results reported in Table 9 we can observe that: (i) the difference regarding daily energy losses between AC and DC grids remains practically constant with an average value of 739.0792 kWh/day. This implies that at all the possible renewable energy penetration scenarios the DC grid has better behavior in terms of grid energy losses, which can be explained by the possibility to provide local reactive power with the VSC interface. This latter is not the case of the AC grid where the reactive energy flows from the substation to the loads; (ii) the division between the DC and AC energy losses presented in the last column of Table 9 shows that the efficiency of the DC grid in comparison to the AC case increases as a function of the renewable energy penetration in the grid; this behavior is mainly associated with the important reductions in the power flow through the lines caused by local injections of active power by renewable sources; and (iii) the total energy reduction in the AC grid when renewable energy penetration passes from 0 % to 100% is about 59.72%, while in the case of the DC network this reduction is about 84.46%, which entails that the same level of renewable energy penetration provides more positive impacts in a distribution network designed under the DC paradigm in contrast with the conventional AC grids.

7. Conclusions and Future Works

A comparative study regarding energy efficiency in AC and DC electrical networks for power distribution from the point of view of optimal power flow analysis was presented in this paper. This study allowed to confirm that AC and DC technologies have identical performances in residential applications, i.e., unity power factor, since the amount of energy losses, greenhouse gas emissions of CO₂ or energy purchase costs are practically the same for both technologies. Nevertheless, in the case of high penetration of reactive power consumptions in AC networks (mainly in industrial applications), it was demonstrated that the performance of the AC grid is rapidly deteriorated compared with the DC equivalent, due to the need to transport this reactive power from the substation towards the loads. This increases the magnitude of the current through the lines, being translated into higher energy losses during the operation horizon. This situation does not happen in the case of the DC grids where reactive power is directly provided by the VSCs that interfaces all the AC loads, which implies that the efficiency of the DC distribution system remains constant regardless the reactive power requirements of the load.

To solve the optimal power flow models regarding the daily operation of AC and DC grids, we have introduced the GAMS software to efficiently solves both models with low computation effort, i.e., processing times about 5 s in all the simulation cases and scenarios. This low-computational time is important since multiple simulation cases can be analyzed before taking the final decision in regards with the day-ahead economic dispatch environment, which makes the GAMS software an attractive alternative for tertiary control in distribution networks. In addition, the GAMS package is a proper tool to solve complex optimization problems by focusing the attention on correctly developing the optimization models rather than the solution technique. This represents an ideal framework to easily introduce engineers and researchers in mathematical optimization; for this reason, this paper has been addressed in a tutorial form.

As future work it will be possible to analyze the following problems: (i) propose convex reformulations for optimal power flow analyses in AC and DC networks that will ensure reaching the global optimum of the problem under well-defined operative conditions, which are very attractive

for real economic dispatch applications, (ii) make a comparative study between AC and DC grids considering transient operation scenarios such as suddenly load disconnections or short-circuit cases, which can be used in protective devices coordination studies for these grids, and extend the economic dispatch optimization model to three-phase distribution networks and bipolar DC configurations operated under unbalanced loads scenarios to analyze their efficiency in terms of power losses and voltage profiles.

Author Contributions: Conceptualization, methodology, software and writing—review and editing, O.D.M., F.M.S. and C.H.D.A. All authors have read and agreed to the published version of the manuscript.

Funding: This work was partially supported by the Universidad Tecnológica de Bolívar under grant CP2019P011 associated with the project: “Operación eficiente de redes eléctricas con alta penetración de recursos energéticos distribuidos considerando variaciones en el recurso energético primario”.

Acknowledgments: The authors want to express to thanks to Universidad Nacional de San Luis and Consejo Nacional de Investigaciones Científicas y Técnicas (CONICET) in Argentina, and Universidad Distrital Francisco José de Caldas and Universidad Tecnológica de Bolívar in Colombia.

Conflicts of Interest: The authors declare no conflicts of interest.

References

1. Poudineh, R.; Peng, D.; Mirnezami, S. *Electricity Networks: Technology, Future Role and Economic Incentives for Innovation*; Technical Report; The Oxford Institute for Energy Studies: Oxford, UK, 2017; doi:10.26889/9781784671006.
2. Liu, Y.; Yu, Z.; Li, H.; Zeng, R. The LCOE-Indicator-Based Comprehensive Economic Comparison between AC and DC Power Distribution Networks with High Penetration of Renewable Energy. *Energies* **2019**, *12*, 4621, doi:10.3390/en12244621.
3. Simiyu, P.; Xin, A.; Wang, K.; Adwek, G.; Salman, S. Multiterminal Medium Voltage DC Distribution Network Hierarchical Control. *Electronics* **2020**, *9*, 506, doi:10.3390/electronics9030506.
4. Li, H.; Cui, H.; Li, C. Distribution Network Power Loss Analysis Considering Uncertainties in Distributed Generations. *Sustainability* **2019**, *11*, 1311, doi:10.3390/su11051311.
5. Montoya, O.D.; Grajales, A.; Hincapié, R.A.; Granada, M. A new approach to solve the distribution system planning problem considering automatic reclosers. *Ingeniare Rev. Chil. Ing.* **2017**, *25*, 415–429, doi:10.4067/s0718-33052017000300415.
6. Correa, K.A.; Cortes-Alonso, R.A. *Technical Analysis of Power Losses in Medium Voltage Levels*; Resreport; Universidad Tecnológica de Pereira: Risaralda, Colombia, 2019. (In Spanish)
7. Montoya, O.D.; Gil-González, W. Dynamic active and reactive power compensation in distribution networks with batteries: A day-ahead economic dispatch approach. *Comput. Electr. Eng.* **2020**, *85*, 106710, doi:10.1016/j.compeleceng.2020.106710.
8. Gil-González, W.; Montoya, O.D.; Grisales-Noreña, L.F.; Cruz-Peragón, F.; Alcalá, G. Economic Dispatch of Renewable Generators and BESS in DC Microgrids Using Second-Order Cone Optimization. *Energies* **2020**, *13*, 1703, doi:10.3390/en13071703.
9. Load Flow Analysis. In *Modern Power Systems Analysis*; Springer US: New York, NY, USA, 2008; pp. 71–128, doi:10.1007/978-0-387-72853-7_2.
10. Li, R.; Wang, W.; Chen, Z.; Jiang, J.; Zhang, W. A Review of Optimal Planning Active Distribution System: Models, Methods, and Future Researches. *Energies* **2017**, *10*, 1715, doi:10.3390/en10111715.
11. Wang, S.; Sun, Y.; Li, Y.; Li, K.; An, P.; Yu, G. Optimal Planning of Distributed Generation and Loads in Active Distribution Network: A Review. In Proceedings of the 2020 4th International Conference on Green Energy and Applications (ICGEA), Singapore, 7–9 March 2020; pp. 176–181.
12. Chew, B.S.H.; Xu, Y.; Wu, Q. Voltage Balancing for Bipolar DC Distribution Grids: A Power Flow Based Binary Integer Multi-Objective Optimization Approach. *IEEE Trans. Power Syst.* **2019**, *34*, 28–39.
13. Montoya, O.D.; Grisales-Noreña, L.F.; Gil-González, W.; Alcalá, G.; Hernandez-Escobedo, Q. Optimal Location and Sizing of PV Sources in DC Networks for Minimizing Greenhouse Emissions in Diesel Generators. *Symmetry* **2020**, *12*, 322, doi:10.3390/sym12020322.

14. Grisales-Noreña, L.; Montoya, O.D.; Ramos-Paja, C.A. An energy management system for optimal operation of BSS in DC distributed generation environments based on a parallel PSO algorithm. *J. Energy Storage* **2020**, *29*, 101488, doi:10.1016/j.est.2020.101488.
15. Altun, T.; Madani, R.; Yadav, A.P.; Nasir, A.; Davoudi, A. Optimal Reconfiguration of DC Networks. *IEEE Trans. Power Syst.* **2020**, doi:10.1109/TPWRS.2020.2994962.
16. Montoya, O.D.; Gil-González, W.; Rivas-Trujillo, E. Optimal Location-Reallocation of Battery Energy Storage Systems in DC Microgrids. *Energies* **2020**, *13*, 2289, doi:10.3390/en13092289.
17. Jakus, D.; Čadenović, R.; Vasilj, J.; Sarajčev, P. Optimal Reconfiguration of Distribution Networks Using Hybrid Heuristic-Genetic Algorithm. *Energies* **2020**, *13*, 1544, doi:10.3390/en13071544.
18. Diaaeldin, I.; Aleem, S.A.; El-Rafei, A.; Abdelaziz, A.; Zobaa, A.F. Optimal Network Reconfiguration in Active Distribution Networks with Soft Open Points and Distributed Generation. *Energies* **2019**, *12*, 4172, doi:10.3390/en12214172.
19. Čadenović, R.; Jakus, D.; Sarajčev, P.; Vasilj, J. Optimal Distribution Network Reconfiguration through Integration of Cycle-Break and Genetic Algorithms. *Energies* **2018**, *11*, 1278, doi:10.3390/en11051278.
20. Injeti, S.K.; Shareef, S.M.; Kumar, T.V. Optimal Allocation of DGs and Capacitor Banks in Radial Distribution Systems. *Distrib. Gener. Altern. Energy J.* **2018**, *33*, 6–34, doi:10.1080/21563306.2018.12016723.
21. Nagaraju, S.K.; Sivanagaraju, S.; Ramana, T.; Satyanarayana, S.; Prasad, P.V. A Novel Method for Optimal Distributed Generator Placement in Radial Distribution Systems. *Distrib. Gener. Altern. Energy J.* **2011**, *26*, 7–19, doi:10.1080/15453669.2011.10388608.
22. Gil-González, W.; Montoya, O.D.; Grisales-Noreña, L.F.; Perea-Moreno, A.J.; Hernandez-Escobedo, Q. Optimal Placement and Sizing of Wind Generators in AC Grids Considering Reactive Power Capability and Wind Speed Curves. *Sustainability* **2020**, *12*, 2983, doi:10.3390/su12072983.
23. Rao, R.S.; Satish, K.; Narasimham, S.V.L. Optimal Conductor Size Selection in Distribution Systems Using the Harmony Search Algorithm with a Differential Operator. *Electr. Power Compon. Syst.* **2011**, *40*, 41–56, doi:10.1080/15325008.2011.621922.
24. TÜRKAY, B.; ARTAÇ, T. Optimal Distribution Network Design Using Genetic Algorithms. *Electr. Power Compon. Syst.* **2005**, *33*, 513–524, doi:10.1080/15325000590505028.
25. Falaghi, H.; Ramezani, M.; Haghifam, M.R.; Milani, K. Optimal selection of conductors in radial distribution systems with time varying load. In Proceedings of the 18th International Conference and Exhibition on Electricity Distribution (CIRED 2005), Turin, Italy, 6–9 June 2005; doi:10.1049/cp:20051351.
26. Javadian, S.; Haghifam, M.R. Optimal placement of protective devices in distribution networks based on risk analysis. In Proceedings of the 2010 IEEE/PES Transmission and Distribution Conference and Exposition: Latin America (T&D-LA), Sao Paulo, Brazil, 8–10 November 2010; doi:10.1109/tdc-la.2010.5762875.
27. Montoya, O.D.; Hincapie, R.A.; Granada, M. Optimal Location of Protective Devices Using Multi-objective Approach. In *Communications in Computer and Information Science*; Springer International Publishing: Berlin/Heidelberg, Germany, 2018; pp. 3–15, doi:10.1007/978-3-030-00353-1_1.
28. Katyara, S.; Staszewski, L.; Leonowicz, Z. Protection Coordination of Properly Sized and Placed Distributed Generations—Methods, Applications and Future Scope. *Energies* **2018**, *11*, 2672, doi:10.3390/en11102672.
29. Fathima, H.; Palanisamy, K. Optimized Sizing, Selection, and Economic Analysis of Battery Energy Storage for Grid-Connected Wind-PV Hybrid System. *Model. Simul. Eng.* **2015**, *2015*, 1–16, doi:10.1155/2015/713530.
30. Lavorato, M.; Franco, J.F.; Rider, M.J.; Romero, R. Imposing Radiality Constraints in Distribution System Optimization Problems. *IEEE Trans. Power Syst.* **2012**, *27*, 172–180.
31. Montoya, O.D.; Gil-González, W.; Garcés, A. Numerical methods for power flow analysis in DC networks: State of the art, methods and challenges. *Int. J. Electr. Power Energy Syst.* **2020**, *123*, 106299, doi:10.1016/j.ijepes.2020.106299.
32. Serra, F.M.; Fernández, L.M.; Montoya, O.D.; Gil-González, W.; Hernández, J.C. Nonlinear Voltage Control for Three-Phase DC-AC Converters in Hybrid Systems: An Application of the PI-PBC Method. *Electronics* **2020**, *9*, 847, doi:10.3390/electronics9050847.
33. Rodríguez, P.; Rouzbehi, K. Multi-terminal DC grids: challenges and prospects. *J. Mod. Power Syst. Clean Energy* **2017**, *5*, 515–523, doi:10.1007/s40565-017-0305-0.
34. Luna, A.C.; Diaz, N.L.; Andrade, F.; Graells, M.; Guerrero, J.M.; Vasquez, J.C. Economic power dispatch of distributed generators in a grid-connected microgrid. In Proceedings of the 2015 9th International Conference on Power Electronics and ECCE Asia (ICPE-ECCE Asia), Seoul, Korea, 1–5 June 2015; pp. 1161–1168.

35. Macedo, L.H.; Franco, J.F.; Rider, M.J.; Romero, R. Optimal Operation of Distribution Networks Considering Energy Storage Devices. *IEEE Trans. Smart Grid* **2015**, *6*, 2825–2836.
36. Soroudi, A. *Power System Optimization Modeling in GAMS*; Springer International Publishing: Berlin/Heidelberg, Germany, 2017; doi:10.1007/978-3-319-62350-4.
37. Montoya, O.D.; Grajales, A.; Garces, A.; Castro, C.A. Distribution Systems Operation Considering Energy Storage Devices and Distributed Generation. *IEEE Lat. Am. Trans.* **2017**, *15*, 890–900.
38. Giraldo, O.D.M. Solving a Classical Optimization Problem Using GAMS Optimizer Package: Economic Dispatch Problem Implementation. *Ingeniería y Ciencia* **2017**, *13*, 39–63, doi:10.17230/ingciencia.13.26.2.
39. Aguado, J.; de la Torre, S.; Triviño, A. Battery energy storage systems in transmission network expansion planning. *Electr. Power Syst. Res.* **2017**, *145*, 63–72, doi:10.1016/j.epsr.2016.11.012.
40. Montoya, O.D.; Gil-González, W.; Grisales-Noreña, L.; Orozco-Henao, C.; Serra, F. Economic Dispatch of BESS and Renewable Generators in DC Microgrids Using Voltage-Dependent Load Models. *Energies* **2019**, *12*, 4494, doi:10.3390/en12234494.
41. Montoya, O.D.; Gil-González, W.; Grisales-Noreña, L. An exact MINLP model for optimal location and sizing of DGs in distribution networks: A general algebraic modeling system approach. *Ain Shams Eng. J.* **2020**, *11*, 409–418, doi:10.1016/j.asej.2019.08.011.
42. kumar, M.; kumar, A.; Sandhu, K. Optimal Location of WT based Distributed Generation in Pool based Electricity Market using Mixed Integer Non Linear Programming. *Mater. Today Proc.* **2018**, *5*, 445–457, doi:10.1016/j.matpr.2017.11.104.
43. Naghiloo, A.; Abbaspour, M.; Mohammadi-Ivatloo, B.; Bakhtari, K. GAMS based approach for optimal design and sizing of a pressure retarded osmosis power plant in Bahmanshir river of Iran. *Renew. Sustain. Energy Rev.* **2015**, *52*, 1559–1565, doi:10.1016/j.rser.2015.08.018.
44. Skworcow, P.; Paluszczyszyn, D.; Ulanicki, B.; Rudek, R.; Belrain, T. Optimisation of Pump and Valve Schedules in Complex Large-scale Water Distribution Systems Using GAMS Modelling Language. *Procedia Eng.* **2014**, *70*, 1566–1574, doi:10.1016/j.proeng.2014.02.173.
45. Amin, W.T.; Montoya, O.D.; Grisales-Noreña, L.F. Determination of the Voltage Stability Index in DC Networks with CPLs: A GAMS Implementation. In *Communications in Computer and Information Science*; Springer International Publishing: Berlin/Heidelberg, Germany, 2019; pp. 552–564, doi:10.1007/978-3-030-31019-6_46.
46. Tartibu, L.; Sun, B.; Kaunda, M. Multi-objective optimization of the stack of a thermoacoustic engine using GAMS. *Appl. Soft Comput.* **2015**, *28*, 30–43, doi:10.1016/j.asoc.2014.11.055.
47. Gallego-Londoño, J.P.; Montoya-Giraldo, O.D.; Hincapié-Isaza, R.A.; Granada-Echeverri, M. Ubicación óptima de reconectores y fusibles en sistemas de distribución. *ITECKNE* **2016**, *13*, 113, doi:10.15332/iteckne.v13i2.1476.
48. Shen, T.; Li, Y.; Xiang, J. A Graph-Based Power Flow Method for Balanced Distribution Systems. *Energies* **2018**, *11*, 511, doi:10.3390/en11030511.
49. Gil-González, W.; Montoya, O.D.; Garces, A. Direct power control for VSC-HVDC systems: An application of the global tracking passivity-based PI approach. *Int. J. Electr. Power Energy Syst.* **2019**, *110*, 588–597, doi:10.1016/j.ijepes.2019.03.042.
50. Siraj, K.; Khan, H.A. DC distribution for residential power networks-A framework to analyze the impact of voltage levels on energy efficiency. *Energy Rep.* **2020**, *6*, 944–951, doi:10.1016/j.egy.2020.04.018.
51. Grisales-Noreña, L.; Montoya, D.G.; Ramos-Paja, C. Optimal Sizing and Location of Distributed Generators Based on PBIL and PSO Techniques. *Energies* **2018**, *11*, 1018, doi:10.3390/en11041018.

