

Article

Thermal, Lighting and IAQ Control System for Energy Saving and Comfort Management

Silvia Maria Zanolì *  and Crescenzo Pepe 

Dipartimento di Ingegneria dell'Informazione, Università Politecnica delle Marche, Via Brecce Bianche 12, 60131 Ancona, Italy

* Correspondence: s.zanolì@univpm.it

Abstract: The present work proposes a simulation and control framework for home and building automation, focusing on heating, ventilating, and air conditioning processes. Control systems based on different advanced control architectures and different control policies are simulated and compared, highlighting control performances, and energy-saving results in terms of CO₂ emissions reduction. Heat, lighting, and natural ventilation phenomena were modeled through first-principles and empirical equations, obtaining a reliable and flexible simulation framework. Energy-consuming and green energy-supplying renewable sources were integrated into the framework, e.g., heat pumps, artificial lights, fresh air flow, and natural illuminance. Different control schemes are proposed, based on proportional–integral–derivative advanced control architectures and discrete event dynamic systems-based supervisors; different control specifications are included, resulting in a multi-mode control system. The specifications refer to energy savings and comfort management, while minimizing overall costs. Comfort specifications include thermal comfort, lighting comfort, and a good level of indoor air quality. Simulations on different scenarios considering various control schemes and specifications show the reliability and soundness of the simulation and control framework. The simulated control and energy performances show the potential of the proposed approach, which can provide energy-saving results greater or equal to 6 [%] (in each season) and 19 [%] (in one year) with respect to more standard approaches.



Citation: Zanolì, S.M.; Pepe, C. Thermal, Lighting and IAQ Control System for Energy Saving and Comfort Management. *Processes* **2023**, *11*, 222. <https://doi.org/10.3390/pr11010222>

Academic Editors: Ferdinando Salata and Virgilio Ciancio

Received: 4 December 2022

Revised: 31 December 2022

Accepted: 3 January 2023

Published: 10 January 2023



Copyright: © 2023 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

Keywords: home and building automation; control system; renewable resources; energy saving; comfort management; indoor air quality; proportional–integral–derivative; discrete event dynamic systems

1. Introduction

Energy efficiency and energy performance maximization in buildings represent a challenge, as stated by the European Parliament in the last decade. The main objective is to reduce greenhouse gas emissions further by at least 40% by 2030 as compared with 1990, to increase the proportion of renewable energy consumed, to make energy savings in accordance with European Union level ambitions, and to improve Europe's energy security, competitiveness, and sustainability [1,2]. An efficient and resilient building and construction sector is a fundamental requirement for zero-emission policies and clean energy transition. For example, in 2017, buildings' construction and operations accounted for 36% of the global final energy use and nearly 40% of the energy-related carbon dioxide (CO₂) emissions [3]. In this context, programs have been introduced in the last few years, e.g., Agenda 2030 [4] at the global level and PNRR (Piano Nazionale di Ripresa e Resilienza) at the Italian level [5].

An efficient approach to reaching optimal solutions is to consider the hardware and software aspects of the buildings: hardware may refer to construction technologies and the geometry of the buildings while, software programs can exploit monitoring, modelization, control, and automation strategies [6]. Monitoring, control [7] and automation strategies [8,9]

can be cross-fertilized from other areas, e.g., petrochemical and/or energy-intensive industries [10,11].

The processes which require significant energy consumption in buildings are heating, ventilating and air conditioning (HVAC), heating, ventilating, air conditioning and refrigeration (HVACR), and domestic hot water (DHW). The home and building automation (HBA) research area can cover these topics [12]. With regard to HVAC, four main factors have to be taken into account: thermal comfort, lighting comfort, a good level of indoor air quality (IAQ), and energy saving. In this context, comfort can be reached by maximizing the natural illuminance, maintaining a desirable indoor temperature, and ensuring IAQ. Conflicting objectives between comfort and energy saving must be handled [13]. In the last few years, many researchers, engineers, and practitioners have proposed monitoring, simulation, high-level optimization, and control solutions for HBA.

Monitoring and simulation solutions are proposed in [14–19]. In [14], an internet of things-based occupancy monitoring system for energy-efficient smart buildings is proposed. The occupancy monitoring is obtained through a minimally intrusive way, and data fusion techniques are developed to improve the occupancy monitoring accuracy through a multitude of sources. The use of the EnergyPlus tool is discussed in [15], analyzing how simulation can support HBA and how the deployment process of simulation-assisted building control systems can be structured. In [16], the authors accurately describe a building management system (BMS), also known as a building automation and control system (BACS), highlighting the benefits provided by the design, development and implementation of automated step response testing tools. The COVID-19 consequences on buildings' management were analyzed in [17,18], assessing the current problems and difficulties that smart buildings face and the possible future directions of this technology. In [19], a review of machine learning algorithms able to power smart homes is provided.

High-level optimization solutions are proposed in [20–23]. In [20], the bat algorithm is applied for energy optimization in residential buildings. Three environmental parameters, namely temperature, illuminance, and air quality, are the bat algorithm's inputs, and the optimized values of these parameters are the outputs. The error difference between the environmental parameters and the optimized parameters is the inputs of the fuzzy controllers, which return energy as an output, which in turn changes the status of the concerned actuators. In [21], to minimize the daily energy cost of HVAC and lights and maintain occupant comfort, a near-optimal strategy is proposed through a daily cost optimization problem solved by combining Lagrangian relaxation, stochastic dynamic programming, and rollout technique within a surrogate optimization framework. In [22], a real-time demand response strategy based on deep reinforcement learning is proposed as an optimal energy management strategy under the uncertainty of the residents' behavior, outdoor temperature, and renewable generation. In [23], an energy management controller is developed for the demand-side management in smart homes. Fuzzy logic and heuristic optimization techniques for cost, energy consumption, and peak-to-average ratio reduction are used.

The high-level optimization algorithms and monitoring/simulation solutions reported previously are not in charge of the management of the real-time operation of the plants. Real-time operation of the plants can be handled through process controllers. Different HBA control solutions are present in the literature, e.g., based on standard single-input single-output (SISO) proportional–integral–derivative (PID) techniques, fuzzy logic, pole placement, model predictive control (MPC) strategy, and deep learning. Standard PID techniques are proposed in [24–29]. Classical PID control algorithms are exploited in [24] for the control of a HVAC system having two zones with different properties. The PID parameters are tuned to minimize the tracking error, but the steady-state error is not totally eliminated. In [25], a tuning strategy for discharge air temperature control of air handlers in building comfort applications is designed. The proposed method adjusts fewer gain values than other tuning algorithms, and it is tested through a standard SISO loop that manipulates a valve command for the air handler in order to track the defined setpoint

for the discharge air temperature. A technique for the fast tuning of the parameters of a standard PID controller of a second-order HVAC system is proposed in [26]. A Big Bang–Big Crunch algorithm is implemented, along with the PID controller, in an FPGA device in order to achieve high tuning speed. In [27], the room temperature and humidity control systems with the conventional PID control using a fixed reset or the modified PID control using adjustable resets, which compensate for the thermal loads upset, are examined through simulations. The optimization of climate conditions in office buildings is proposed in [28] by the use of modeling and simulation tools to define the buildings' energy demand, and the design and implementation of standard PID controls for the different control areas of the HVAC system are also proposed. In [29], the modeling, numerical simulation, and intelligent control of an expert HVAC system having two different zones with variable flow rates were performed by considering the ambient temperature. Standard decoupled SISO PID architectures are used for the control of the temperature of the two zones, and the fuzzy logic is exploited for tuning purposes.

In [30–32], fuzzy logic is employed for control purposes in HBA. The use of smart handheld devices, using MIT App Inventor and fuzzy control, to perform the real-time monitoring and smart control of the designed intelligent windowsill system in a smart home is proposed in [30]. A fuzzy microcontroller exploits information provided by a weather station, which measures indoor illuminance, temperature-humidity, CO₂ concentration and outdoor rain, and wind direction. The control degrees of freedom are fully or partly open to the electric curtain and electric window. Other examples of fuzzy logic implementation are reported in [31,32], pursuing lighting comfort, visual comfort, thermal comfort, and energy-saving objectives. In [33], advanced controllers based on pole placement enhanced with additional variables, namely solar radiation and external temperature, are proposed as climatic control systems. The potential of model predictive control (MPC) for enhancing building and HVAC system energy efficiency is reported in [34], highlighting problem formulation, applications, and opportunities. A recent state-of-the-art review on MPC in the HVAC field is reported in [35], focusing on energy management, energy savings, simulation software, optimization, modelization, and disturbances. In [36], the combination of predictive control and deep thermo-modernization is tackled and studied in a real-world case study: the impact of weather-forecast-based regulation on energy savings for heating in multi-family buildings is assessed. Furthermore, deep learning models, such as convolutional neural networks, are reported.

As a result of the literature review, SISO PID architectures in HBA usually provide decoupled solutions for thermal, lighting, and IAQ control. On the other hand, the main drawbacks of the other analyzed control solutions are the need for in-depth process knowledge for fuzzy logic and the need for accurate models for MPC and pole-placement solutions. The present paper proposes a simulation framework and advanced control approaches for HBA based on PID and discrete event dynamic systems (DEDS), focusing on HVAC processes. Combining different PID/DEDS advanced control architectures, a multi-mode control system is derived. The energy savings and comfort specifications are taken into account and tested through tailored simulations based on different scenarios, assessing control, and energy-saving performances. The paper aims to provide adaptable knobs for engineers, researchers, and practitioners. To the best of the authors' knowledge, in the literature on control systems in HVAC processes, the following aspects have not been explored in depth:

- The design of flexible simulation and control frameworks that allow the modelization and simulation of different environments and the test and comparison of different controllers is not present in the literature. In the design of control systems for energy saving and comfort management in HBA, flexible frameworks can represent a significant tool for designing and prototyping optimal control solutions.
- An assessment of advanced PID control architectures for energy savings and comfort management in HBA is not present in the literature. Exploiting non-standard PID control architectures, coupled control of thermal, lighting, and IAQ subprocesses can

be obtained. In this way, unexpected control margins can be detected and control performance can be improved over standard PID solutions.

- The combination of advanced PID control architectures with DEDS for energy savings and comfort management in HBA is not present in the literature. This combination can result in a significant improvement in energy savings and comfort management performances with respect to more standard control architectures.

Exploiting a multivariable approach with respect to HBA standard PID solutions, further energy savings and comfort margins can be observed. As it will be shown in the paper, the proposed approach can achieve energy-saving results greater than or equal to 6 [%] (in each season) and 19 [%] (in one year) with respect to more standard approaches.

The paper is organized as follows: Section 2 reports the material and methods, focusing on PID controllers, DEDS, and simulation/control frameworks. Section 3 reports the results and discussion, focusing on the control and energy-saving performances. The conclusions are summarized in Section 4.

2. Materials and Methods

2.1. PID Control Architectures

The PID control is exploited in a large number of sectors and at different levels of the automation hierarchy. PID techniques are typically used for SISO feedback control of processes with/without dead times (or delays) [37].

PID controllers are characterized by three main components that process the control error: proportional, integral and derivative. These components are represented by the tuning parameters K_P , T_I , T_D [37]. In order to efficiently control the process, the three terms have to be suitably tuned. In the literature, different tuning methods were proposed, e.g., the Ziegler-Nichols and Cohen-Coon methods. The Ziegler-Nichols frequency response and step response methods are widely used tuning methods for PID controllers [38].

The Ziegler-Nichols frequency response method (close-loop method) assumes to model the controlled process with two parameters: the ultimate gain (K_u) and the ultimate period (T_u). These parameters are determined by forcing the process through a P controller, increasing the proportional gain until the process oscillates critically. The gain yielding marginal stability is the ultimate gain, and the ultimate period is the period of oscillation in correspondence with the ultimate gain. Using the ultimate gain (K_u) and the ultimate period (T_u), the proportional, integral, and derivative gains are typically computed as in Table 1 [37].

Table 1. PID control parameters tuning (Ziegler-Nichols frequency response method) [37].

Controller	K_P	T_I	T_D
P	$0.5 \cdot K_u$		
PI	$0.4 \cdot K_u$	$0.8 \cdot T_u$	
PID	$0.6 \cdot K_u$	$0.5 \cdot T_u$	$0.125 \cdot T_u$

The Ziegler-Nichols step response method (open-loop method) is based on an open-loop step test procedure applied to the process, hence requiring the process to be stable. The unit step response of the process is characterized by two parameters, i.e., α and τ . These can be determined, for example, by drawing a tangent line at the inflexion point of the step response, where the slope of the step response has its maximum value. The intersections of the tangent and the coordinate axes give the parameter α and τ that are used to compute the proportional, integral, and derivative gains (see Table 2) [37].

Table 2. PID control parameters tuning (Ziegler-Nichols step response method) [37].

Controller	K_P	T_I	T_D
P	$1/\alpha$		
PI	$0.9/\alpha$	$3 \cdot \tau$	
PID	$1.2/\alpha$	$2 \cdot \tau$	$\tau/2$

As previously described, the PID technique can be exploited for the SISO control of processes with dead times (or delays). Often, industrial processes are modeled by a first-order plus deadtime (FOPDT) model. In the Laplace domain, this model is [39]:


$$y(s) = P(s)u(s) = P_\gamma(s)e^{-Ls}u(s) = \frac{K}{Ts + 1}e^{-Ls}u(s) \quad (1)$$

where s is the Laplace variable, $P(s)$ is the input-output transfer function, $P_\gamma(s)$ is the input-output transfer function without delay, y is the output, u is the input, K is the gain of the process, T is the time constant and L is the delay. In this paper, the case where the time constant T and the delay L are comparable is considered, i.e., [37]:

$$0.6 < \frac{L}{T} < 1 \quad (2)$$

Assuming that model (1) is sufficiently reliable, when Equation (2) holds, the Smith Predictor can be used [37]. This PID-based predictive controller overcomes the limitations of a PID controller, which exploits only feedback. A Smith Predictor architecture is reported in Figure 1. In Figure 1, r is the reference to be tracked, w and z are intermediate variables and y' is the feedback variable. The input-output transfer function related to y' is [37]

$$y'(s) = P_\gamma(s)(1 - e^{-Ls})u(s) \quad (3)$$

**Figure 1.** Smith Predictor architecture [37].

In Figure 1, $F(s)$ is a low-pass filter that allows to compensate low frequency errors. $F(s)$ can be defined as [37]:

$$F(s) = \frac{1}{0.5Ls + 1} \quad (4)$$

In the scheme of Figure 1, $R(s)$ can be designed as a PID controller.

Different control architectures based on PID controllers were introduced by researchers, engineers, and practitioners. Examples of these architectures are cascade, split-range, valve position, and override control [37].

A cascade control structure involves two or more PID controllers in serial connection and two or more nested control loops. The manipulated variable (MV) of the master controller is connected to the setpoint of the slave controller. The advantage of the cascade

control is that disturbance variables (DVs) affecting the inner loop can be compensated much more quickly in the slave (inner) loop than in the slower master (external) loop. The inner controller design is beneficial if its dynamics are faster. Cascade control requires a major effort in the tuning phase with respect to a standard PID controller. Due to the inner loop being an element within the master (external) one, it must be properly tuned before the master controller, with the master controller in manual mode. Then, the master controller should be tuned, with the inner controller in automatic mode [40].

A wide variety of process control problems are characterized by having one controlled variable (CV) and two or more MVs. The challenge from a control perspective is that there is no unique set of input values that can ensure the setpoint tracking of the CV. One of the most common ways of addressing this problem is known as split-range control. A splitter block is used to map the controller output to multiple MVs [41].

In many case studies (e.g., feedstock flow control), the synchronized use of actuators characterized by different dynamics, such as, for example, a small and a large actuation valve, can be required for accurate control over a significant operating range. An ideal solution would be to use the small valve to make fine changes and the large valve to significantly adjust the CV, differently from the split-range control, where valves are sequenced one at a time. Valve position control architecture achieves this type of regulation for the small and large valves [41].

In an override control architecture, two or more CVs share a common actuator (MV). Depending on the current process state, a decision is made on which controller is in charge of the actual manipulation of the actuator; in other words, the various controllers can override each other [37]. Figure 2 reports an override control architecture. In the case reported in Figure 2, the decision is based on a comparison of the computed MV requests of both controllers; for example, the controller that demands the higher MV value takes control of the actuator (high-pass selector). Both controllers run the entire time. This scheme can also be used in applications with more than two CVs and with low-pass selector logic.




Figure 2. Override control architecture with high-pass selector logic [37].

In order to implement efficient and flexible architectures, the previous control architectures can be enriched with anti-wind-up schemes and bumpless transfer techniques to handle possible transitions between manual and automatic control modes [37].

2.2. HVAC Simulation Framework

In order to design and implement a HVAC simulation framework, first-principles, and empirical models related to an office building were combined. The considered office building is located in Ancona, Italy. The HVAC simulation framework consists of a thermal model, a lighting model and an IAQ model [42,43]. Six walls (two floors and four vertical) and two windows characterize the rectangular layout of the single office room. The considered devices are reported in Figure 3: the actuators are the rolling shutters, the windows, a light dimmer and a heat pump (with a fan coil). The measured variables are

the room temperature (through a thermostat) and light (through a luxmeter). Furthermore, a weather station is considered for the measurement of the outdoor temperature, wind speed, and other parameters. Eventually, a presence sensor and IAQ sensors can be present. Table 3 reports the room parameters.




Figure 3. Overall system scheme.

Table 3. Room parameters.

Component/Device	Features	SI Measurement Unit
Room	[5.0 × 4.0 × 2.7]	[m] × [m] × [m]
Wall-SW	[5.0 × 2.7], Vertical	[m] × [m]
Wall-NW	[4.0 × 2.7], Vertical	[m] × [m]
Wall-NE	[5.0 × 2.7], Vertical, (Not Exposed)	[m] × [m]
Wall-SE	[4.0 × 2.7], Vertical, (Not Exposed)	[m] × [m]
Wall-A	[5.0 × 4.0], Horizontal	[m] × [m]
Wall-B	[5.0 × 4.0], Horizontal, (Not Exposed)	[m] × [m]
Window-SW1	[2 × 1.25 × 1], Vertical	[m] × [m] × [m]
Window-SW2	[2 × 1.25 × 1], Vertical	[m] × [m] × [m]
Heat Pump	COP* = 2.8, Max Power = 4	[], [kW]
Artificial Light (Dimmer)	location (2.5, 2.0, 2.4), Flux = 8900	[m], [lumen]

*COP = coefficient of performance.

2.2.1. Thermal Model

The thermal model of the considered office room takes into account the thermal behavior of the room, which can be modeled through an energy balance equation [42] reported in (5). Six main contributions were considered in Equation (5) for the total thermal accumulation, e.g., internal heat sources (Q_{IS} , due to people, lamps, and motors), heat pump source (Q_{HP}), thermal conduction and convection exchanges through walls (Q_W), thermal conduction, convection and radiation exchanges through windows (Q_{GL_S} , $Q_{GL_S_I}$), and finally the fluid dynamic exchanges with the outside environment (Q_{VENT}). The thermal contributions are reported in Equations (6)–(9), while the terms involved in the Equations (5)–(9) are reported in Table 4 [42].

$$m_a \cdot c_a \cdot \frac{\partial T_a(t)}{\partial t} = Q_{IS}(t) + Q_{HP}(t) + Q_W(t) + Q_{GL_S}(t) + Q_{GL_S_I}(t) + Q_{VENT}(t) \quad (5)$$

$$Q_W(t) = \sum_{k=1}^6 A_k \cdot h_{O_k} \cdot (T_{W_{k,L1}}(t) - T_a(t)) \quad (6)$$

$$Q_{GL,S}(t) = \sum_{j=1}^2 A_{gl_j} \cdot h_{Ogl_j} \cdot \left[(1 - SAF_j(t)) \cdot (T_{gl_j}(t) - T_a(t)) + SAF_j(t) \cdot (T_{gl_{s_j}}(t) - T_a(t)) \right] \quad (7)$$

$$Q_{GL,S,I}(t) = \sum_{j=1}^2 A_{gl_j} \cdot \left[(1 - SAF_j(t)) \cdot F_{G_{gl_j}} + SAF_j(t) \cdot F_{G_{gl_{s_j}}} \right] \cdot I_{gl_j}(t) \quad (8)$$

$$Q_{VENT}(t) = \sum_{j=1}^2 \rho_a \cdot c_a \cdot N_j(t) \cdot V_j \cdot (T_e(t) - T_a(t)) \quad (9)$$

Table 4. Thermal model parameters (Equations (5)–(9)).

Symbol	Description	SI Measurement Unit
Q_{IS}	Heat supplied by internal heat sources (people, lamps, and motors)	[W]
Q_{HP}	heat supplied by heat pump source	[W]
Q_W	heat supplied by walls	[W]
$Q_{GL,S}, Q_{GL,S,I}$	heat supplied by windows	[W]
Q_{VENT}	heat supplied by the outside environment	[W]
A_k	k th wall area	[m ²]
h_{O_k}	k th wall adduction coefficient	[W/(m ² ·K)]
h_{Ogl_j}	j th glass adduction coefficient	[W/(m ² ·K)]
$F_{G_{gl_j}}, F_{G_{gl_{s_j}}}$	solar gain coefficient (j th glass, j th glass/shutter)	[]
N_j	number of times air is exchanged through the j th window opening	[1/s]
ρ_a	air density	[kg/m ³]
c_a	air specific heat	[J/(kg·K)]
m_a	room air mass	[kg]
V_j	air incoming volume (fixed value) from j th window	[m ³]
$T_{W_{k,Lj}}$	temperature of j th layer of k th wall	[K]
T_{gl_j}	j th internal temperature of glass	[K]
$T_{gl_{s_j}}$	j th internal temperature of glass combined with shutters	[K]
T_a	room temperature	[K]
T_e	outside temperature	[K]
A_{gl_j}	j th glass area	[m ²]
SAF_j	j th shutter actuation factor	[%]
I_{gl_j}	j th glass solar thermal radiation	[W/m ²]

Indoor wall and glass temperatures are included in Equations (6) and (7). These terms are modeled through a dynamic multi-layer model. Figure 4 shows a multi-layer wall composed of five layers. For example, the first wall, i.e., the external wall, composed of five layers, can be modeled by Equations (10)–(14) [42] whose terms are described in Table 5.

$$\frac{\partial T_{W_k}(t)}{\partial t} = A \cdot T_{W_k}(t) + B \cdot u_{W_k}(t) \quad (10)$$

$$T_{W_k}(t) = \begin{bmatrix} T_{W_{k,L1}}(t) \\ \vdots \\ T_{W_{k,L5}}(t) \end{bmatrix} \quad (11)$$

$$u_{W_k}(t) = \begin{bmatrix} T_e(t) \\ T_a(t) \\ I_{W_k}(t) \\ I_{gl_1}(t) \\ I_{gl_2}(t) \end{bmatrix} \tag{12}$$

$$A = A_{W_k} \begin{bmatrix} -\frac{K_{e1}+K_{12}}{m_1c_1} & \frac{K_{12}}{m_1c_1} & 0 & 0 & 0 \\ \frac{K_{12}}{m_2c_2} & -\frac{K_{12}+K_{23}}{m_2c_2} & \frac{K_{23}}{m_2c_2} & 0 & 0 \\ 0 & \frac{K_{23}}{m_3c_3} & -\frac{K_{23}+K_{34}}{m_3c_3} & \frac{K_{34}}{m_3c_3} & 0 \\ 0 & 0 & \frac{K_{34}}{m_4c_4} & -\frac{K_{34}+K_{45}}{m_4c_4} & \frac{K_{45}}{m_4c_4} \\ 0 & 0 & 0 & \frac{K_{34}}{m_5c_5} & -\frac{K_{45}+K_{5i}}{m_5c_5} \end{bmatrix} \tag{13}$$

$$B = \begin{bmatrix} A_{W_k} \frac{K_{e1}}{m_1c_1} & 0 & A_{W_k} \frac{\alpha_e}{(h_e \cdot R_{e1})} & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & A_{W_k} \frac{K_{5i}}{m_5c_5} & 0 & \frac{\Gamma_1 \cdot A_{gl_1} \cdot \text{Tau}_1 \cdot F_1}{m_5c_5} & \frac{\Gamma_2 \cdot A_{gl_2} \cdot \text{Tau}_2 \cdot F_2}{m_5c_5} \end{bmatrix} \tag{14}$$





Figure 4. Multi-layer wall [42].

Table 5. Thermal model parameters (Equations (10)–(14)).

Symbol	Description	SI Measurement Unit
T_{W_k, L_j}	temperature of j th layer of k th wall	[K]
I_{gl_j}	j th glass solar thermal radiation	[W/m ²]
T_a	room temperature	[K]
T_e	outside temperature	[K]
I_{W_k}	k th wall solar thermal radiation	[W/m ²]
A_{W_k}	k th wall area	[m ²]
K_{ji}	thermal transmittance between layers j and i of the wall	[W/(m ² ·K)]
K_{e1}	thermal transmittance between layer one of the wall and outdoor air	[W/(m ² ·K)]
K_{5i}	thermal transmittance between layer five of the wall and indoor air	[W/(m ² ·K)]
m_i	mass of the layer i of the wall	[kg]
c_i	specific heat of the layer i of the wall	[J/(kg·K)]
α_e	absorption coefficient of the wall	[]
h_e	adduction coefficient of the wall	[W/(m ² ·K)]
R_{e1}	thermal resistance of the wall	[(m ² ·K)/W]
Γ_j	internal flux parameter	[]
A_{gl_j}	j th glass area	[m ²]
τ_j	j th glass transparency	[]
F_j	j th shutter shading factor	[]

The window's contribution to the room's thermal behavior is characterized by conduction, convection and radiation phenomena. Equation (7) represents conduction and convection, while Equation (8) reports the radiation contribution. In Equations (7) and (8), two sections characterize the window's contribution (see Figure 5): the first section is related to the lower part of the glass window and takes into account only the contribution of the glass (subscript gl), while the second section takes into account the contribution of the glass coupled to the rolling shutter (subscript gl_s). These contributions are modeled separately here and not reported for brevity. The density, the thickness, and the specific heat of glass and rolling shutters characterize these contributions [44].

**Figure 5.** Considered sections of the windows [44].

In order to estimate the thermal radiation related to the windows' glass and to the walls, historical data were selected for the considered location (see Table 3). Different seasons and times of day were taken into account. These inputs, together with the disposition of the

considered surfaces, were used in different algorithms, e.g., the Liu and Jordan method or the Collares-Pereira and Rabl method [45].

With regard to the outside temperature used in the thermal model, historical data were selected for the considered location (see Table 3).

The formulated thermal model can be suitably extended to different room configurations and features and to multi-room environments. For example, if a wall with more than five layers were to be considered, a number of equations (similar to Equation (10)) equal to the assumed layers' number would result. In addition, if a multi-room environment is assumed, an equation (similar to Equation (5)) for each room must be included in the model, taking into account possible coupling effects between the different rooms.

2.2.2. Lighting Model

Artificial light and natural illuminance were considered for the designed lighting model. Different assumptions on the room/lights and room/window relative dimensions were made for the lighting model (see Table 3). The superposition principle is applied, so uniformity of the light radiation is assumed. Furthermore, extended light sources and point light sources were considered: natural light sources belong to the first category, while artificial light sources were included in the second one. Equation (15) reports the designed lighting model for a generic point of interest $P(x, y, z)$ [46,47], while Table 6 summarizes the involved parameters.

Table 6. Lighting model parameters (Equation (15)).

Symbol	Description	SI Measurement Unit
E_a	environment illuminance at the point of interest $P(x, y, z)$	[Lux]
$E_{N_D_gl,j}$	natural diffuse illuminance on the window	[Lux]
$E_{N_R_gl,j}$	natural reflection illuminance on glass	[Lux]
$E_{NAT_gl,j}$	natural direct illuminance on glass	[Lux]
$C_{j,c}, C_{j,r}$	environmental influence of natural diffuse/reflections illuminance at the point of interest $P(x, y, z)$	[]
I_L	artificial light source luminous emission	[cd/klm]
<i>Lumen</i>	luminous flux of the artificial light source	[lm]
γ	incidence angle of the light radiation in relation to the point of interest $P(x, y, z)$	[°C]
h	distance between the point of interest and light source	[m]
Tau_j	j th glass transparency	[]
V_j	natural direct illuminance coefficient	[]
$A_{gl,j}$	j th glass area	[m ²]
ρ	reflection coefficient	[]
$\rho_{weighted}$	average reflection coefficient of the walls	[]
<i>sum_{AREA}</i>	total area of the reflective walls	[m ²]
$E_{NAT_gl,j}$	j th glass area	[m ²]
η	efficiency of artificial light source	[]
M	maintenance factor	[]

$$E_a(t) = \sum_{j=1}^2 \left[C_{j,c} \cdot E_{N_D_gl,j}(t) + C_{j,r} \cdot E_{N_R_gl,j}(t) \right] + \frac{I_L(t) \cdot Lumen \cdot 1000 \cdot \cos(\gamma)^3}{h^2} + \sum_{j=1}^2 \frac{Tau_j \cdot V_j \cdot A_{gl,j} \cdot \rho_{weighted}}{sum_{AREA} \cdot (1 - \rho_{weighted})} E_{NAT_gl,j}(t) + \frac{Lumen \cdot \eta \cdot M \cdot \rho}{sum_{AREA} \cdot (1 - \rho_{weighted})} \quad (15)$$

The natural illuminance used in the lighting model was estimated. Historical data were selected for the considered location (see Table 3). Different seasons and times of day were taken into account.

The formulated lighting model can be suitably extended to different room configurations and features and to multi-room environments. For example, if different points of interest were to be considered, an equation (similar to Equation (15)) for each point of interest must be formulated. Furthermore, if more artificial light sources are present, different artificial light source contributions (similar to the second and fourth terms of Equation (15)) must be included. In addition, if more windows are present, different natural light source contributions (similar to the first and third terms of Equation (15)) have to be considered.

2.2.3. IAQ Model

The IAQ model is composed of three main sources of pollution: formaldehyde (HCHO), carbon dioxide (CO₂) and TVOC (total volatile organic compounds). The first one consists of a colorless organic compound with a highly irritating odor, used mainly in the production of wood panels and furniture, paints, and laminate. CO₂ is produced by people in sedentary work in the room. The last source of pollution, i.e., TVOC, includes different chemical compounds. The concentration of toxic waste can be evaluated in terms of the volume of pollution to the volume of standard indoor air [48].

IAQ dynamics are represented in Equations (16)–(19), while Table 7 reports the IAQ model parameters [49,50].

$$\frac{\partial \text{CO}_2(t)}{\partial t} = n_{\text{people}}(t) \cdot E_p + E_{\text{std}_{\text{air}}} \cdot G(t) - G(t) \cdot \frac{\text{CO}_2(t)}{\text{Vol}} \quad (16)$$

$$\frac{\partial \text{HCHO}(t)}{\partial t} = \sum_{i=1}^{n_{\text{furn}}} A_{\text{furn},i} \cdot E_{\text{furn},i} - G(t) \cdot \frac{\text{HCHO}(t)}{\text{Vol}} \quad (17)$$

$$\frac{\partial \text{TVOC}(t)}{\partial t} = A_{\text{room}} \cdot E_{\text{TVOC, room}} - G(t) \cdot \frac{\text{TVOC}(t)}{\text{Vol}} \quad (18)$$

$$G(t) = OW_{\text{window}} \cdot H_{\text{window}} \cdot S_{\text{wind}}(t) \quad (19)$$

Table 7. IAQ model parameters (Equations (16)–(19)).

Symbol	Description	SI Measurement Unit
CO ₂	room CO ₂	[m ³ CO ₂]
n_{people}	number of people in the room	[]
E_p	CO ₂ emissions for each people (sedentary)	[m ³ CO ₂ /s]
$E_{\text{std}_{\text{air}}}$	standard conditions air CO ₂	[m ³ CO ₂ /m ³]
G	natural ventilation flow rate	[m ³ /s]
Vol	room volume	[m ³]
HCHO	room HCHO	[mg HCHO]
n_{furn}	number of the room's furniture	[]
$A_{\text{furn},i}$	room's i th furniture area	[m ²]
$E_{\text{furn},i}$	room's i th furniture HCHO emissions per unit area	[mg HCHO/(m ² ·s)]
TVOC	room TVOC	[μg]
A_{room}	room area	[m ²]
$E_{\text{TVOC, room}}$	room's i th furniture TVOC emissions per unit area	[μg/(m ² ·s)]
OW_{window}	opening width of the window	[m]
H_{window}	height of the window	[m]
S_{wind}	wind speed	[m/s]

The wind speed used in the IAQ model was estimated. Historical data were selected for the considered location (see Table 3). Different seasons and times of day were taken into account.

The formulated IAQ model can be suitably extended to different room configurations and features and to multi-room environments. For example, if a multi-room environment is

assumed, a set of equations (similar to Equations (16)–(18)) for each room must be included in the model.

2.2.4. Case Study Additional Details

The room planimetry and top view are reported in Figure 6. In the planimetry of Figure 6, only the four vertical walls are reported; the other two horizontal ones (Wall-A and Wall-B in Table 3) are an attic floor and an intermediate floor; Table 3 reports the features of the walls. Walls 1–2 (Wall-SW and Wall-NW in Table 3) are external walls (see Figure 6). Their thickness, which is greater than the thickness of the other walls, is 420 [mm] and their intermediate layer is constituted by extruded expanded polystyrene. Their total thermal transmittance is $0.3 \text{ [W/(m}^2 \cdot \text{K)]}$, i.e., they have a high opposition to thermal radiation. Windows are located on wall one. Walls 3–4 (Wall-SE and Wall-NE in Table 3) are characterized by a thickness equal to 300 [mm] (see Figure 6) and by a lower thermal resistance with respect to the exposed walls. The attic floor wall (Wall-A in Table 3) is similar to walls 1–2, while the intermediate floor wall (Wall-B in Table 3) is characterized by a thermal resistance lower than the attic floor wall [42].



Figure 6. Top view and planimetry of the room (simulated environment).

With regard to the windows, they are characterized by an athermal single glass type, and the transmissivity factor of the glass is equal to 0.46. Through suitable computations, the other parameters related to the thermal behavior of the windows, e.g., solar gain coefficients, were achieved. In addition, tailored computations were performed for achieving the thermal transmittance of the windows, differentiating between the glass-only case and the glass together with shutters case [42].

The room temperature computed by the thermal model is assumed to be the mean temperature of the room (neglecting the temperature layering). The heat pump source contribution will be positive in the case of heating and negative in the case of cooling [51].

With regard to the lighting model, the artificial source is supposed to be located in the middle of the $x - y$ plane of the room (see Table 3), and it is considered a point of light source (see Section 2.2.2 and Figure 7). Furthermore, the artificial source is assumed to be capable of guaranteeing the same illuminance to both work positions (see Figure 6) [46,47]. The point of interest of the lighting model is assumed to be a single point of interest in the room, which was set at the coordinates (2.5, 2.0, 1.0) [m], i.e., in the middle point of the room at a height of 1 [m] above the floor. The choice of using illuminance at the midpoint of the room was mainly because, in most practical applications, only one luxmeter was available for each room [46,47].




Figure 7. Light emission (simulated environment).

With regard to both thermal and lighting models, the actuation factor of each rolling shutter is a value in the range 0–1 (0 corresponds to an open rolling shutter, 1 corresponds to a closed rolling shutter).

For the IAQ model (see Section 2.2.3), it is assumed that there are two desks composed of laminated panels and a bookcase in the office (see Figure 6). For a work desk height, a horizontal plane with an elevation equal to 0.8 [m] from the floor is assumed. The correspondent average HCHO emission value used in the equation is 3.5 [mg/(m²·h)] and the furniture's TVOC average emission per unit is used in the model is 0.125 [μg/(m²·s)]. Furthermore, CO₂ average emission produced by two users in sedentary work is assumed to be 0.019 [m³CO₂/s] [52,53]. Finally, in order to enhance the fit of the framework for the real process, window opening is inhibited if wind speed is greater than a threshold value, i.e., 0.3 [m/s].

2.3. HVAC Control Framework

Based on the HVAC simulation framework described in Section 2.2, a HVAC control framework was designed and implemented. First, the MVs, the CVs, and the DVs were defined. The MVs group includes the heat supplied by the heat pump source, the shutter actuation factor of each of the two rolling shutters, the dimming of the artificial light, and the actuation of the natural ventilation through window opening. The CVs are the mean room temperature, the environment illuminance at the point of interest, and the IAQ parameters. The DVs are the outside temperature, the thermal radiation related to the window's glass and to the walls, the natural illuminance, the heat supplied by the internal heat sources (people, lamps, and motors), and the wind speed.

The control system must guarantee the desired comfort within the room but at the same time must ensure the maximization of energy saving. This last objective can be obtained by maximizing the natural energy sources exploitation. This target can be put into practice, ensuring an efficient multi-variable control of the defined CVs. As previously described, the heat transfer through the glass windows affects the room temperature. The heat is generated by the solar radiation; rolling shutters can be used to regulate this contribution. In addition, the opening of the windows also affects the temperature of the room through the dynamic exchange of fluid. The room illuminance is affected by

the rolling shutters' positions, which diffuse and reflect natural contributions. For this reason, the controller must manage possible conflicts between lighting and thermal control objectives [13].

In order to design a flexible control system, Energy Saving and Comfort and Energy Saving control policies were designed. These control policies are defined in the present research work, taking into account different control specifications. For brevity, Comfort and Energy Saving control policy will be indicated as Comfort policy in the following. Energy saving is the main specification in the Energy Saving control policy while fulfilling constraints on user comfort is the main goal in the Comfort control policy. In order to evaluate the CO₂ emissions performances, energy ([kWh]) and CO₂ emissions were related through a linear relationship [54].

The HVAC control framework was based on the use of different PID architectures combined with DEDES (automata) [55] control architectures to obtain a multi-mode control system. Each controller was equipped with anti-wind-up schemes and automatic/manual modes with bumpless transfer techniques (see Section 2.1).

Thanks to the flexibility of the developed simulation and control framework, two main control systems were designed and compared. In the following, the first one will be indicated as the *initial* control system while the second one as the *modified* control system. With regard to the tuning of the controllers included in the *initial* and *modified* control systems (see Sections 2.3.1 and 2.3.2), the methods presented in Section 2.1 were exploited.

To the best of the authors' knowledge, the flexibility of the proposed simulation and control framework represents an innovation in the literature of control systems for energy saving and comfort management in HBA. Thanks to this feature, the frameworks can be adapted based on the environments to be considered as case studies and the controllers to be designed. Different environments can be modeled and simulated in the simulation framework and different control algorithms can be straightly switched in order to compare their performances.

2.3.1. Initial Control System

The architecture related to the *initial* control system is shown in Figure 8. A hybrid scheme consisting of PID controllers in a split-range configuration and a DEDES-based (automatic) supervision module performs the thermal control. A split-range configuration is used in order to split the thermal control efforts, considering the three available MVs (rolling shutters, heat pumps, and windows). MVs sequences are assigned based on the energy consumption profile, i.e., a higher priority is assigned to MVs with a lower energy effort (cost). For this reason, heat pumps have the lowest priority. The DEDES-based (automatic) supervision module represents the splitter of the split range architecture. Based on the current process state, the automata take into consideration all process conditions, such as the malfunction of an actuator or unavailability of an actuator. Six states characterize the designed automata, together with events' set of fifteen elements (see Figure 9 and Table 8). A state represents a defined operating mode. MVs' availability differentiates each operating mode. Table 8 shows the operating modes of the split range configuration ("1" indicates that the considered actuator is available). The states associated with the simultaneous availability of the heat pump and of the windows were assumed to be inadmissible due to energy efficiency purposes. Furthermore, the rolling shutters can be used only if solar radiation is present. States transitions within the automata are triggered by events which are the result of the combination of the following parameters:

- Period of the day (i.e., daytime, nighttime)
- Presence or absence of solar radiation
- Thresholds on the tracking error between the desired reference temperature and the room temperature at different ranges were defined (e.g., tracking error range 0 is associated with a tracking error in the range between -0.2 [°C] and 0.2 [°C])
- Thresholds on the difference between the room temperature and the outside temperature at different ranges were defined (e.g., difference range 0 is associated with a

difference in the range between $-2 [^{\circ}\text{C}]$ and $2 [^{\circ}\text{C}]$, while a range 1 is associated with a difference greater than $2 [^{\circ}\text{C}]$)

- Control efforts required for the heat pump
- System switch off




Figure 8. Architecture of the *initial* control system.




Figure 9. Automata (for the split range of the thermal control) of the *initial* control system.

Table 8. Split range operating modes (thermal control, *initial* control system).

State	Window	Rolling Shutters	Heat Pump
S1	1	1	0
S2	1	0	0
S3	0	1	1
S4	0	1	0
S5	0	0	1
S6	0	0	0

All the events obtained are mutually exclusive. With regard to the control efforts required for the heat pump, if the computed control effort is less than a defined threshold (e.g., 10 [%] of the operating range), the heat pump is switched off. In this way, a major opportunity for intervention is given to the other actuators, e.g., the windows. With regard to the thresholds related to tracking error and the difference between the room temperature and the outside temperature, a suitable hysteresis was added in order to avoid oscillatory behaviors and excessive changes in the asset [38,41]. Table 9 reports the description of some events depicted in Figure 9, while Table 10 reports an example of the state transition matrix related to the first five events.

Table 9. Events description (splitter of the thermal control, *initial* control system).

Event	Description
0	switch-off of the devices
1	daytime, solar radiation, tracking error range 0, difference range 0
2	daytime, no solar radiation, tracking error range 0, difference range 0
3	daytime, solar radiation, tracking error range 0, difference range 1
4	daytime, no solar radiation, tracking error range 0, difference range 1

Table 10. Sub-part of the state transition matrix (splitter of the thermal control, *initial* control system).

Event	Initial State					
	S1	S2	S3	S4	S5	S6
0	S6	S6	S6	S6	S6	S6
1	S1	S1	S3	S4	S3	S4
2	S2	S2	S5	S6	S5	S6
3	S4	S4	S3	S4	S3	S4
4	S6	S6	S5	S6	S5	S6

With regard to the lighting control, the dimmer control effort is computed by the controller EC |0101 (see Figure 8). Since the dimmer control effort can be reduced through the exploitation of natural light, a second controller (MPC |0101 in Figure 8) is placed in the valve position configuration with a setpoint equal to zero. Finally, a third controller (TEC |0104) is present; its main function is to not exceed the illuminance threshold acting on the rolling shutters. An override logic handles MPC |0101 and TEC |0104 controllers (low-pass mode). MPC |0101 was tuned as a faster controller with respect to TEC |0104 in order to limit the dimmer control effort.

In order to handle eventual contrasting requests between thermal and lighting control objectives, an additional override module was added to the control architecture (see Figure 8). This module selects the input signals based on four system configurations, obtained by pairing Energy Saving/Comfort control policies and heating/cooling conditions. The Energy Saving control policy requires the reduction of power consumption as much as possible. If the cooling condition is considered, rolling shutters must be used in order to reduce the use of heat pumps. Conversely, Comfort control policy assigns high priority to the lighting control, and natural illuminance is preferred for the tracking of

the desired setpoint. Comfort preferences may be required by the users; for this purpose, specific management constraints were implemented, e.g., for constrained manipulation of the shutter position within defined limits. In this condition, if the rolling shutters saturate the constraints, a request for heat pump activation could be needed.

2.3.2. Modified Control System

The *modified* control system considers the room temperature and the room illuminance together with the IAQ. An enhanced thermal control policy was introduced with respect to the *initial* control system, together with an anti-glare logic and a function that allows for the consideration of solar radiation. The *modified* control system architecture is reported in Figures 10 and 11. Table 11 reports the symbols and the detailed description of the functional blocks depicted in Figures 10 and 11. In addition to the mentioned novelties, IAQ control is introduced; the MV associated with windows' opening and closing is delegated to this task. For this purpose, as can be observed in Figure 10, the window actuation is elevated to a supervisory level and must be considered a DV for the thermal control system.




Figure 10. Architecture of the *modified* control system (thermal and lighting control).




Figure 11. Architecture of the *modified* control system (IAQ control).

Table 11. Functional blocks description (*modified* control system).

Symbol	Description
EC 0101	PID controller, lighting control
TC 0102	PID controller, thermal control
TEC 0103	PID controller, thermal limitation
MPC 0102	PID controller, motor position control
TEC 0105	PID controller, lighting limitation
MPC 0101	PID controller, dimmer position control
MODE	Logic, control mode
XC 001	Logic, presence radiation
XC 002	Logic, no excessive brightness
AC 001	PID controller, CO ₂ limitation
AC 002	PID controller, HCHO limitation

As can be noted in Figure 10, the lighting control of the *modified* control system is the same as the *initial* control system (see Figure 8). Three inter-connected PID controllers characterize the new thermal control system architecture: TC | 0102, TEC | 0103, and MPC | 0102. The activation of the heat pump is managed by TC | 0102, which exploits thermostat information. Heat pump control effort is optimized through MPC | 0102, which is added to the valve position configuration with TC | 0102. A third controller TEC | 0103 is added through an override architecture with MPC | 0102 in order to suggest the rolling shutter actuation for the thermal control.

Possible conflicting requirements on rolling shutters between thermal and lighting control systems are handled through a personal comfort logic (PCL) module (see Figures 10 and 12), depending on the policy (Energy Saving or Comfort) and on the condition (heating or cooling). As can be noted in Figure 12, four states characterize the PCL module: each state is associated with a control action. In state “MIN selection”, a coupled thermal and lighting control action with an override architecture configured in low-pass mode is applied; in state “MAX selection” state, a high-pass mode is applied. In the other two states, priority is assigned to the thermal or lighting controller, respectively. When Energy Saving control policy is selected by the user, rolling shutters are used instead of the heat pump when possible. When Comfort control policy is selected by the user, natural illuminance is preferred for the achievement of lighting control objectives. In addition, the same comfort preference considerations given at the end of Section 2.3.1 also apply here.




Figure 12. Personal comfort logic (PCL) module configuration (*modified* control system).

The PCL module exploits the check “XC | 001–Direct solar radiation Presence Check” (see Figure 10). This check evaluates the presence of direct solar radiation on the glass wall. If direct solar radiation is detected, the selector operates normally. On the other hand, in the case of no solar radiation, the PCL module selects the rolling shutters’ values as defined

by the lighting control, because in this case, the influence of the solar radiation on room temperature is negligible. The PCL module also takes into account the thermal conduction/convection and the heat radiation contributions. Evaluating all the contributions, the PCL module infers the heat flow direction, i.e., from outside into the environment and vice versa. In this way, this information can be included in the coupled control logic, thus, finalizing the management policies of the rolling shutters.

In addition, the logic “XC | 002–Anti-glare” (see Figure 10) takes into account the sun position to evaluate possible glare effects in the environment and represents an additional check for rolling shutter actuation. For this purpose, azimuth and solar height are considered based on the latitude of the location [56]. This check was introduced in the controller through an override architecture (see Figure 10).

Figure 11 shows the IAQ control system; its functional blocks are described in Table 11. An intelligent logic evaluates the air quality (the presence of CO₂ and HCHO is considered in this section, without loss of generality) and decides the opening or closing of the windows. Suitable hysteresis logics were introduced in order to avoid chattering on the windows’ actuation. These logics pre-process the process variables exploited in the computation of tracking errors. IAQ control takes into account two aspects: not increasing energy consumption (such as by excessive window actuation) and not exceeding the imposed pollution limit. The control system works with a virtual sensor of the HCHO and of the CO₂ emissions (or a sensor if available) produced, respectively, by furniture and people. The same control architecture can be extended in order to include other pollutants, e.g., TVOC.

In the control scheme of Figure 11, two regulation loops are present, together with an override selector that allows maintaining the pollution values at fixed levels. Fixed levels that can be considered as maximum constraints are [12,57]:

- CO₂: 1500 [ppm];
- HCHO: 0.1 [ppm];
- TVOC: 300 [µg/m³].

In the previous bullet list, 1 [ppm] is equal to approximately 1000 [mg/m³]. This approach, related to the IAQ control, is known as “performance-based approach” [12,57].

To the best of the authors’ knowledge, the design of different advanced PID control architectures, exploiting different configurations, and defining different control specifications, represents an innovation in the literature of control systems for energy savings and comfort management in HBA. This feature allows for bridging the gap between non-optimized solutions and optimized ones, providing a coupled control of thermal, lighting, and IAQ sub-processes. In addition, to the best of the authors’ knowledge, the combination of advanced PID control architectures with DEDS for energy savings and comfort management in HBA is not present in the literature; this feature allows for smartly managing the huge number of operating conditions that can occur in HVAC processes. Finally, to the best of the authors’ knowledge, the elevation of the IAQ controller to a supervisory level with respect to thermal and lighting controllers represents further innovation that allows for efficiently handling the multi-variable nature of the HVAC processes.

2.4. Software

A MATLAB/Simulink environment was adopted for the HVAC simulation and control frameworks [58]. Furthermore, the MATLAB Identification Toolbox and the MATLAB Control System Toolbox were exploited for process identification and controllers’ synthesis [58].

The work has been executed using a laptop computer with the following specifications: Intel(R) Core(TM) i8-3840QM CPU with 3 GHz HDD.

3. Results and Discussion

3.1. Modelization Results

In order to evaluate the proposed HVAC simulation framework (see Section 2.2), tailored simulations were performed. Sampling time of the model was set equal to 60 s.

Figures 13–15 report room temperature and the illuminance of the modelization results assuming no action of the control devices (MVs). The results refer to the effects of the following selected DVs: outside temperature, thermal radiation related to the window glass, and natural illuminance on the walls. In Figure 13, the behavior of the solar radiation for one month is reported. Figure 14 reports the room temperature (blue line) together with the outside temperature (green line) and solar radiation (red line) disturbances. In Figure 15, the room illuminance at the height of the work desk (0.8 [m]) is depicted.




Figure 13. Modelization results: solar radiation.




Figure 14. Modelization results with no control actions: room temperature.




Figure 15. Modelization results with no control actions: room illuminance.

Figures 16–18 report some modelization results on IAQ variables in a typical working day. It is assumed that two people are present in the room during the hours 8–12 and 14–18. The windows are assumed to be closed when the people are in the room. In each figure, the black dashed line indicates the desired maximum constraint of the variable (see Section 2.3), while the variable is depicted by a blue line. Occupancy (suitably scaled) is depicted with a red line in Figure 16. With regard to Figures 16 and 17, as previously stated, 1 [ppm] is equal to approximately 1000 [mg/m³]. With regard to HCHO and TVOC, zero initial conditions are assumed (see Figures 17 and 18). Observing Figures 16–18, HCHO can be identified as the most critical IAQ variable.




Figure 16. Modelization results on IAQ variables: CO₂.




Figure 17. Modelization results on IAQ variables: HCHO.




Figure 18. Modelization results on IAQ variables: TVOC.

In order to efficiently tune the controllers described in Section 2.3, step tests were executed in the proposed HVAC simulation framework, assuming a manual management of the involved actuators, thus, setting the PID controllers in manual mode.

With regard to the thermal control through the heat pump (in both the *initial* and *modified* control systems), a unitary step was simulated on the actuator in order to evaluate the response of the room temperature. The other input variables that influenced the temperature were assumed to be constant. The following FOPDT model was assumed to approximate the behavior of the thermal model in the Laplace domain:

$$y(s) = \frac{0.0017}{370s + 1} e^{-345s} u(s) \quad (20)$$

where the time constant and the delay are expressed in seconds.

With regard to the IAQ control through window opening (in the *modified* control system), a step of 1 [m] was simulated on the actuator in order to evaluate the response of the CO₂ and of the HCHO. The step magnitude corresponds to the maximum width of the window opening. A wind speed of 0.15 [m/s] was assumed, which is the average value of wind speed among the values that allow windows to be opened. For the most critical IAQ variable, i.e., HCHO, from the step test, the α and τ parameters were found to be 860 [mg HCHO/m] and 80 [s], respectively (see Section 2.1).

3.2. Control Results

In this section, some tuning results are reported together with tailored simulations of the *initial* and *modified* control systems. Sampling time of the model and of the controllers were set equal to 60 s.

For the heat pump-based thermal controller, the approximate thermal model reported in Equation (20) has been considered in both the *initial* and *modified* control systems. The ratio between the delay and the time constant is:

$$\frac{L}{\tau} = \frac{345 \text{ [s]}}{370 \text{ [s]}} = 0.93 \quad (21)$$

Based on the theoretical assumptions reported in Section 2.1, the Smith predictor architecture reported in Figure 1 was applied to the heat pump-based thermal controller. In order to tune the PID parameters, the Ziegler–Nichols frequency response method (close-loop method; see Table 1) was used (see Figure 19). The ultimate gain (K_u) and the ultimate period (T_u) result in values equal to 0.4 [°C/W] and 1200 [s], respectively (see Figure 19). The PID parameters were computed based on Table 1. Different simulations were performed in order to adjust the parameters starting from the initial tuning. In particular, a faster response was sought while maintaining the overshoot limited to approximately 1.5 [%] of the temperature reference value. Table 12 reports the initial and final tuning parameters. Figures 20 and 21 report the performances related to the room temperature (CV) and the heat pump (MV) with different tuning parameters of the Smith predictor, or in the case of no Smith predictor. The green lines refer to the final tuning parameters in Table 12.




Figure 19. Control results: Smith predictor architecture tuning.

Table 12. Smith predictor architecture tuning.

Parameter	Initial Tuning Value	Final Tuning Value
K_P	0.24 [°C/W]	0.24 [°C/W]
T_I	600 [s]	20 [s]
T_D	150 [s]	150 [s]

In the *modified* control system, with regard to the IAQ controllers, the step tests described in Section 3.1 were exploited for the tuning of the PID parameters, using the Ziegler–Nichols step response method (open-loop method; see Table 2). With respect to the initial tuning parameters, HCHO controller parameters were modified, in order to obtain a faster response to formaldehyde, i.e., the most critical pollutant (see Section 3.1).




Figure 20. Control results: Smith Predictor architecture performances (CV).




Figure 21. Control results: Smith predictor architecture performances (MV).

Figures 22–25 report the results of the IAQ control over a day achieved by the *modified* control system. In the simulation, the season is assumed to be winter; the difference between room temperature and outside temperature is assumed to be equal to 10 [°C]. It is assumed that two people are present in the room during the hours 8–12 and 14–18. Figures 22–24 report the considered CVs, i.e., CO₂, HCHO, and TVOC. Figure 25 reports the MV, i.e., the window's opening width. In Figures 22–24, a black dashed line indicates the desired maximum constraint of the variable (see Sections 2.3 and 3.1), while the current process variable is depicted by a blue line. Occupancy (suitably scaled) is depicted by a green line in Figure 22. The MV, i.e., the window's opening width, is reported (suitably scaled) through a green line in Figure 23. In Figures 24 and 25, wind speed is also reported (suitably scaled). Looking at the figures, it can be seen that the control system is able to meet IAQ specifications in most cases. The only process condition where constraint violation was observed was when the wind speed was greater than 3 [m/s] (see Figures 24 and 25): windows cannot be opened (see Figure 25), and the HCHO violates its constraint (see Figure 23).




Figure 22. Control results: IAQ control, CO₂ (CV).




Figure 23. Control results: IAQ control, HCHO (CV).




Figure 24. Control results: IAQ control, TVOC (CV).




Figure 25. Control results: IAQ control, windows opening (MV).

The performance of the *initial* and *modified* control systems on thermal and lighting control is shown below by simulating three scenarios. An entire day is simulated in each scenario. The first scenario refers to the *initial* control system, while the second and third scenarios refer to the *modified* control system. The simulated scenarios refer to the winter and summer seasons, considering both control policies: Energy Saving and Comfort.

The first scenario is represented in Figures 26–29: it refers to the winter season; the *initial* control system supplies heat to the room in the Energy Saving policy (Figures 26 and 27) and in the Comfort policy (Figures 28 and 29). Figures 26 and 28 report the CVs (room temperature and room illuminance), while the MVs (heat pump, dimmer, and rolling shutters) are depicted in Figures 27 and 29. The room temperature setpoint is set to 22 [°C]. The defined room illuminance setpoint is 200 [Lux]. The controller requires a full opening of the rolling shutters: this action is executed because Energy Saving control policy is active. In this way, thermal solar radiation is exploited and energy saving target is pursued (see Figure 27). In Figure 26, it can be seen that during the middle hours of the day there is a high illuminance in the room, which may be excessive for the user. Comfort control policy performances are reported in Figures 28 and 29. In this case, the highest priority is retained by the room illuminance request: the rolling shutters are closed in the middle part of the day in order to respect the desired illuminance level through artificial light use (see Figures 28 and 29). The Comfort policy tries to search for an optimal tradeoff between energy savings and user comfort specifications: an energy consumption increase is observed in the middle part of the day (see Figure 29). On the day under consideration, thermal radiation is of low intensity: despite this fact, the Energy Saving control policy ensures a reduction in energy consumption compared to the Comfort policy (compare Figures 27 and 29). The transitions required by the controller result in increased control efforts by the heat pump.

The second scenario is represented in Figures 30–35: it refers to the winter season; the *modified* control system supplies heat to the room in the Comfort policy (Figures 30–32) and in the Energy Saving policy (Figures 33–35). Figures 30, 31, 33 and 34 report the CVs (blue lines), together with the defined setpoints (green lines), and two DVs, i.e., the outside temperature (red line) and solar radiation (magenta line). MVs are depicted in Figures 32 and 35, together with the presence of solar radiation. Time-varying setpoints are assigned to room temperature and illuminance. In particular, thanks to the presence check, tailored reference trajectories are imposed, taking into account the occupancy. Similar behaviors can be observed in both the control policies of the room temperature (see Figures 30 and 33); however, MVs behavior is quite different (see Figures 32 and 35): the use of the heat pump is minimized in the Energy Saving policy. This can be clearly observed during periods when solar radiation is present. A significant difference can be observed in room illuminance (see Figures 31 and 34): in the Comfort policy, the tracking of the required CVs setpoint has higher priority, so the rolling shutters are not immediately opened in the middle of the day

(when the solar radiation is present, see Figure 32). In this way, a satisfactory tracking of the room illuminance setpoint is obtained (see Figure 31). In the case of the Energy Saving policy, the rolling shutters are immediately opened in the middle of the day so as to allow for exploiting natural heat sources provided by the solar radiation. In this way, considering the higher cost of heat pump activation compared to other MVs, energy savings is achieved at the expense of less comfortable room illuminance.




Figure 26. Control results (first scenario, *initial* control system, Energy Saving policy): room temperature and room illuminance (CVs).




Figure 27. Control results (first scenario, *initial* control system, Energy Saving policy): MVs (heat pump, dimmer, and rolling shutters).




Figure 28. Control results (first scenario, *initial* control system, Comfort policy): room temperature and room illuminance (CVs).




Figure 29. Control results (first scenario, *initial* control system, Comfort policy): MVs (heat pump, dimmer, and rolling shutters).




Figure 30. Control results (second scenario, *modified* control system, Comfort policy): room temperature (CV), outside temperature, and solar radiation (DVs).




Figure 31. Control results (second scenario, *modified* control system, Comfort policy): room illuminance (CV).




Figure 32. Control results (second scenario, *modified* control system, Comfort policy): MVs (heat pump, dimmer, and rolling shutters) and DV (presence of solar radiation).




Figure 33. Control results (second scenario, *modified* control system, Energy Saving policy): room temperature (CV), outside temperature, and solar radiation (DVs).




Figure 34. Control results (second scenario, *modified* control system, Energy Saving policy): room illuminance (CV).




Figure 35. Control results (second scenario, *modified* control system, Energy Saving policy): MVs (heat pump, dimmer, and rolling shutters) and DV (presence of solar radiation).

The third scenario is represented in Figures 36–41: it refers to the summer season; the *modified* control system cools the room in the Comfort policy (Figures 36–38) and in the Energy Saving policy (Figures 39–41). Figures 36, 37, 39, and 40 report the CVs (blue lines), together with the defined setpoints (green lines), and two DVs, i.e., the outside temperature (red line) and solar radiation (magenta line). MVs are depicted in Figures 38 and 41, together with the presence of solar radiation. As in the second scenario, time-varying setpoints are assigned to room temperature and illuminance, considering the presence check. Similar behaviors can be observed in both the control policies on the room temperature (see

Figures 36 and 39); however, the MVs behavior is quite different (see Figures 38 and 41): the use of the heat pump is minimized in the Energy Saving policy. This control action causes a general reduction in the rolling shutters' opening in the Energy Saving policy (see Figures 38 and 41) and, as a consequence, a major increase in the usage of artificial light. These control actions generated some differences in the room illuminance behavior (see Figures 37 and 40).




Figure 36. Control results (third scenario, *modified* control system, Comfort policy): room temperature (CV), outside temperature, and solar radiation (DVs).




Figure 37. Control results (third scenario, *modified* control system, Comfort policy): room illuminance (CV).




Figure 38. Control results (third scenario, *modified* control system, Comfort policy): MVs (heat pump, dimmer, and rolling shutters) and DV (presence of solar radiation).




Figure 39. Control results (third scenario, *modified* control system, Energy Saving policy): room temperature (CV), outside temperature, and solar radiation (DVs).




Figure 40. Control results (third scenario, *modified* control system, Energy Saving policy): room illuminance (CV).




Figure 41. Control results (third scenario, *modified* control system, Energy Saving policy): MVs (heat pump, dimmer, and rolling shutters) and DV (presence of solar radiation).

In order to limit the overshoot of the room illuminance in the presence of solar radiation (main DV), suitable logic can be included to limit the rolling shutter actuation.

Observing the proposed simulations for the *initial* and *modified* control systems, the following conclusions on the control performances can be derived. The *initial* control system is characterized by weak points, mainly in the thermal control due to the presence of bumps on the heat pump control efforts (MV). This is an intrinsic behavior of the MV caused by the adopted thermal control architecture (combination of PID and DEDES). Starting from this consideration, the *modified* control system was designed to implement a different control solution based on the following principle: the thermal control system and

lighting have similar requirements and have been designed according to the same criteria of engineering. The *modified* control system was equipped with an enhanced thermal controller based on a more complex architecture. A new automaton has been designed to handle possible conflicting requirements between thermal and lighting controllers, exploiting also additional features, e.g., anti-glare and solar radiation presence. Furthermore, IAQ control was added to the *modified* control system, elevating the actuation of the windows to a supervisory level.

3.3. Energy Saving Results

In order to assess the CO₂ emissions reduction achievable through the proposed control systems, a linear relationship between energy ([kWh]) and CO₂ emissions has been exploited (see Section 2.3). The performances of the *initial* and the *modified* control systems have been compared to the performances of the standard decoupled thermal and lighting PID controllers. The standard PID controllers considered take into account the rolling shutters as measured DVs, while the heat pump and dimmer are the MVs of the thermal and lighting systems, respectively. Since the rolling shutters are measured DVs of the standard PID controllers, two significant conditions are considered in the simulations: the first condition refers to the worst case, i.e., assuming the rolling shutters closed in the winter season and opened in the summer season. The second condition refers to an “average” case, i.e., assuming the half-open rolling shutters. The *initial* and the *modified* control systems are simulated in both the Energy Saving and Comfort policies. Multiple simulations in each season were performed with different weather conditions, obtaining an average energy savings percentage performance for each season of the *initial* and the *modified* control systems with respect to the considered standard PID controllers in both the mentioned rolling shutter cases. Tables 13 and 14 report the results of the simulations performed for the different seasons. In addition, average yearly energy savings and worst yearly energy savings were evaluated for the *initial* and the *modified* control systems with respect to standard decoupled PID controllers (see Figure 42). To calculate the average yearly energy savings, the yearly results obtained based on the experiments shown in Tables 13 and 14 were averaged. On the other hand, to calculate the worst annual energy savings values, the proposed control systems were compared with standard decoupled PID controllers with half-open rolling shutters.

Table 13. Energy saving results: comparison between the *initial* control system and the standard decoupled PID controllers.

	Standard Decoupled PID (Open/Closed Shutters)		Standard Decoupled PID (Half-Open Shutters)	
Initial control system (Energy Saving)	Spring	Summer	Spring	Summer
	32 [%]	47 [%]	29 [%]	35 [%]
	Autumn	Winter	Autumn	Winter
	24 [%]	21 [%]	16 [%]	13 [%]
Initial control system (Comfort)	Spring	Summer	Spring	Summer
	11 [%]	41 [%]	6 [%]	25 [%]
	Autumn	Winter	Autumn	Winter
	22 [%]	19 [%]	15 [%]	11 [%]

As can be noted in Tables 13 and 14 and Figure 42, both the proposed control systems outperform the standard decoupled PID controllers. Furthermore, the *modified* control system outperforms the *initial* one due to the improved control and optimization features. Observing the results reported in Tables 13 and 14, a remarkable aspect can be highlighted: significant energy savings values are obtained in the Comfort policy by the proposed controllers in all the seasons (range 6 [%]–42 [%]). Furthermore, it should be emphasized that the data reported for the winter season refer to a situation where the heat provided by natural sources is minimal due to the unfavorable conditions of average daily solar radia-

tion. In addition, comparing the energy saving results obtained by the proposed controllers in the Energy Saving policy and in the Comfort policy, the Energy Saving policy shows the best performance compared to the Comfort policy. For example, considering the spring season, the high solar radiation forces the rolling shutters to remain almost closed during daylight hours; therefore, the Comfort policy is penalized in terms of energy efficiency.

Table 14. Energy saving results: comparison between the *modified* control system and the standard decoupled PID controllers.

	Standard Decoupled PID (Open/Closed Shutters)		Standard Decoupled PID (Half-Open Shutters)	
Modified control system (Energy Saving)	Spring	Summer	Spring	Summer
	32.5 [%]	48 [%]	30 [%]	35.5 [%]
	Autumn	Winter	Autumn	Winter
	24.5 [%]	22 [%]	16.5 [%]	14 [%]
Modified control system (Comfort)	Spring	Summer	Spring	Summer
	12 [%]	42 [%]	7 [%]	26 [%]
	Autumn	Winter	Autumn	Winter
	23 [%]	20 [%]	15.5 [%]	12 [%]



Figure 42. Energy saving results (average yearly energy savings and worst yearly energy savings): *initial* control system (**top**) and *modified* control system (**bottom**).

4. Conclusions

The present work aims at supplying contributions on simulation and control methods for home and building automation, focusing on heating, ventilating, and air conditioning processes. A simulation and control framework was designed and implemented for the thermal, lighting, and indoor air quality (IAQ) subprocesses. The simulation framework was based on first-principles and empirical models, including heat, lighting, and natural

ventilation phenomena. Energy-consuming and green energy-supplying renewable sources were integrated into the framework, e.g., heat pumps, artificial lights, fresh air flow, and natural illuminance.

Proportional–integral–derivative (PID) controllers were combined in different advanced architectures. Supervisors based on discrete event dynamic systems (DEDS) methodology were added to the control system, obtaining a multi-mode control framework. Control systems based on different advanced control architectures and different control policies were simulated and compared, highlighting control performances and energy-saving results in terms of CO₂ emissions reduction.

The present work provided qualitative and quantitative results. Qualitative results refer to some methodological innovations provided in the literature on control solutions for thermal, lighting, and IAQ subprocesses. The innovative methods concerned:

- The option to test and simulate different control systems in a flexible framework;
- The assessment of different advanced PID control architectures with the goal of achieving a coupled control of thermal, lighting, and IAQ subprocesses;
- The combination of advanced PID control architectures with DEDS for energy-saving and comfort management.

The proposed control systems achieved significant quantitative results compared with the more standard control approaches. In particular, seasonal and yearly simulations showed that energy-saving results greater than or equal to 6 [%] (in each season) and 19 [%] (in one year) could be achieved compared with the more standard approaches.

Future work will focus on further improving the proposed simulation and control frameworks by adding new features, e.g., multi-room environments, and including other control techniques, e.g., model predictive control. In addition, cost-benefit analysis and feasibility studies for field implementation will be carried out.

Author Contributions: Conceptualization, S.M.Z. and C.P.; methodology, S.M.Z. and C.P.; software, S.M.Z. and C.P.; validation, S.M.Z. and C.P.; formal analysis, S.M.Z. and C.P.; investigation, S.M.Z. and C.P.; data curation, S.M.Z. and C.P.; writing—original draft preparation, S.M.Z. and C.P.; writing—review and editing, S.M.Z. and C.P.; visualization, S.M.Z. and C.P. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Data Availability Statement: Not applicable.

Conflicts of Interest: The authors declare no conflict of interest.

References

1. European Parliament. Directive 2010/31/EU of the European Parliament and of the Council of 19 May 2010 on the energy performance of buildings (recast). *Off. J. Eur. Union* **2010**, *31*, L153/13–L153/35. Available online: <https://eur-lex.europa.eu/LexUriServ/LexUriServ.do?uri=OJ:L:2010:153:0013:0035:en:PDF> (accessed on 6 September 2022).
2. European Parliament. Directive 2018/844 of the European Parliament and of the Council of 30 May 2018 amending Directive 2010/31/EU on the energy performance of buildings and Directive 2012/27/EU on energy efficiency (Text with EEA relevance). *Off. J. Eur. Union* **2018**, L156/75–L156/91. Available online: <https://eur-lex.europa.eu/legal-content/EN/TXT/PDF/?uri=CELEX:32018L0844&from=IT> (accessed on 6 September 2022).
3. International Energy Agency, & United Nations Environment Programme. 2018 Global Status Report: Towards a Zero-Emission, Efficient and Resilient Buildings and Construction Sector. 2018. Available online: <https://wedocs.unep.org/20.500.11822/27140> (accessed on 6 September 2022).
4. United Nations. Agenda 2030. Available online: <https://unric.org/it/agenda-2030/> (accessed on 6 October 2022).
5. Ministero delle Imprese e del Made in Italy. PNRR. Available online: <https://www.mise.gov.it/index.php/it/pnrr> (accessed on 6 October 2022).
6. Ciardiello, A.; Rosso, F.; Dell’Olmo, J.; Ciancio, V.; Ferrero, M.; Salata, F. Multi-objective approach to the optimization of shape and envelope in building energy design. *Appl. Energy* **2020**, *280*, 115984. [CrossRef]
7. Zanolì, S.M.; Cocchioni, F.; Pepe, C. MPC-based energy efficiency improvement in a pusher type billets reheating furnace. *Adv. Sci. Technol. Eng. Syst. J.* **2018**, *3*, 74–84. [CrossRef]
8. Zanolì, S.M.; Pepe, C.; Rocchi, M. Control and Optimization of a Cement Rotary Kiln: A Model Predictive Control Approach. In Proceedings of the 2016 Indian Control Conference (ICC), Hyderabad, India, 4–6 January 2016. [CrossRef]

9. Zanolì, S.M.; Astolfi, G.; Orlietti, L.; Frisinghelli, M.; Pepe, C. Water Distribution Networks Optimization: A real case study. *IFAC-PapersOnLine* **2020**, *53*, 16644–16650. [CrossRef]
10. Zanolì, S.M.; Pepe, C.; Rocchi, M. Cement Rotary Kiln: Constraints Handling and Optimization via Model Predictive Control Techniques. In Proceedings of the 2015 5th Australian Control Conference (AUCC), Gold Coast, QLD, Australia, 5–6 November 2015; Available online: <https://ieeexplore.ieee.org/document/7361950> (accessed on 1 December 2020).
11. Zanolì, S.M.; Pepe, C.; Rocchi, M.; Astolfi, G. Application of Advanced Process Control Techniques for a Cement Rotary Kiln. In Proceedings of the 2015 19th International Conference on System Theory, Control and Computing (ICSTCC), Cheile Gradistei, Romania, 14–16 October 2015. [CrossRef]
12. ASHRAE. Available online: <https://www.ashrae.org/> (accessed on 6 October 2022).
13. Mayhoub, M.; Carter, D. A feasibility study for hybrid lighting systems. *Build. Environ.* **2012**, *53*, 83–94. [CrossRef]
14. Akkaya, K.; Guvenc, I.; Aygun, R.; Pala, N.; Kadri, A. IoT-Based Occupancy Monitoring Techniques for Energy-Efficient Smart Buildings. In Proceedings of the 2015 IEEE Wireless Communications and Networking Conference Workshops (WCNCW), New Orleans, LA, USA, 9–12 March 2015. [CrossRef]
15. Leal, S.; Zucker, G.; Hauer, S.; Judex, F. A Software Architecture for Simulation Support in Building Automation. *Buildings* **2014**, *4*, 320–335. [CrossRef]
16. Santos, A.; Liu, N.; Jradi, M. Design, Development and Implementation of a Novel Parallel Automated Step Response Testing Tool for Building Automation Systems. *Buildings* **2022**, *12*, 1479. [CrossRef]
17. Xie, X.; Ramakrishna, S.; Manganelli, M. Smart Building Technologies in Response to COVID-19. *Energies* **2022**, *15*, 5488. [CrossRef]
18. Pedersen, J.M.; Jebaei, F.; Jradi, M. Assessment of Building Automation and Control Systems in Danish Healthcare Facilities in the COVID-19 Era. *Appl. Sci.* **2022**, *12*, 427. [CrossRef]
19. Saleem, A.A.; Hassan, M.M.; Ali, I.A. Smart Homes Powered by Machine Learning: A Review. In Proceedings of the 2022 International Conference on Computer Science and Software Engineering (CSASE), Duhok, Iraq, 15–17 March 2022. [CrossRef]
20. Fayaz, M.; Kim, D. Energy Consumption Optimization and User Comfort Management in Residential Buildings Using a Bat Algorithm and Fuzzy Logic. *Energies* **2018**, *11*, 161. [CrossRef]
21. Sun, B.; Luh, P.B.; Jia, Q.-S.; Jiang, Z.; Wang, F.; Song, C. Building Energy Management: Integrated Control of Active and Passive Heating, Cooling, Lighting, Shading, and Ventilation Systems. *IEEE Trans. Autom. Sci. Eng.* **2012**, *10*, 588–602. [CrossRef]
22. Liu, W.; Wang, Y.; Jiang, F.; Cheng, Y.; Rong, J.; Wang, C.; Peng, J. A Real-time Demand Response Strategy of Home Energy Management by Using Distributed Deep Reinforcement Learning. In Proceedings of the 2021 IEEE 23rd International Conferences on High Performance Computing & Communications; 7th 23rd International Conferences on Data Science & Systems; 19th 23rd International Conferences on Smart City; 7th International Conferences on Dependability in Sensor, Cloud & Big Data Systems & Application (HPCC/DSS/SmartCity/DependSys), Haikou, China, 20–22 December 2021. [CrossRef]
23. Khalid, R.; Javaid, N.; Rahim, M.H.; Aslam, S.; Sher, A. Fuzzy energy management controller and scheduler for smart homes. *Sustain. Comput. Informatics Syst.* **2019**, *21*, 103–118. [CrossRef]
24. Soyguder, S.; Alli, H. Simulation and Modelling of HVAC System Having Two Zones with Different Properties. In Proceedings of the TOK2006 conference, Ankara, Turkey, 31 August–1 September 2006.
25. Zhou, J.Q.; Claridge, D.E. PI tuning and robustness analysis for air handler discharge air temperature control. *Energy Build.* **2012**, *44*, 1–6. [CrossRef]
26. Almabrok, A.; Psarakis, M.; Dounis, A. Fast Tuning of the PID Controller in An HVAC System Using the Big Bang–Big Crunch Algorithm and FPGA Technology. *Algorithms* **2018**, *11*, 146. [CrossRef]
27. Yamazaki, T.; Yamakawa, Y.; Kamimura, K.; Kurosu, S. Air-Conditioning PID Control System with Adjustable Reset to Offset Thermal Loads Upsets. In *Advances in PID Control*; IntechOpen: London, UK, 2011. [CrossRef]
28. Blasco, C.; Monreal, J.; Benítez, I.; Lluna, A. Modelling and PID Control of HVAC System According to Energy Efficiency and Comfort Criteria. In *Sustainability in Energy and Buildings. Smart Innovation, Systems and Technologies*; M'Sirdi, N., Namaane, A., Howlett, R.J., Jain, L.C., Eds.; Springer: Berlin/Heidelberg, Germany, 2012; Volume 12. [CrossRef]
29. Soyguder, S.; Karakose, M.; Alli, H. Design and simulation of self-tuning PID-type fuzzy adaptive control for an expert HVAC system. *Expert Syst. Appl.* **2009**, *36*, 4566–4573. [CrossRef]
30. Wang, J.-M.; Yang, M.-T.; Chen, P.-L. Design and Implementation of an Intelligent Windowsill System Using Smart Handheld Device and Fuzzy Microcontroller. *Sensors* **2017**, *17*, 830. [CrossRef]
31. Liu, J.; Zhang, W.; Chu, X.; Liu, Y. Fuzzy logic controller for energy savings in a smart LED lighting system considering lighting comfort and daylight. *Energy Build.* **2016**, *127*, 95–104. [CrossRef]
32. Ain, Q.-U.; Iqbal, S.; Mukhtar, H. Improving Quality of Experience Using Fuzzy Controller for Smart Homes. *IEEE Access* **2022**, *10*, 11892–11908. [CrossRef]
33. Fontes, F.; Antão, R.; Mota, A.; Pedreiras, P. Improving the Ambient Temperature Control Performance in Smart Homes and Buildings. *Sensors* **2021**, *21*, 423. [CrossRef]
34. Serale, G.; Fiorentini, M.; Capozzoli, A.; Bernardini, D.; Bemporad, A. Model Predictive Control (MPC) for Enhancing Building and HVAC System Energy Efficiency: Problem Formulation, Applications and Opportunities. *Energies* **2018**, *11*, 631. [CrossRef]
35. Yao, Y.; Shekhar, D.K. State of the art review on model predictive control (MPC) in Heating Ventilation and Air-conditioning (HVAC) field. *Build. Environ.* **2021**, *200*, 107952. [CrossRef]

36. Piotrowska-Woroniak, J.; Szul, T.; Cieśliński, K.; Krilek, J. The Impact of Weather-Forecast-Based Regulation on Energy Savings for Heating in Multi-Family Buildings. *Energies* **2022**, *15*, 7279. [[CrossRef](#)]
37. Åström, K.J.; Hägglund, T. *PID Controllers: Theory, Design, and Tuning*; ISA: Research Triangle Park, NC, USA, 1995.
38. O'Dwyer, A. *Handbook of PI and PID Controller Tuning Rules*; Imperial College Press: London, UK, 2009. [[CrossRef](#)]
39. Ljung, L. *System Identification. Theory for the User*; Prentice-Hall PTR: Upper Saddle River, NJ, USA, 1999.
40. Shinskey, F.G. *Process Control Systems: Application, Design, and Tuning*; McGraw-Hill Professional Publishing: New York, NY, USA, 1996.
41. Morari, M.; Zafiriou, E. *Robust Process Control*; Prentice-Hall PTR: Hoboken, NJ, USA, 1988.
42. Cammarata, G.; Fichera, A.; Forgia, F.; Marletta, L.; Muscato, G. Thermal Load Buildings: General Models and Reduced Models. In Proceedings of the Health Buildings, the 3rd International Conferences, Budapest, Hungary, 22–25 August 1994.
43. Mitsios, I.; Kolokotsa, D.; Stavrakakis, G.; Kalaitzakis, K.; Pouliezios, A. Developing a Control Algorithm for CEN Indoor Environmental Criteria—Addressing Air Quality, Thermal Comfort and Lighting. In Proceedings of the 2009 17th Mediterranean Conference on Control and Automation, Thessaloniki, Greece, 24–26 June 2009. [[CrossRef](#)]
44. De Santoli, L. Trasmissione del Calore. In *Fisica Tecnica Ambientale*; CEA: Milan, Italy, 1999; Volume 2.
45. Collares-Pereira, M.; Rabl, A. The average distribution of solar radiation-correlations between diffuse and hemispherical and between daily and hourly insolation values. *Sol. Energy* **1979**, *22*, 155–164. [[CrossRef](#)]
46. Bonomo, M. *Illuminazione D'interni*; Maggioli Editore: Santarcangelo di Romagna, Italy, 2009.
47. Paribeni, M.; Parolini, G. *Tecnica Dell'illuminazione*; UTET: Torino, Italy, 2009.
48. Wargocki, P.; Wyon, D.P.; Baik, Y.K.; Clausen, G.; Fanger, P.O. Perceived Air Quality, Sick Building Syndrome (SBS) Symptoms and Productivity in an Office with Two Different Pollution Loads. *Indoor Air* **1999**, *9*, 165–179. [[CrossRef](#)]
49. Dasi, H.; Xiaowei, F.; Daisheng, C. On-Line Control Strategy of Fresh Air to Meet the Requirement of IAQ in Office Buildings. In Proceedings of the 2010 5th IEEE Conference on Industrial Electronics and Applications, Taichung, Taiwan, 15–17 June 2010. [[CrossRef](#)]
50. Bako-Biro, Z.; Wargocki, P.; Weschler, C.J.; Fanger, P.O. Effects of pollution from personal computers on perceived air quality, SBS symptoms and productivity in offices. *Indoor Air* **2004**, *14*, 178–187. [[CrossRef](#)]
51. Kawachi, S.; Hagiwara, H.; Baba, J.; Furukawa, K.; Shimoda, E.; Numata, S. Modeling and Simulation of Heat Pump Air Conditioning Unit Intending Energy Capacity Reduction of Energy Storage System in Microgrid. In Proceedings of the 2011 14th European Conference on Power Electronics and Applications, Birmingham, UK, 30 August–1 September 2011.
52. European Parliament. Directive 2008/50/EC of the European Parliament and of the Council of 21 May 2008 on ambient air quality and cleaner air for Europe. *Off. J. Eur. Union* **2008**, L152/1. Available online: <https://eur-lex.europa.eu/legal-content/EN/TXT/HTML/?uri=CELEX:32008L0050&from=IT> (accessed on 6 September 2022).
53. European Parliament. Commission Directive (EU) 2015/1480 of 29 August 2015 amending several annexes to Directives 2004/107/EC and 2008/50/EC of the European Parliament and of the Council laying down the rules concerning reference methods, data validation and location of sampling points for the assessment of ambient air quality. *Off. J. Eur. Union* **2015**, L226/4. Available online: <https://eur-lex.europa.eu/legal-content/EN/TXT/HTML/?uri=CELEX:32015L1480&from=EN> (accessed on 6 September 2022).
54. International Energy Agency. *CO2 Emissions from Fuel Combustion 2019*; IEA: Paris, France, 2019. [[CrossRef](#)]
55. Cassandras, C.G.; Lafortune, S. *Introduction to Discrete Event Systems*; Springer Science & Business Media: Berlin/Heidelberg, Germany, 2007.
56. Health and Safety Executive (HSE). *Lighting at Work*; HSE Books: Norwich, UK, 1998.
57. Brager, G.S.; de Dear, R.J. Climate, comfort & natural ventilation: A new adaptive comfort standard for ASHRAE Standard 55. In Proceedings of the Moving Thermal Comfort Standards into the 21st Century, Windsor, UK, 5–8 April 2001. Available online: <http://www.escholarship.org/uc/item/2048t8nn>. (accessed on 1 December 2020).
58. MathWorks. Available online: <https://it.mathworks.com/> (accessed on 24 October 2022).

Disclaimer/Publisher's Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.