




Test: **Example for visual presentation of the results**


Measurement Location (1st floor, room type: patient room)




Measurement Point	3
Orientation	South
Measurement Time	10:08:45 AM 12-01-22
Measurement Height (cm)	104
Measurement of Spectrum Within the Visual Field (SPD)	



Visual (Image-forming Light)




Illuminance (Lux)





Color-rendering (CRI)



Colortemperature (K)



Non-image forming light (Integrative Lighting)



- Sleep promoting - 1 MEDI
- Active/ Awake Night - 10 MEDI
- Below Daytime Threshold
- Min. Daytime Threshold - 250 MEDI
- Superior Daytime Threshold - 500 MEDI

- Sleep Promoting - 0.3
- Active Light - 0.8
- D65 Daylight - 1.0