

Table S2. Bromate concentrations in sodium hypochlorite and in treated waters.

| Country | Number of water treatment works | BrO ₃ ⁻ in sodium hypochlorite [mg/L] | BrO ₃ ⁻ in treated waters [µg/L] | References |
|---------|---------------------------------|---|--|------------|
| Canada | 16 | 5.4 - 47.8 | 0.5 - 11.2 | [36] |
| USA | 40 | 12 - 35 | 0.46 - 7.7 | [47] |
| France | 3 | 82 - 857 | 3 - 7 | [48] |
| Japan | 28 | 96 (mean) - 414 | <10 | [49] |
| Spain | 261 | 219-7684 (median) 1022 | 1.0-49 | [50] |

References

36. Aranda-Rodriguez, R.; Lemieux, F.; Jin, Z.; Hnatiw, J.; Tugulea, A-M. (Yet more) challenges for water treatment plants: potential contribution of hypochlorite solutions to bromate, chlorate, chlorite and perchlorate in drinking water. *J Water Supply Res. Technol.* **2017**, *66*, 621-631. doi:10.2166/aqua.2017.147.
47. Weinberg H.S.; Delcomyn C. A.; Unnam V. Bromate in chlorinated drinking waters: occurrence and implications for future regulation, *Environ. Sci. Technol.* **2003**, *37*, 3104-3110. doi:10.1021/es026400z.
48. Bouland, S.; Duguet, J-P.; Montiel, A. Evaluation of bromate ions level introduced by sodium hypochlorite during post-disinfection of drinking water. *Environ. Technol.* **2005**, *26*, 121-125. doi:10.1080/09593332608618572.
49. Asami, M.; Kosaka, K.; Kunikane, S. Bromate, chlorate, chlorite and perchlorate in sodium hypochlorite solution used in water supply. *J Water Supply Res. Technol.* **2009**, *58*, 107-115, doi:10.2166/aqua.2009.014.
50. Garcia-Villanova, R.J.; Oliveira Dantas Leite, M.V.; Hernández Hierro, J.M.; De Castro Alfageme S.; García Hernández García C. Occurrence of bromate, chlorite and chlorate in drinking waters disinfected with hypochlorite reagents. Tracing their origins. *Sci. Total Environ.* **2010**, *408*, 2616-2620. doi:10.1016/j.scitotenv.2010.03.011.